



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 10, 2023 **Inspection Result:** **FAILED**

Permit Number: PRDE20221756

Property Address: 1106 VALLEY AVE NW, PUYALLUP, WA 98371;

Contractor: ASCENDENT LLC PO BOX 1150 SUMNER, WA 98390

To construct: Demolition of a SFR, two out buildings, decom of septic and capping of water from well (well to remain for 1036 use) asbestos removal, erosion control

On this day we have inspected your construction for **Utility Capping Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: septic tank has been demolished. still need

A well decommissioning certificate shall be filed with Pierce County and a copy submitted to the City of Puyallup.

Corrections:

- 1 The applicant shall demolish the existing private well per Tacoma Pierce County Health Department standards or install an approved reduced pressure backflow device on the City water service. A well decommissioning certificate shall be filed with Pierce County and a copy submitted to the City of Puyallup.

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424