



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Feb 10, 2023                      **Inspection Result:**     **FAILED**

**Permit Number:** PRDE20221756

**Property Address:** 1106 VALLEY AVE NW, PUYALLUP, WA 98371;

**Contractor:** ASCENDENT LLC PO BOX 1150 SUMNER, WA 98390

**To construct:** Demolition of a SFR, two out buildings, decom of septic and capping of water from well (well to remain for 1036 use) asbestos removal, erosion control

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** one of the out buildings was a well house with a well inside.  
condition #2 not met- - The applicant shall demolish the existing private well per Tacoma Pierce County Health Department standards or install an approved reduced pressure backflow device on the City water service. A well decommissioning certificate shall be filed with Pierce County and a copy submitted to the City of Puyallup

**Corrections:**

Sincerely,

Jeff Hill  
Engineering Tech IV  
Jhill@PuyallupWA.gov  
(253) 841-5424