



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 17, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCCP20220092

Property Address: 300 RIVER RD, PUYALLUP, WA 98371;

Contractor: WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW
GIG HARBOR, WA 98332

To construct: Construct underground utilities, storm drainage, replacements of
concrete curb, gutter, sidewalk, re-align driveway, replace driveways.
Remove & replace asphalt paving.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: collections was onsite at 7:30 am. the ran a camera through the 8" concrete line between cb#1&2. Kevin Carel (COP collections lead) said to abandon the line. The line was grouted shut 2' from each side of the new storm. Peterson installed the 12" storm from CB#2 to #1

Corrections:

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424