

Reviewed 2/23/2023 DL
Subject to field inspectors approvals.

THE APPROVED CONSTRUCTION
PLANS AND ALL ENGINEERING MUST
BE POSTED ON THE JOB AT ALL
INSPECTIONS IN A VISIBLE AND
READILY ACCESSIBLE LOCATION.

Structural Calculations

Steel Stockroom Shelving

By PIPP Mobile Storage Systems Inc.


PIPP PO #67120 SO #140336

City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic

Bath & Body Works #737 – Remote Storage

South Hill Mall
3500 S. Meridian Street – Space #142
Puyallup, Washington 98373

FEB 01 2023



Digitally signed by Rolf Henry
Armstrong

DN: E=rarmstrong@eeimt.com,
CN=Rolf Henry Armstrong,
O="Eclipse Engineering, P.C.",
L=Bend, S=Oregon, C=US
Date: 2023.02.01 18:24:22-08'00'

Prepared For:

PIPP Mobile Storage Systems Inc.
2966 Wilson Drive NW
Walker, MI 49534

Please note the calculations contained within justify the seismic resistance of the shelving for both vertical and lateral forces as required by the 2018 IBC, ASCE 7-16, and ANSI/RMI-MH16.1-2012. These storage shelves are not accessible to the general public.

PRCTI20230176

PIPP MOBILE STORAGE SYSTEMS INC.

STEEL STORAGE SHELVING - LIGHT RETAIL

CODES: Current Editions of the: IBC & CBC & ASCE 7 & RMI

Design Inputs: Steel Storage Shelving: MOBILE UNITS

Shelving Geometry -

Height of Shelving Unit =	10.0	ft	Steel Yield Stress =	33	ksi
Width of Shelving Unit =	4.0	ft	Modulus of Elast. =	29000	ksi
Depth of Shelving Unit =	2.5	ft	Eff. Lx Factor =	1.7	
Number of Shelves/Unit =	6		Unbraced Length,x =	22.5	in
Vertical Shelf Spacing =	22.5	in	Unbraced Length,y =	22.5	in
Back to Back Unit?	NO		Type of Post?	14ga Upright Posts	
Unit Type:	MOBILE		Type of Beam?	DRZ Z-Beam	
Number of Units per Track?	1		Top Shelf Loaded?	YES	
Mobile Anchor Spacing?	22.50	in	Intermediate Anchor:	Double	
Wall Supported Unit?	NO				

Shelving Loading -

Live Load per Shelf =	16.00	psf	Display On Plaque Near Shelving Units
Maximum Weight per Shelf =	160	lbs	Per 48.00 in. x 30.00 in. shelf
Dead Load per Shelf =	2.5	psf	Particle Board Shelf Material
Weight of Each Post =	7.4	lbs	Shelving is NOT accessible to public
Weight of Mobile Carriage =	50	lbs	

Floor Load Calculations:

Total Load on Each Post =	285	lbs	Ground Flr Conc Slab
Total Load On Each Unit =	1190	lbs	2500 psi NWC Concrete
Floor Area Load =	12.0	ft2	3/8"φ KB-TZ2 w/ 2.000" Embedment
Allowable Floor Loading =	100	psf	

Floor Load Under Shelf =	99	psf	OK FOR 100psf RETAIL FLOOR LOADING
--------------------------	----	-----	------------------------------------

Seismic Information -

Risk Category =	II	Not Open to the Public	SDC: D
Seismic Importance Factor (I_E) =	1.0		
Site Class =	D	- Default	Worst Case Assumed

Mapped Accel. Parameters:

$\rho = 1.3$			
$S_s = 1.264$	$F_a = 1.200$	$S_{ms} = 1.517$	$S_d_s = 1.011$
$S_1 = 0.436$	$F_v = 1.864$	$S_{m1} = 0.813$	$S_{d1} = 0.542$

Structural System: ASCE 7 Section 15.5.1

Steel Storage Shelving:	R = 4	$a_p = 2.5$	$l_p = 1.0$
Average Roof Height =	20	ft	0'-0" For Ground Floor Location
Height of Base Attachment =	0	ft	Ground Floor
Shear Coeff Boundaries =	$V_{min} = 0.044$	RMI, 2.6.3	
	$V_{max} = 0.253$	RMI, 2.6.3	

Design Base Shear Coeff =	$V_t = 0.230$	Adjusted For ASD	RMI, 2.6.3
---------------------------	---------------	------------------	------------

Lateral Force Distribution: per ASCE 7 Section 15.5.1

Total Dead Load per Level =	29.9	lbs
Total Live Load per Level =	160	lbs
Lateral DL Force per Level =	6.9	lbs
Lateral LL Force per Level =	36.8	lbs
67% of LL Force per Level =	24.7	lbs
Total DL Base Shear =	41.3	lbs
Total LL Base Shear =	220.8	lbs

LC1: Each Level, Loaded to 67% of its Live Weight

Cumulative Moment: 49570 in-lbs

Total Base Shear =	189.3	lbs
--------------------	-------	-----

LC #1 Governs

LC 2: Top Level Only, Loaded to 100% of its Live Weight

Cumulative Moment: 29457 in-lbs

Total Base Shear =	78.1	lbs
--------------------	------	-----

LC #2 Does NOT Govern

Shelf Heights:	Load Case #1:		Load Case #2:		Lateral Force/Shelf:		
	Load:	% Per Shelf:	Load:	% Per Shelf:	Force #:	LC #1:	LC #2:
h1 = 4 in	137 lbs	1.1%	30 lbs	0.4%	F1 =	2.1 lbs	0.3 lbs
h2 = 27 in	137 lbs	7.3%	30 lbs	2.7%	F2 =	13.9 lbs	2.1 lbs
h3 = 49 in	137 lbs	13.6%	30 lbs	5.0%	F3 =	25.7 lbs	3.9 lbs
h4 = 72 in	137 lbs	19.8%	30 lbs	7.3%	F4 =	37.4 lbs	5.7 lbs
h5 = 94 in	137 lbs	26.0%	30 lbs	9.5%	F5 =	49.2 lbs	7.5 lbs
h6 = 117 in	137 lbs	32.2%	190 lbs	75.1%	F6 =	61.0 lbs	58.7 lbs
h7 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F7 =	0.0 lbs	0.0 lbs
h8 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F8 =	0.0 lbs	0.0 lbs
h9 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F9 =	0.0 lbs	0.0 lbs
h10 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F10 =	0.0 lbs	0.0 lbs
h11 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F11 =	0.0 lbs	0.0 lbs
h12 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F12 =	0.0 lbs	0.0 lbs
h13 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F13 =	0.0 lbs	0.0 lbs
h14 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F14 =	0.0 lbs	0.0 lbs
h15 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F15 =	0.0 lbs	0.0 lbs
h16 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F16 =	0.0 lbs	0.0 lbs
h17 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F17 =	0.0 lbs	0.0 lbs
h18 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F18 =	0.0 lbs	0.0 lbs
h19 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F19 =	0.0 lbs	0.0 lbs
h20 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F20 =	0.0 lbs	0.0 lbs
		Sum = 100%		Sum = 100%	Total =	189.3 lbs	78.1 lbs

By inspection, the force distribution for intermediate level without live load (case 2) is negligible. Calculate the moment for each column based on the total seismic base shear for each shelf being loaded to 67% of its allowable live weight. The column at the center of the shelving system is the worst case for this condition.

Column Calculations - Combined Bending and Axial

Post Type: Double Rivet "L" or "T" Post

Width =	1.5	in	$r_x =$	0.470	in
Depth =	1.5	in	$S_x =$	0.044	in ³
Thickness =	0.075	in	$I_x =$	0.049	in ⁴
			$A_p =$	0.217	in ²

Column Bending Calculations -

Max Column Moment =	43.9	ft-lbs
Allowable Bending Stress =	19.8	ksi
Bending Stress on Column =	11.9	ksi

Bending Stress OK

Column Deflection Calculations -

Max Deflection =	0.457	in	At Top of Unit
Deflection Ratio =	263		L/Δ
Allowable Deflection =	6	in	Max Deflection = 5% of Height

Deflection OK

Column Axial Calculations - Per "L" Post

DL + PL =	285	lbs	RMI Load Combination #1
DL + PL + EQ =	414	lbs	RMI Load Combination #6

Column Capacity Calculations -

Controlling Buckling Stress =	9.6	ksi
Allowable Comp. Stress =	9.6	ksi
Factor of Safety for Comp. =	1.80	
Nominal Column Capacity =	2068	lbs
Allowable Column Capacity =	1149	lbs
Static Axial Load on Column =	285	lbs

Axial Load OK

Combined Bending And Axial Forces -

Critical Buckling Load =	9527	lbs	Magnification Factor =	0.946
Axial Stress Unity =	0.360		$C_m =$	0.85
Bending Stress Unity =	0.539			

Combined Stress Unity = 0.900

Column is Adequate

Overturing and Anti-Tip Calculations

Overturing Forces On Anchors (LRFD)

Overstrength Factor, $\Omega = 2.00$

Load Combination	Total Weight, W (lbs)	Base Shear, Eh (lbs)	Vertical Seismic Force, Ev (lbs)	Overturing Moment ($\Omega=2$), Mo (ft-lbs)	Resisting Moment, Mr (ft-lbs)	Net Overturing Moment, Mn (ft-lbs)	Shear Force per Anchor, V (lbs)	Tension Force per Anchor, T (lbs)
LC1	823	208	166	1469	718	751	104	301
LC2	340	86	69	750	296	454	43	182

$W(LC1) = (DL_{Shelf} + 0.67 * LL_{Shelf}) * \# \text{ of Shelves}$
 $W(LC2) = DL_{Shelf} * \# \text{ of Shelves} + LL_{Shelf}$
 $Eh = (Vt * W) / (0.7 * \rho)$
 $Ev = 0.20 * Sds * W$
 $Mo(LC1) = \Omega * \sum (hx * fx / 0.7)$
 $Mo(LC2) = \Omega * Vt / 0.7 * (DL_{Total} * (\frac{H}{2} + S) + LL_{Shelf} * H)$

$Mr = (0.9 * W - Ev) * \frac{d}{2}$
 $Mn = Mo - Mr$
 $V = \frac{\Omega * Eh}{\# \text{ of Anchors}}$
 $T = \frac{\frac{Mn}{d}}{\# \text{ of Anchors}}$

Per Side of Unit

USE: POST INSTALLED ANCHOR BOLTS / LAG SCREWS AS REQUIRED FOR FLOOR NOTED BELOW

Fixed Units - Allowable Loads
 Allowable Tension Force = 1327 lbs
 Allowable Shear Force = 1165 lbs

2500 psi NWC Concrete
 3/8" ϕ KB-TZ2 w/ 2.000" Embedment

Fixed Units - Combined Loading
 LC1: 0.227
 LC2: 0.137

Floor anchors are adequate

Mobile Unit Anchors -
 LC1: 0.415
 LC2: 0.251

Mobile Units - Allowable Loads
 Allowable Tension Force = 1448 lbs
 Allowable Shear Force = 1541 lbs

Floor anchors are adequate

Anti-Tip Track Design -

Type of Anti-Tip Device = **Arm and Track**

Tension per Carriage Anchor = 601 lbs

Combined Loading = 0.415

Tension per Shelf Post = 346 lbs

Capacity of Screws to Carriage = 1200 lbs

Floor anchors are adequate

(2) 1/4-in screws are adequate

Anti-Tip Peg Yield Stress = 40.275 ksi

Thickness Anti-Tip Peg Head = 0.09 in

Width of Anti-Tip Peg Head = 0.43 in

Section Modulus of Peg Head = 0.0006 in³

Steel Fy = 53.700 ksi

Fu = 63.800 ksi

Allowable Stress on Leg = 40.275 ksi

Bending Stress on Leg = 25.71 ksi

Anti-Tip Stress Unity = 0.638

Bending Stress OK

Section Modulus of Track = 0.093 in³

Spacing of Track A.B's = 22.50 in

Allowable Alumn. Stress = 21 ksi

Bending Stress on Track = 10.47 ksi

Track Stress Unity = 0.498

6061-T6 Fty = 35.000 ksi

Ftu = 38.000 ksi

Bending Stress OK

Shelf Beam Calculations

Shelf Beam Calculations:

DRZ Z-Beam

Steel Yield Stress = 33 ksi
Modulus of Elast. = 29000 ksi

Shelf DL = 2.5 psf
Shelf LL = 16.00 psf

Beam Type: DRZ Z-Beam

Area of Beam = 0.234 in²
Section Modulus of Beam = 0.054 in³
Moment of Inertia of Beam = 0.058 in⁴

Shelf Width = 4.0 ft
Shelf Depth = 2.5 ft
Total Load/Shelf = 185 lbs
Distributed Load = 23.125 plf

Allowable Bending Stress = 19.8 ksi
Allowable Shear Stress = 13.2 ksi

Maximum Design Moment = 46.3 ft-lbs
Maximum Design Shear = 46.3 lbs

Beam Bending Stress = 10.3 ksi
Bending Stress Unity = 0.519

Bending Stress OK

Beam Shear Stress = 0.20 ksi
Shear Stress Unity = 0.015

Shear Stress OK

Max Allowable Deflection = 0.267 in
Maximum Beam Deflection = 0.079 in

L/180
Deflection OK

Shelf Beam Rivet Check:

Diameter of Rivet = 0.25 in
Post Moment Shear on Rivet = 351.0 lbs
Beam Shear on Rivet = 46.3 lbs
Resultant Shear = 354.0 lbs

Bearing Capacity of Rivet = 519.8 lbs

Bearing Stress OK

Allowable Shear Stress = 13.5 ksi
Shear Stress on Rivet = 7.2 ksi

Shear Stress OK

Seismic Uplift on Shelves -

Vertical Seismic Component = 37.4 lbs
Vertical Total Load per Shelf = 137.1 lbs

Connection Points per Shelf = 4.0 (1) per Corner
Net Uplift Load per Shelf = -44.9 lbs

Uplift Forcer per Connection = -11.2 lbs

Rivet Connection OK

Slab Bearing & Uplift Calculations

Slab Design Properties -

Minimum Concrete Strength =	2500	psi	Assumed
Thickness of Concrete Slab =	4	in	Assumed
Weight of Concrete Slab =	50	psf	
Allowable Bearing Pressure =	500	psf	Assumed
Bearing Loads On Post =	45	lbs	Dead Load
	240	lbs	Live Load
	294	lbs	EQ Load
Uplift Loads on Post =	358	lbs	Resultant Uplift

Slab Bearing Capacity -

Depth of Post on Slab =	1.5	in	
Factored Bearing Load =	858	lbs	
Required Bearing Area =	166.66	in ²	12.91 inches per side
Critical Section =	3.70	in	For Bending
Soil Pressure on Crit. Section =	741.0	plf	Along Critical Length
Section Modulus =	32.0	in ³	Plain Concrete per Foot
Shear Area =	22	in	
Conc. Shear Stress =	9.7	psi	
Allowable Shear Stress =	73.2	psi	Shear Stress OK
Conc. Bending Stress =	13.2	psi	
Allowable Bending Stress =	137.5	psi	Bending Stress OK

Slab Uplift Capacity -

Required Area to Resist Uplift =	6.68	ft ²	
Length of Slab Req'd =	0.83	ft	Assume Required Area / Full Shelf Width
Worst Case Length of Slab =	1.25	ft	Maximum Length Required
Distance to Anchor Bolt =	0.63	ft	
Length of 1ft Strip =	1.25	ft	Length Safety Factor: 2.00
Shear Force on 1ft Strip =	87.5	lbs	
Allowable Shear Force =	1760.0	lbs	Shear OK
Bending Moment on 1ft Strip =	13.7	ft-lbs	
Allowable Bending Moment =	366.7	ft-lbs	Bending OK

PIPP MOBILE STORAGE SYSTEMS INC.

STEEL STORAGE SHELVING - LIGHT RETAIL

CODES: Current Editions of the: IBC & CBC & ASCE 7 & RMI

Design Inputs: Steel Storage Shelving: FIXED UNITS - 30" DEEP

Shelving Geometry -

Height of Shelving Unit =	10.0	ft	Steel Yield Stress =	33	ksi
Width of Shelving Unit =	4.0	ft	Modulus of Elast. =	29000	ksi
Depth of Shelving Unit =	2.5	ft	Eff. Lx Factor =	1.7	
Number of Shelves/Unit =	5		Unbraced Length,x =	21.0	in
Average Vertical Shelf Spacing =	22.5	in	Unbraced Length,y =	21.0	in
Back to Back Unit?	NO		Type of Post?	14ga Upright Posts	
Unit Type:	FIXED		Type of Beam?	DRZ Z-Beam	
Number of Units per Track?	NA		Top Shelf Loaded?	YES	
Mobile Anchor Spacing?		in	Intermediate Anchor:	Double	
Wall Supported Unit?	YES				

Shelving Loading -

Live Load per Shelf =	20.75	psf	Display On Plaque Near Shelving Units
Maximum Weight per Shelf =	205	lbs	Per 48.00 in. x 30.00 in. shelf
Dead Load per Shelf =	2.5	psf	Particle Board Shelf Material
Weight of Each Post =	7.4	lbs	Shelving is NOT accessible to public
Weight of Mobile Carriage =	0	lbs	

Floor Load Calculations:

Total Load on Each Post =	295	lbs	Ground Flr Conc Slab
Total Load On Each Unit =	1180	lbs	2500 psi NWC Concrete
Floor Area Load =	12.0	ft2	3/8"φ KB-TZ2 w/ 2.000" Embedment
Allowable Floor Loading =	100	psf	

Floor Load Under Shelf =	98	psf	OK FOR 100psf RETAIL FLOOR LOADING
--------------------------	----	-----	------------------------------------

Seismic Information -

Risk Category =	II	Not Open to the Public	SDC: D
Seismic Importance Factor (I_E) =	1.0		
Site Class =	D	- Default	Worst Case Assumed

Mapped Accel. Parameters:

$\rho = 1.3$			
$S_s = 1.264$	$F_a = 1.200$	$S_{ms} = 1.517$	$S_d_s = 1.011$
$S_1 = 0.436$	$F_v = 1.864$	$S_{m1} = 0.813$	$S_{d1} = 0.542$

Structural System: ASCE 7 Section 15.5.1

Steel Storage Shelving:	R = 4	$a_p = 2.5$	$l_p = 1.0$
Average Roof Height =	20	ft	0'-0" For Ground Floor Location
Height of Base Attachment =	0	ft	Ground Floor
Shear Coeff Boundaries =	$V_{min} = 0.044$	RMI, 2.6.3	
	$V_{max} = 0.253$	RMI, 2.6.3	

Design Base Shear Coeff =	$V_t = 0.230$	Adjusted For ASD	RMI, 2.6.3
---------------------------	---------------	------------------	------------

Lateral Force Distribution: per ASCE 7 Section 15.5.1

Total Dead Load per Level =	30.9	lbs
Total Live Load per Level =	205	lbs
Lateral DL Force per Level =	7.1	lbs
Lateral LL Force per Level =	47.2	lbs
67% of LL Force per Level =	31.6	lbs
Total DL Base Shear =	35.6	lbs
Total LL Base Shear =	235.8	lbs

LC1: Each Level, Loaded to 67% of its Live Weight Cumulative Moment: 59563 in-lbs

Total Base Shear =	193.5	lbs
--------------------	-------	-----

LC #1 Governs

LC 2: Top Level Only, Loaded to 100% of its Live Weight Cumulative Moment: 35541 in-lbs

Total Base Shear =	82.7	lbs
--------------------	------	-----

LC #2 Does NOT Govern

Shelf Heights:	Load Case #1:		Load Case #2:		Lateral Force/Shelf:		
	Load:	% Per Shelf:	Load:	% Per Shelf:	Force #:	LC #1:	LC #2:
h1 = 24 in	168 lbs	6.8%	31 lbs	2.1%	F1 =	13.1 lbs	1.7 lbs
h2 = 47 in	168 lbs	13.3%	31 lbs	4.1%	F2 =	25.7 lbs	3.4 lbs
h3 = 70 in	168 lbs	19.8%	31 lbs	6.1%	F3 =	38.3 lbs	5.0 lbs
h4 = 93 in	168 lbs	26.3%	31 lbs	8.1%	F4 =	50.8 lbs	6.7 lbs
h5 = 120 in	168 lbs	33.9%	236 lbs	79.7%	F5 =	65.6 lbs	65.9 lbs
h6 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F6 =	0.0 lbs	0.0 lbs
h7 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F7 =	0.0 lbs	0.0 lbs
h8 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F8 =	0.0 lbs	0.0 lbs
h9 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F9 =	0.0 lbs	0.0 lbs
h10 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F10 =	0.0 lbs	0.0 lbs
h11 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F11 =	0.0 lbs	0.0 lbs
h12 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F12 =	0.0 lbs	0.0 lbs
h13 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F13 =	0.0 lbs	0.0 lbs
h14 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F14 =	0.0 lbs	0.0 lbs
h15 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F15 =	0.0 lbs	0.0 lbs
h16 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F16 =	0.0 lbs	0.0 lbs
h17 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F17 =	0.0 lbs	0.0 lbs
h18 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F18 =	0.0 lbs	0.0 lbs
h19 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F19 =	0.0 lbs	0.0 lbs
h20 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F20 =	0.0 lbs	0.0 lbs
	Sum = 100%		Sum = 100%		Total =	193.5 lbs	82.7 lbs

By inspection, the force distribution for intermediate level without live load (case 2) is negligible. Calculate the moment for each column based on the total seismic base shear for each shelf being loaded to 67% of it's allowable live weight. The column at the center of the shelving system is the worst case for this condition.

Column Calculations - Combined Bending and Axial

Post Type: Double Rivet "L" or "T" Post

Width =	1.5	in	$r_x =$	0.470	in
Depth =	1.5	in	$S_x =$	0.044	in ³
Thickness =	0.075	in	$I_x =$	0.049	in ⁴
			$A_p =$	0.217	in ²

Column Bending Calculations -

Max Column Moment =	45.1	ft-lbs
Allowable Bending Stress =	19.8	ksi
Bending Stress on Column =	12.2	ksi

Bending Stress OK

Column Deflection Calculations -

Max Deflection =	0.418	in	At Top of Unit
Deflection Ratio =	287		L/Δ
Allowable Deflection =	6	in	Max Deflection = 5% of Height

Deflection OK

Column Axial Calculations - Per "L" Post

DL + PL =	295	lbs	RMI Load Combination #1
DL + PL + EQ =	426	lbs	RMI Load Combination #6

Column Capacity Calculations -

Controlling Buckling Stress =	10.4	ksi
Allowable Comp. Stress =	10.4	ksi
Factor of Safety for Comp. =	1.80	
Nominal Column Capacity =	2247	lbs
Allowable Column Capacity =	1248	lbs
Static Axial Load on Column =	295	lbs

Axial Load OK

Combined Bending And Axial Forces -

Critical Buckling Load =	10937	lbs	Magnification Factor =	0.951
Axial Stress Unity =	0.341		$C_m =$	0.85
Bending Stress Unity =	0.551			

Combined Stress Unity = 0.892

Column is Adequate

Overtipping and Anti-Tip Calculations

Overtipping Forces On Anchors (LRFD)

Overstrength Factor, $\Omega = 2.00$

Load Combination	Total Weight, W (lbs)	Base Shear, Eh (lbs)	Vertical Seismic Force, Ev (lbs)	Overtipping Moment ($\Omega=2$), Mo (ft-lbs)	Resisting Moment, Mr (ft-lbs)	Net Overtipping Moment, Mn (ft-lbs)	Shear Force per Anchor, V (lbs)	Tension Force per Anchor, T (lbs)
LC1	841	213	170	1539	734	805	106	322
LC2	360	91	73	832	314	518	45	207

Per Side of Unit

$$W(LC1) = (DL_{Shelf} + 0.67 * LL_{Shelf}) * \# \text{ of Shelves}$$

$$W(LC2) = DL_{Shelf} * \# \text{ of Shelves} + LL_{Shelf}$$

$$Eh = (Vt * W) / (0.7 * \rho)$$

$$Ev = 0.20 * Sds * W$$

$$Mo(LC1) = \Omega * \sum (hx * fx / 0.7)$$

$$Mo(LC2) = \Omega * Vt / 0.7 * (DL_{Total} * (\frac{H}{2} + S) + LL_{Shelf} * H)$$

$$Mr = (0.9 * W - Ev) * \frac{d}{2}$$

$$Mn = Mo - Mr$$

$$V = \frac{\Omega * Eh}{\# \text{ of Anchors}}$$

$$T = \frac{\frac{Mn}{d}}{\# \text{ of Anchors}}$$

USE: POST INSTALLED ANCHOR BOLTS / LAG SCREWS AS REQUIRED FOR FLOOR NOTED BELOW

Fixed Units - Allowable Loads	
Allowable Tension Force =	1327 lbs
Allowable Shear Force =	1165 lbs
Fixed Units - Combined Loading	LC1: 0.243 LC2: 0.156
Mobile Units - Combined Loading	LC1: N/A LC2: N/A

2500 psi NWC Concrete
3/8" ϕ KB-TZ2 w/ 2.000" Embedment

Floor anchors are adequate

Mobile Units - Allowable Loads
Allowable Tension Force = 1448 lbs
Allowable Shear Force = 1541 lbs

N/A

Anti-Tip Track Design -

Type of Anti-Tip Device =	NONE
Tension per Carriage Anchor =	N/A lbs
Combined Loading =	N/A
Tension per Shelf Post =	N/A lbs
Capacity of Screws to Carriage =	N/A lbs
Anti-Tip Peg Yield Stress =	40.275 ksi
Thickness Anti-Tip Peg Head =	0.09 in
Width of Anti-Tip Peg Head =	0.43 in
Section Modulus of Peg Head =	0.0006 in ³
Allowable Stress on Leg =	40.275 ksi
Bending Stress on Leg =	N/A ksi
Anti-Tip Stress Unity =	N/A
Section Modulus of Track =	0.093 in ³
Spacing of Track A.B's =	0.00 in
Allowable Alumn. Stress =	21 ksi
Bending Stress on Track =	N/A ksi
Track Stress Unity =	N/A

Steel Fy = 53.700 ksi
Fu = 63.800 ksi

N/A

6061-T6 Fty = 35.000 ksi
Ftu = 38.000 ksi

N/A

Shelf Beam Calculations

Shelf Beam Calculations:

DRZ Z-Beam

Steel Yield Stress = 33 ksi
 Modulus of Elast. = 29000 ksi

Shelf DL = 2.5 psf
 Shelf LL = 20.75 psf

Beam Type: DRZ Z-Beam

Area of Beam = 0.234 in²
 Section Modulus of Beam = 0.054 in³
 Moment of Inertia of Beam = 0.058 in⁴

Shelf Width = 4.0 ft
 Shelf Depth = 2.5 ft
 Total Load/Shelf = 233 lbs
 Distributed Load = 29.0625 plf

Allowable Bending Stress = 19.8 ksi
 Allowable Shear Stress = 13.2 ksi

Maximum Design Moment = 58.1 ft-lbs
 Maximum Design Shear = 58.1 lbs

Beam Bending Stress = 12.9 ksi
 Bending Stress Unity = 0.652

Bending Stress OK

Beam Shear Stress = 0.25 ksi
 Shear Stress Unity = 0.019

Shear Stress OK

Max Allowable Deflection = 0.267 in
 Maximum Beam Deflection = 0.100 in

L/180
Deflection OK

Shelf Beam Rivet Check:

Diameter of Rivet = 0.25 in
 Post Moment Shear on Rivet = 360.8 lbs
 Beam Shear on Rivet = 58.1 lbs
 Resultant Shear = 365.5 lbs

Bearing Capacity of Rivet = 519.8 lbs

Bearing Stress OK

Allowable Shear Stress = 13.5 ksi
 Shear Stress on Rivet = 7.4 ksi

Shear Stress OK

Seismic Uplift on Shelves -

Vertical Seismic Component = 47.0 lbs
 Vertical Total Load per Shelf = 168.3 lbs

Connection Points per Shelf = 4.0 (1) per Corner
 Net Uplift Load per Shelf = -53.9 lbs

Uplift Forcer per Connection = -13.5 lbs

Rivet Connection OK

Wall Supported Unit Calculations

Seismic Force at Top of Units -

Average Roof Height = 20.0 ft

Height of Attachment = 10.0 ft

Shear Coeff Boundaries = $V_{min} = 0.303$

$V_{max} = 1.618$

Design Base Shear Coeff = $V_t = 0.460$

Adjusted For ASD and "ρ"

Total Weight per Unit = 841 lbs

Lateral Force at Top/Bottom = 194 lbs

Standard Stud Spacing = 16 in

Wall Connections per Unit = 3

Tek Screw Capacity = 84 lbs

Force Per Connection = 65 lbs

Tension Cap. for #10 Screw in 20ga Stud

Screw Capacity OK

Light Gauge Steel Stud Wall Framing

Stud Design Data -

Height of Wall Studs =	16.0	ft	Int. Non-Brg - Worst Case Ht Assumed
Location of Point Load =	10.0	ft	
Design Lateral Load =	64.5	lbs	From Shelving Unit
Additional Lateral Load =	5.0	psf	Interior Seismic Force
Design Axial Load =	85.3	lbs	Dead Load of Wall Framing
Spacing of Studs =	16.0	in	

TRY: 3-5/8" x 1-5/8" x 20ga Studs @ 16" o.c. (Worst Case Assumed)

Width =	3.625	in	rx =	1.450	in
Depth =	1.625	in	ry =	0.616	in
Thickness =	0.035	in	Sx =	0.268	in ³
Fy =	33	ksi	Ix =	0.551	in ⁴
E =	29000	ksi	Ap =	0.262	in ²
K =	1.0		Unbraced Length X =	16	ft
			Unbraced Length Y =	4	ft

Stud Capacity -

Buckling Stress, X =	16.32	ksi
Buckling Stress, Y =	47.14	ksi
Allowable Buckling Stress =	16.32	ksi
Nominal Axial Strength =	4277	lbs
Factor of Safety =	1.92	
Allowable Axial Load =	2228	lbs
Maximum Design Moment =	455.3	ft-lbs
Maximum Design Shear =	93.7	lbs
Allowable Bending Stress =	21.78	ksi
Actual Bending Stress =	20.38	ksi
Allowable Shear Stress =	13.20	ksi
Actual Shear Stress =	0.36	ksi
Allowable Axial Stress =	8.50	ksi
Actual Axial Stress =	0.33	ksi

Bending Stress OK

Shear Stress OK

Axial Stress OK

Combined Stress Unity = 0.97

Combined Stress OK

Slab Bearing & Uplift Calculations

Slab Design Properties -

Minimum Concrete Strength =	2500	psi	Assumed
Thickness of Concrete Slab =	4	in	Assumed
Weight of Concrete Slab =	50	psf	
Allowable Bearing Pressure =	500	psf	Assumed
Bearing Loads On Post =	39	lbs	Dead Load
	256	lbs	Live Load
	308	lbs	EQ Load
Uplift Loads on Post =	381	lbs	Resultant Uplift

Slab Bearing Capacity -

Depth of Post on Slab =	1.5	in	
Factored Bearing Load =	896	lbs	
Required Bearing Area =	173.56	in ²	13.17 inches per side
Critical Section =	3.84	in	For Bending
Soil Pressure on Crit. Section =	743.4	plf	Along Critical Length
Section Modulus =	32.0	in ³	Plain Concrete per Foot
Shear Area =	22	in	
Conc. Shear Stress =	10.2	psi	
Allowable Shear Stress =	73.2	psi	Shear Stress OK
Conc. Bending Stress =	14.3	psi	
Allowable Bending Stress =	137.5	psi	Bending Stress OK

Slab Uplift Capacity -

Required Area to Resist Uplift =	0.00	ft ²	
Length of Slab Req'd =	0.00	ft	Assume Required Area / Full Shelf Width
Worst Case Length of Slab =	1.25	ft	Maximum Length Required
Distance to Anchor Bolt =	0.63	ft	
Length of 1ft Strip =	1.25	ft	Length Safety Factor: 2.00
Shear Force on 1ft Strip =	87.5	lbs	
Allowable Shear Force =	1760.0	lbs	Shear OK
Bending Moment on 1ft Strip =	13.7	ft-lbs	
Allowable Bending Moment =	366.7	ft-lbs	Bending OK

PIPP MOBILE STORAGE SYSTEMS INC.

STEEL STORAGE SHELVING - LIGHT RETAIL

CODES: Current Editions of the: IBC & CBC & ASCE 7 & RMI

Design Inputs: Steel Storage Shelving: FIXED UNITS - 18" DEEP

Shelving Geometry -

Height of Shelving Unit =	10.0	ft	Steel Yield Stress =	33	ksi
Width of Shelving Unit =	4.0	ft	Modulus of Elast. =	29000	ksi
Depth of Shelving Unit =	1.5	ft	Eff. Lx Factor =	1.7	
Number of Shelves/Unit =	5		Unbraced Length,x =	22.5	in
Average Vertical Shelf Spacing =	22.5	in	Unbraced Length,y =	22.5	in
Back to Back Unit?	NO		Type of Post?	14ga Upright Posts	
Unit Type:	FIXED		Type of Beam?	DRL Low Profile	
Number of Units per Track?	NA		Top Shelf Loaded?	YES	
Mobile Anchor Spacing?		in	Intermediate Anchor:	Double	
Wall Supported Unit?	YES				

Shelving Loading -

Live Load per Shelf =	23.00	psf	Display On Plaque Near Shelving Units
Maximum Weight per Shelf =	135	lbs	Per 48.00 in. x 18.00 in. shelf
Dead Load per Shelf =	2.5	psf	Particle Board Shelf Material
Weight of Each Post =	7.4	lbs	Shelving is NOT accessible to public
Weight of Mobile Carriage =	0	lbs	

Floor Load Calculations:

Total Load on Each Post =	195	lbs	Ground Flr Conc Slab
Total Load On Each Unit =	780	lbs	2500 psi NWC Concrete
Floor Area Load =	8.0	ft2	3/8"φ KB-TZ2 w/ 2.000" Embedment
Allowable Floor Loading =	100	psf	

Floor Load Under Shelf =	97	psf	OK FOR 100psf RETAIL FLOOR LOADING
--------------------------	----	-----	------------------------------------

Seismic Information -

Risk Category =	II	Not Open to the Public	SDC: D
Seismic Importance Factor (I_E) =	1.0		
Site Class =	D	- Default	Worst Case Assumed

Mapped Accel. Parameters:

$\rho = 1.3$			
$S_s = 1.264$	$F_a = 1.200$	$S_{ms} = 1.517$	$S_d_s = 1.011$
$S_1 = 0.436$	$F_v = 1.864$	$S_{m1} = 0.813$	$S_{d1} = 0.542$

Structural System: ASCE 7 Section 15.5.1

Steel Storage Shelving:	R = 4	$a_p = 2.5$	$l_p = 1.0$
Average Roof Height =	20	ft	0'-0" For Ground Floor Location
Height of Base Attachment =	0	ft	Ground Floor
Shear Coeff Boundaries =	$V_{min} = 0.044$	RMI, 2.6.3	
	$V_{max} = 0.253$	RMI, 2.6.3	

Design Base Shear Coeff =	$V_t = 0.230$	Adjusted For ASD	RMI, 2.6.3
---------------------------	---------------	------------------	------------

Lateral Force Distribution: per ASCE 7 Section 15.5.1

Total Dead Load per Level =	20.9	lbs
Total Live Load per Level =	135	lbs
Lateral DL Force per Level =	4.8	lbs
Lateral LL Force per Level =	31.1	lbs
67% of LL Force per Level =	20.8	lbs
Total DL Base Shear =	24.0	lbs
Total LL Base Shear =	155.3	lbs

LC1: Each Level, Loaded to 67% of its Live Weight Cumulative Moment: 39420 in-lbs

Total Base Shear =	128.1	lbs
--------------------	-------	-----

LC #1 Governs

LC 2: Top Level Only, Loaded to 100% of its Live Weight Cumulative Moment: 23601 in-lbs

Total Base Shear =	55.1	lbs
--------------------	------	-----

LC #2 Does NOT Govern

Shelf Heights:	Load Case #1:		Load Case #2:		Lateral Force/Shelf:		
	Load:	% Per Shelf:	Load:	% Per Shelf:	Force #:	LC #1:	LC #2:
h1 = 24 in	111 lbs	6.8%	21 lbs	2.1%	F1 =	8.7 lbs	1.2 lbs
h2 = 47 in	111 lbs	13.3%	21 lbs	4.2%	F2 =	17.0 lbs	2.3 lbs
h3 = 70 in	111 lbs	19.8%	21 lbs	6.2%	F3 =	25.3 lbs	3.4 lbs
h4 = 93 in	111 lbs	26.3%	21 lbs	8.2%	F4 =	33.7 lbs	4.5 lbs
h5 = 120 in	111 lbs	33.9%	156 lbs	79.3%	F5 =	43.4 lbs	43.7 lbs
h6 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F6 =	0.0 lbs	0.0 lbs
h7 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F7 =	0.0 lbs	0.0 lbs
h8 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F8 =	0.0 lbs	0.0 lbs
h9 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F9 =	0.0 lbs	0.0 lbs
h10 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F10 =	0.0 lbs	0.0 lbs
h11 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F11 =	0.0 lbs	0.0 lbs
h12 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F12 =	0.0 lbs	0.0 lbs
h13 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F13 =	0.0 lbs	0.0 lbs
h14 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F14 =	0.0 lbs	0.0 lbs
h15 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F15 =	0.0 lbs	0.0 lbs
h16 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F16 =	0.0 lbs	0.0 lbs
h17 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F17 =	0.0 lbs	0.0 lbs
h18 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F18 =	0.0 lbs	0.0 lbs
h19 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F19 =	0.0 lbs	0.0 lbs
h20 = 0 in	0 lbs	0.0%	0 lbs	0.0%	F20 =	0.0 lbs	0.0 lbs
Sum = 100%			Sum = 100%		Total =	128.1 lbs	55.1 lbs

By inspection, the force distribution for intermediate level without live load (case 2) is negligible. Calculate the moment for each column based on the total seismic base shear for each shelf being loaded to 67% of it's allowable live weight. The column at the center of the shelving system is the worst case for this condition.

Column Calculations - Combined Bending and Axial

Post Type: Double Rivet "L" or "T" Post

Width =	1.5	in	$r_x =$	0.470	in
Depth =	1.5	in	$S_x =$	0.044	in ³
Thickness =	0.075	in	$I_x =$	0.049	in ⁴
			$A_p =$	0.217	in ²

Column Bending Calculations -

Max Column Moment =	29.9	ft-lbs
Allowable Bending Stress =	19.8	ksi
Bending Stress on Column =	8.1	ksi

Bending Stress OK

Column Deflection Calculations -

Max Deflection =	0.277	in	At Top of Unit
Deflection Ratio =	434		L/Δ
Allowable Deflection =	6	in	Max Deflection = 5% of Height

Deflection OK

Column Axial Calculations - Per "L" Post

DL + PL =	195	lbs	RMI Load Combination #1
DL + PL + EQ =	342	lbs	RMI Load Combination #6

Column Capacity Calculations -

Controlling Buckling Stress =	9.6	ksi
Allowable Comp. Stress =	9.6	ksi
Factor of Safety for Comp. =	1.80	
Nominal Column Capacity =	2068	lbs
Allowable Column Capacity =	1149	lbs
Static Axial Load on Column =	195	lbs

Axial Load OK

Combined Bending And Axial Forces -

Critical Buckling Load =	9527	lbs	Magnification Factor =	0.963
Axial Stress Unity =	0.298		$C_m =$	0.85
Bending Stress Unity =	0.360			

Combined Stress Unity = 0.658

Column is Adequate

Overtipping and Anti-Tip Calculations

Overtipping Forces On Anchors

Overstrength Factor, $\Omega = 2.00$

(LRFD)

Load Combination	Total Weight, W (lbs)	Base Shear, Eh (lbs)	Vertical Seismic Force, Ev (lbs)	Overtipping Moment ($\Omega=2$), Mo (ft-lbs)	Resisting Moment, Mr (ft-lbs)	Net Overtipping Moment, Mn (ft-lbs)	Shear Force per Anchor, V (lbs)	Tension Force per Anchor, T (lbs)
LC1	557	141	113	1018	291	727	70	485
LC2	240	61	48	553	125	428	30	285

Per Side of Unit

$$W(LC1) = (DL_{Shelf} + 0.67 * LL_{Shelf}) * \# \text{ of Shelves}$$

$$W(LC2) = DL_{Shelf} * \# \text{ of Shelves} + LL_{Shelf}$$

$$Eh = (Vt * W) / (0.7 * \rho)$$

$$Ev = 0.20 * Sds * W$$

$$Mo(LC1) = \Omega * \sum (hx * fx / 0.7)$$

$$Mo(LC2) = \Omega * Vt / 0.7 * (DL_{Total} * (\frac{H}{2} + S) + LL_{Shelf} * H)$$

$$Mr = (0.9 * W - Ev) * \frac{d}{2}$$

$$Mn = Mo - Mr$$

$$V = \frac{\Omega * Eh}{\# \text{ of Anchors}}$$

$$T = \frac{\frac{Mn}{d}}{\# \text{ of Anchors}}$$

USE: POST INSTALLED ANCHOR BOLTS / LAG SCREWS AS REQUIRED FOR FLOOR NOTED BELOW

Fixed Units - Allowable Loads
 Allowable Tension Force = 1327 lbs
 Allowable Shear Force = 1165 lbs

2500 psi NWC Concrete
 3/8" ϕ KB-TZ2 w/ 2.000" Embedment

Fixed Units - Combined Loading
 LC1: 0.365
 LC2: 0.215

Floor anchors are adequate

Mobile Units - Combined Loading
 LC1: N/A
 LC2: N/A

Mobile Units - Allowable Loads
 Allowable Tension Force = 1448 lbs
 Allowable Shear Force = 1541 lbs

Anti-Tip Track Design -

Type of Anti-Tip Device = **NONE**

Tension per Carriage Anchor = N/A lbs

Combined Loading = N/A

Tension per Shelf Post = N/A lbs

Capacity of Screws to Carriage = N/A lbs

N/A

N/A

N/A

Anti-Tip Peg Yield Stress = 40.275 ksi
 Thickness Anti-Tip Peg Head = 0.09 in
 Width of Anti-Tip Peg Head = 0.43 in
 Section Modulus of Peg Head = 0.0006 in³

Steel Fy = 53.700 ksi
 Fu = 63.800 ksi

Allowable Stress on Leg = 40.275 ksi

Bending Stress on Leg = N/A ksi

Anti-Tip Stress Unity = N/A

N/A

Section Modulus of Track = 0.093 in³

Spacing of Track A.B's = 0.00 in

Allowable Alumn. Stress = 21 ksi

Bending Stress on Track = N/A ksi

Track Stress Unity = N/A

6061-T6 Fty = 35.000 ksi
 FtU = 38.000 ksi

N/A

Shelf Beam Calculations

Shelf Beam Calculations:

DRL Low Profile

Steel Yield Stress = 33 ksi
 Modulus of Elast. = 29000 ksi

Shelf DL = 2.5 psf
 Shelf LL = 23.00 psf

Beam Type: DRL Low Profile

Area of Beam = 0.264 in²
 Section Modulus of Beam = 0.098 in³
 Moment of Inertia of Beam = 0.072 in⁴

Shelf Width = 4.0 ft
 Shelf Depth = 1.5 ft
 Total Load/Shelf = 153 lbs
 Distributed Load = 19.125 plf

Allowable Bending Stress = 19.8 ksi
 Allowable Shear Stress = 13.2 ksi

Maximum Design Moment = 38.3 ft-lbs
 Maximum Design Shear = 38.3 lbs

Beam Bending Stress = 4.7 ksi
 Bending Stress Unity = 0.238

Bending Stress OK

Beam Shear Stress = 0.14 ksi
 Shear Stress Unity = 0.011

Shear Stress OK

Max Allowable Deflection = 0.267 in
 Maximum Beam Deflection = 0.053 in

L/180
Deflection OK

Shelf Beam Rivet Check:

Diameter of Rivet = 0.25 in
 Post Moment Shear on Rivet = 238.8 lbs
 Beam Shear on Rivet = 38.3 lbs
 Resultant Shear = 241.9 lbs

Bearing Capacity of Rivet = 519.8 lbs

Bearing Stress OK

Allowable Shear Stress = 13.5 ksi
 Shear Stress on Rivet = 4.9 ksi

Shear Stress OK

Seismic Uplift on Shelves -

Vertical Seismic Component = 30.9 lbs
 Vertical Total Load per Shelf = 111.4 lbs

Connection Points per Shelf = 4.0 (1) per Corner
 Net Uplift Load per Shelf = -35.9 lbs

Uplift Forcer per Connection = -9.0 lbs

Rivet Connection OK

Wall Supported Unit Calculations

Seismic Force at Top of Units -

Average Roof Height = 20.0 ft

Height of Attachment = 10.0 ft

Shear Coeff Boundaries = $V_{min} = 0.303$

$V_{max} = 1.618$

Design Base Shear Coeff = $V_t = 0.460$

Adjusted For ASD and "ρ"

Total Weight per Unit = 557 lbs

Lateral Force at Top/Bottom = 128 lbs

Standard Stud Spacing = 16 in

Wall Connections per Unit = 3

Tek Screw Capacity = 84 lbs

Force Per Connection = 43 lbs

Tension Cap. for #10 Screw in 20ga Stud

Screw Capacity OK

Light Gauge Steel Stud Wall Framing

Stud Design Data -

Height of Wall Studs =	16.0	ft	Int. Non-Brg - Worst Case Ht Assumed
Location of Point Load =	10.0	ft	
Design Lateral Load =	42.7	lbs	From Shelving Unit
Additional Lateral Load =	5.0	psf	Interior Seismic Force
Design Axial Load =	85.3	lbs	Dead Load of Wall Framing
Spacing of Studs =	16.0	in	

TRY: 3-5/8" x 1-5/8" x 20ga Studs @ 16" o.c. (Worst Case Assumed)

Width =	3.625	in	rx =	1.450	in
Depth =	1.625	in	ry =	0.616	in
Thickness =	0.035	in	Sx =	0.268	in ³
Fy =	33	ksi	Ix =	0.551	in ⁴
E =	29000	ksi	Ap =	0.262	in ²
K =	1.0		Unbraced Length X =	16	ft
			Unbraced Length Y =	4	ft

Stud Capacity -

Buckling Stress, X =	16.32	ksi
Buckling Stress, Y =	47.14	ksi
Allowable Buckling Stress =	16.32	ksi
Nominal Axial Strength =	4277	lbs
Factor of Safety =	1.92	
Allowable Axial Load =	2228	lbs
Maximum Design Moment =	373.4	ft-lbs
Maximum Design Shear =	80.0	lbs
Allowable Bending Stress =	21.78	ksi
Actual Bending Stress =	16.72	ksi
Allowable Shear Stress =	13.20	ksi
Actual Shear Stress =	0.31	ksi
Allowable Axial Stress =	8.50	ksi
Actual Axial Stress =	0.33	ksi

Bending Stress OK

Shear Stress OK

Axial Stress OK

Combined Stress Unity = 0.81

Combined Stress OK

Slab Bearing & Uplift Calculations

Slab Design Properties -

Minimum Concrete Strength =	2500	psi	Assumed
Thickness of Concrete Slab =	4	in	Assumed
Weight of Concrete Slab =	50	psf	
Allowable Bearing Pressure =	500	psf	Assumed
Bearing Loads On Post =	26	lbs	Dead Load
	169	lbs	Live Load
	339	lbs	EQ Load
Uplift Loads on Post =	420	lbs	Resultant Uplift

Slab Bearing Capacity -

Depth of Post on Slab =	1.5	in	
Factored Bearing Load =	786	lbs	
Required Bearing Area =	153.89	in ²	12.41 inches per side
Critical Section =	3.45	in	For Bending
Soil Pressure on Crit. Section =	735.8	plf	Along Critical Length
Section Modulus =	32.0	in ³	Plain Concrete per Foot
Shear Area =	22	in	
Conc. Shear Stress =	8.9	psi	
Allowable Shear Stress =	73.2	psi	Shear Stress OK
Conc. Bending Stress =	11.4	psi	
Allowable Bending Stress =	137.5	psi	Bending Stress OK

Slab Uplift Capacity -


Required Area to Resist Uplift =	0.00	ft ²	
Length of Slab Req'd =	0.00	ft	Assume Required Area / Full Shelf Width
Worst Case Length of Slab =	0.75	ft	Maximum Length Required
Distance to Anchor Bolt =	0.38	ft	
Length of 1ft Strip =	0.75	ft	Length Safety Factor: 2.00
Shear Force on 1ft Strip =	52.5	lbs	
Allowable Shear Force =	1760.0	lbs	Shear OK
Bending Moment on 1ft Strip =	4.9	ft-lbs	
Allowable Bending Moment =	366.7	ft-lbs	Bending OK

Geometric Properties	
Area	0.217 in ²
Ix	0.049 in ⁴
Ixy	-0.029 in ⁴
Iy	0.049 in ⁴
Sx+	0.044 in ³
Sx-	0.120 in ³
Sy+	0.044 in ³
Sy-	0.120 in ³
Xc	0.406 in
Yc	0.406 in
rx	0.473 in
ry	0.473 in
Polar Properties	
Ip	0.097 in ⁴
rp	0.669 in

Principal Properties	
I1	0.078 in ⁴
I2	0.019 in ⁴
S1+	0.074 in ³
S1-	0.074 in ³
S2+	0.035 in ³
S2-	0.036 in ³
r1	0.599 in
r2	0.296 in
o	45.000 deg
Overall Properties	
Depth	1.500 in
Perimeter	5.920 in
Weight	0.001 K/ft
Width	1.500 in

Torsion Properties	
Cw	0.000 in ⁶
H	0.626
J	0.000 in ⁴
Xsc	0.041 in
Ysc	0.041 in
ro	0.845 in
B1	0.000 in
Plastic Properties	
Xpna	0.074 in
Ypna	0.074 in
Zx	0.080 in ³
Zy	0.080 in ³

THESE ARE THE SECTION PROPERTY VALUES FOR THE "L" POST MEMBERS AT THE AREAS WITHOUT ANY HOLES THROUGH THE SECTION.



14 GA. "L" POST

PRCTI20230176


Geometric Properties	
Area	0.401 in ²
Ix	0.183 in ⁴
Ixy	0.000 in ⁴
Iy	0.192 in ⁴
Sx+	0.140 in ³
Sx-	0.291 in ³
Sy+	0.113 in ³
Sy-	0.113 in ³
Xc	0.676 in
Yc	0.629 in
rx	0.676 in
ry	0.692 in
Polar Properties	
Ip	0.375 in ⁴
rp	0.967 in

Principal Properties	
I1	0.192 in ⁴
I2	0.183 in ⁴
S1+	0.113 in ³
S1-	0.113 in ³
S2+	0.140 in ³
S2-	0.291 in ³
r1	0.692 in
r2	0.676 in
o	90.000 deg
Overall Properties	
Depth	1.938 in
Perimeter	14.293 in
Weight	0.001 K/ft
Width	3.387 in

Torsion Properties	
Cw	0.059 in ⁶
H	0.967
J	0.000 in ⁴
Xsc	1.693 in
Ysc	0.807 in
ro	0.983 in
B1	0.000 in
Plastic Properties	
Xpna	1.693 in
Ypna	0.238 in
Zx	0.231 in ³
Zy	0.205 in ³

16 GA. "T" POST

THESE ARE THE SECTION PROPERTY VALUES FOR THE "T" POST MEMBERS AT THE AREAS WITHOUT ANY HOLES THROUGH THE SECTION.




NOTE THAT THE "T" POST MEMBER SECTION PROPERTIES ARE APPROXIMATELY THREE TIMES THE VALUES FOR THE "L" POST MEMBERS, BUT ONLY SUPPORT ABOUT TWICE THE LOADS.

Geometric Properties		Principal Properties		Overall Properties	
Area	0.142 in ²	I1	0.067 in ⁴	Depth	1.500 in
Ix	0.041 in ⁴	I2	0.016 in ⁴	Perimeter	4.218 in
Ixy	-0.026 in ⁴	S1+	0.063 in ³	Weight	0.000 K/ft
Iy	0.041 in ⁴	S1-	0.063 in ³	Width	1.500 in
Sx+	0.040 in ³	S2+	0.034 in ³	Plastic Properties	
Sx-	0.089 in ³	S2-	0.026 in ³	Xpna	0.074 in
Sy+	0.040 in ³	r1	0.685 in	Ypna	0.074 in
Sy-	0.089 in ³	r2	0.332 in	Zx	0.060 in ³
Xc	0.461 in	o	45.000 deg	Zy	0.060 in ³
Yc	0.461 in	Polar Properties			
rx	0.539 in	Ip	0.083 in ⁴		
ry	0.539 in	rp	0.762 in		

Shear Flow		Qx		Qy		f(Vx)		f(Vy)	
Name		in ⁻³		in ⁻³		K/ft		K/ft	
Part #2 0		0.036	0.022	0.000	0.000	0.000	0.000	0.000	0.000
Part #3 0		0.014	0.014	0.000	0.000	0.000	0.000	0.000	0.000
Part #4 0		0.022	0.036	0.000	0.000	0.000	0.000	0.000	0.000

THESE ARE THE SECTION PROPERTY VALUES FOR THE "L" POST MEMBERS AT THE AREAS WITH THE RIVET-CONNECTION HOLES THROUGH THE SECTION.




14 GA. "L" POST

Geometric Properties		Principal Properties		Overall Properties	
Area	0.288 in ²	I1	0.156 in ⁴	Depth	1.938 in
Ix	0.156 in ⁴	I2	0.120 in ⁴	Perimeter	10.745 in
Ixy	0.000 in ⁴	S1+	0.125 in ³	Weight	0.001 K/ft
Iy	0.120 in ⁴	S1-	0.226 in ³	Width	3.387 in
Sx+	0.125 in ³	S2+	0.071 in ³	Plastic Properties	
Sx-	0.226 in ³	S2-	0.071 in ³	Xpna	1.693 in
Sy+	0.071 in ³	r1	0.735 in	Ypna	0.328 in
Sy-	0.071 in ³	r2	0.646 in	Zx	0.180 in ³
Xc	1.693 in	o	0.000 deg	Zy	0.132 in ³
Yc	0.689 in	Polar Properties			
rx	0.735 in	Ip	0.276 in ⁴		
ry	0.646 in	rp	0.978 in		

Shear Flow		Qx		Qy		f(Vx)		f(Vy)	
Name		in ⁻³		in ⁻³		K/ft		K/ft	
ClosedPoly 1		0.036	0.027	0.000	0.000	0.000	0.000	0.000	0.000
Part 1		0.013	0.030	0.000	0.000	0.000	0.000	0.000	0.000
Part 2		0.013	0.030	0.000	0.000	0.000	0.000	0.000	0.000
Part 3		0.097	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Part 4		0.036	0.027	0.000	0.000	0.000	0.000	0.000	0.000

THESE ARE THE SECTION PROPERTY VALUES FOR THE "T" POST MEMBERS AT THE AREAS WITH THE RIVET-CONNECTION HOLES THROUGH THE SECTION.



16 GA. "T" POST

NOTE THAT THE "T" POST MEMBER SECTION PROPERTIES ARE APPROXIMATELY THREE TIMES THE VALUES FOR THE "L" POST MEMBERS, BUT ONLY SUPPORT ABOUT TWICE THE LOADS.

Screw Capacities

Table Notes

- Capacities based on AISI S100 Section E4.
- When connecting materials of different steel thicknesses or tensile strengths, use the lowest values. Tabulated values assume two sheets of equal thickness are connected.
- Capacities are based on Allowable Strength Design (ASD) and include safety factor of 3.0.
- Where multiple fasteners are used, screws are assumed to have a center-to-center spacing of at least 3 times the nominal diameter (d).
- Screws are assumed to have a center-of-screw to edge-of-steel dimension of at least 1.5 times the nominal diameter (d) of the screw.
- Pull-out capacity is based on the lesser of pull-out capacity in sheet closest to screw tip or tension strength of screw.
- Pull-over capacity is based on the lesser of pull-over capacity for sheet closest to screw header or tension strength of screw.
- Values are for pure shear or tension loads. See AISI Section E4.5 for combined shear and pull-over.
- Screw Shear (Pss), tension (Pts), diameter, and head diameter are from CFSEI Tech Note (F701-12).
- Screw shear strength is the average value, and tension strength is the lowest value listed in CFSEI Tech Note (F701-12).
- Higher values for screw strength (Pss, Pts), may be obtained by specifying screws from a specific manufacturer.

Allowable Screw Connection Capacity (lbs)																		
Thickness (Mils)	Design Thickness	Fy Yield (ksi)	Fu Tensile (ksi)	#6 Screw (Pss = 643 lbs, Pts = 419 lbs)			#8 Screw (Pss = 1278 lbs, Pts = 586 lbs)			#10 Screw (Pss = 1644 lbs, Pts = 1158 lbs)			#12 Screw (Pss = 2330 lbs, Pts = 2325 lbs)			¼" Screw (Pss = 3048 lbs, Pts = 3201 lbs)		
				0.138" dia, 0.272" Head			0.164" dia, 0.272" Head			0.190" dia, 0.340" Head			0.216" dia, 0.340" Head			0.250" dia, 0.409" Head		
				Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over
18	0.0188	33	33	44	24	84	48	29	84	52	33	105	55	38	105	60	44	127
27	0.0283	33	33	82	37	127	89	43	127	96	50	159	102	57	159	110	66	191
30	0.0312	33	33	95	40	140	103	48	140	111	55	175	118	63	175	127	73	211
33	0.0346	33	45	151	61	140	164	72	195	177	84	265	188	95	265	203	110	318
43	0.0451	33	45	214	79	140	244	94	195	263	109	345	280	124	345	302	144	415
54	0.0566	33	45	214	100	140	344	118	195	370	137	386	394	156	433	424	180	521
68	0.0713	33	45	214	125	140	426	149	195	523	173	386	557	196	545	600	227	656
97	0.1017	33	45	214	140	140	426	195	195	548	246	386	777	280	775	1,016	324	936
118	0.1242	33	45	214	140	140	426	195	195	548	301	386	777	342	775	1,016	396	1,067
54	0.0566	50	65	214	140	140	426	171	195	534	198	386	569	225	625	613	261	752
68	0.0713	50	65	214	140	140	426	195	195	548	249	386	777	284	775	866	328	948
97	0.1017	50	65	214	140	140	426	195	195	548	356	386	777	405	775	1,016	468	1,067
118	0.1242	50	65	214	140	140	426	195	195	548	386	386	777	494	775	1,016	572	1,067

SUPREME* Allowable Screw Connection Capacity (Pounds Per Screw)																		
See back cover for exclusive manufacturers of the Supreme Framing System.																		
Thickness (mil)	Design Thickness (in)	Fy Yield (ksi)	Fu Tensile (ksi)	#6 Screw (Pss = 643 lbs, Pts = 419 lbs)			#8 Screw (Pss = 1278 lbs, Pts = 586 lbs)			#10 Screw (Pss = 1644 lbs, Pts = 1158 lbs)			#12 Screw (Pss = 2330 lbs, Pts = 2325 lbs)			¼" Screw (Pss = 3048 lbs, Pts = 3201 lbs)		
				0.138" Dia; 0.272" Head			0.164" Dia; 0.272" Head			0.190" Dia; 0.340" Head			0.216" Dia; 0.340" Head			0.250" Dia; 0.409" Head		
				Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over
D25	0.0155	57	65	65	39	137	150	47	137	77	54	171	-	-	-	-	-	-
D20	0.0188	57	65	142 ¹	48	140	150 ¹	57	166	164 ¹	66	208	109	75	208	-	-	-
30EQD	0.0235	57	65	174 ¹	60	140	184 ¹	71	195	236 ¹	82	260	152	93	260	-	-	-
33EQD	0.0235	57	65	174 ¹	60	140	184 ¹	71	195	236 ¹	82	260	152	93	260	-	-	-
33EQS	0.0295	57	65	171	75	140	187	89	195	201	103	326	214	117	326	231	136	392
43EQS	0.0400	57	65	270	102	140	295	121	195	317	140	386	338	159	442	364	184	532

¹Values are based on testing using AISI S100 procedures.

***SUPREME products are only available from those SSMA members who are certified to produce SUPREME products.**



Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC.
 Address: 376 SW Bluff Dr., Suite 8
 Phone | Fax: 541-389-9659 |
 Design: NWC- (1) KB-TZ2-0.375X2.0
 Fastening point: Base of Shelving Unit

Page: 1
 Specifier: nburnam
 E-Mail: nburnam
 Date: 8/6/2022

Specifier's comments: Single Anchor Condition


1 Input data

Anchor type and diameter: Kwik Bolt TZ2 - CS 3/8 (2) Inom2
Item number: 2210236 KB-TZ2 3/8x3
Effective embedment depth: $h_{ef,act} = 2.000$ in., $h_{nom} = 2.500$ in.
Material: Carbon Steel
Evaluation Service Report: ESR-4266
Issued | Valid: 12/17/2021 | 12/1/2023
Proof: Design Method ACI 318-14 / Mech



Stand-off installation:
Profile:
Base material: cracked concrete, 2500, $f_c' = 2,500$ psi; $h = 4,000$ in.
Installation: hammer drilled hole, **Installation condition:** Dry
Reinforcement: tension: condition B, shear: condition B; no supplemental splitting reinforcement present
 edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F): Tension load: yes (17.2.3.4.3 (d))
 Shear load: yes (17.2.3.5.3 (c))

Geometry [in.] & Loading [lb, in.lb]



Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC.
 Address: 376 SW Bluff Dr., Suite 8
 Phone | Fax: 541-389-9659 |
 Design: NWC- (1) KB-TZ2-0.375X2.0
 Fastening point: Base of Shelving Unit

Page: 2
 Specifier: nburnam
 E-Mail: nburnam
 Date: 8/6/2022

1.1 Design results

Case	Description	Forces [lb] / Moments [in.-lb]	Seismic	Max. Util. Anchor [%]
1	Load case: Design loads	N = 500; V _x = 300; V _y = 0; M _x = 0; M _y = 0; M _z = 0;	yes	35

2 Load case/Resulting anchor forces

Anchor reactions [lb]

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	500	300	300	0

max. concrete compressive strain: - [‰]
 max. concrete compressive stress: - [psi]
 resulting tension force in (x/y)=(0.000/0.000); 0 [lb]
 resulting compression force in (x/y)=(0.000/0.000); 0 [lb]

3 Tension load

	Load N _{un} [lb]	Capacity ϕN_n [lb]	Utilization $\beta_N = N_{un} / \phi N_n$	Status
Steel Strength*	500	4,869	11	OK
Pullout Strength*	N/A	N/A	N/A	N/A
Concrete Breakout Failure**	500	35	35	OK

THIS IS THE LIMITING TENSION VALUE FOR A SINGLE ANCHOR. 1,448 LBS PER ANCHOR

1,448

* highest loaded anchor ** anchor group (anchors in tension)

Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 12/05-2022 Hilti AG, P.O. Box 7000, Schaan. Hilti is a registered trademark of Hilti AG, Schaan



www.hilti.com
 Company: ECLIPSE ENGINEERING, INC. Page: 3
 Address: 376 SW Bluff Dr., Suite 8 nburnam
 Phone I Fax: 541-389-9659 E-Mail:
 Design: NWC-(1) KB-TZ2-0.375X2.0 8/6/2022
 Fastening point: Base of Shelving Unit

3.1 Steel Strength

$N_{s,a}$ = ESR value refer to ICC-ES ESR-4266
 $\phi N_{s,a} \geq N_{s,u}$ ACI 318-14 Table 17.3.1.1

Variables	$A_{s,N}$ [in. ²]	f_u [psi]
	0.05	126,204

Calculations

$N_{s,u}$ [lb]	$\phi_{nominal}$	$\phi N_{s,u}$ [lb]	$N_{s,u}$ [lb]
6,493	1.000	4,869	500

Results

$N_{s,u}$ [lb]	$\phi_{nominal}$	$\phi N_{s,u}$ [lb]	$N_{s,u}$ [lb]
6,493	1.000	4,869	500

3.2 Concrete Breakout Failure

$N_{cb} = \left(\frac{A_{bc}}{A_{bc0}} \right) V_{ed,N} V_{c,N} V_{sp,N} N_b$ ACI 318-14 Eq. (17.4.2.1a)
 $\phi N_{cb} \geq N_{s,u}$ ACI 318-14 Table 17.3.1.1
 A_{bc} see ACI 318-14, Section 17.4.2.1, Fig. R.17.4.2.1(b)
 $A_{bc0} = 9 h_{ef}^2$ ACI 318-14 Eq. (17.4.2.1c)
 $V_{ed,N} = 0.7 + 0.3 \left(\frac{C_{min}}{1.5 h_{ef}} \right) \leq 1.0$ ACI 318-14 Eq. (17.4.2.5b)
 $V_{sp,N} = \text{MAX} \left(\frac{C_{min}}{C_{sp}}, \frac{1.5 h_{ef}}{C_{sp}} \right) \leq 1.0$ ACI 318-14 Eq. (17.4.2.7b)
 $N_b = k_1 k_2 \lambda_a \sqrt{f_c} h_{ef}$ ACI 318-14 Eq. (17.4.2.2a)

Variables

h_{ef} [in.]	C_{min} [in.]	$V_{c,N}$	C_{sp} [in.]	k_1	λ_a	f_c [psi]
2.000	6.000	1.000	4.375	21	1.000	2,500

Calculations

A_{bc} [in. ²]	A_{bc0} [in. ²]	$V_{ed,N}$	$V_{sp,N}$	N_b [lb]
36.00	36.00	1.000	1.000	2,970

Results

N_{cb} [lb]	$\phi_{concrete}$	$\phi_{elastic}$	ϕN_{cb} [lb]	$N_{s,u}$ [lb]
2,970	0.650	0.750	1,448	500

Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 2205-2022 Hilti AG, P.O. Box 2589, Hilti is a registered trademark of Hilti AG, Schaan



www.hilti.com
 Company: ECLIPSE ENGINEERING, INC. Page: 4
 Address: 376 SW Bluff Dr., Suite 8 nburnam
 Phone I Fax: 541-389-9659 E-Mail:
 Design: NWC-(1) KB-TZ2-0.375X2.0 8/6/2022
 Fastening point: Base of Shelving Unit

4 Shear load

Steel Strength*	Load V_{ed} [lb]	Capacity ϕV_n [lb]	Utilization $\rho_V = V_{ed} / \phi V_n$	Status
Steel failure (with lever arm)*	300	2,201	14	OK
Pryout Strength**	N/A	N/A	N/A	N/A
Concrete edge failure in direction x**	300	2,079	15	OK
Concrete edge failure in direction y**	300	1,541	20	OK

* highest loaded anchor ** anchor group (relevant anchors)

4.1 Steel Strength

$V_{s,req}$ = ESR value refer to ICC-ES ESR-4266
 $\phi V_{s,req} \geq V_{ed}$ ACI 318-14 Table 17.3.1.1

Variables

$A_{s,V}$ [in. ²]	f_u [psi]	$C_{V,req}$
0.05	126,204	1.000

Calculations

$V_{s,req}$ [lb]
3,386

Results

$V_{s,req}$ [lb]	ϕ_{steel}	$\phi_{nominal}$	$\phi V_{s,req}$ [lb]	V_{ed} [lb]
3,386	0.650	1.000	2,201	300

THIS IS THE LIMITING SHEAR VALUE FOR A SINGLE ANCHOR. 1,541 LBS PER ANCHOR



Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC. Page: 5
 Address: 376 SW Bluff Dr., Suite 8 Specifier: nburnam
 Phone I Fax: 541-389-9659 E-Mail: 8/6/2022
 Design: NWC-(1) KB-TZ2-0.375X2.0
 Fastening point: Base of Shelving Unit

4.2 Pryout Strength

$$V_{sp} = k_{sp} \left[\left(\frac{A_{vc}}{A_{vc0}} \right) \psi_{ed,N} \psi_{c,N} \psi_{sp,N} N_b \right]$$

$$\phi V_{sp} \geq V_{ult}$$

$$A_{vc} \text{ see ACI 318-14, Section 17.4.2.1, Fig. R 17.4.2.1(b)}$$

$$A_{vc0} = 9 h_{ef}^2$$

$$\psi_{ed,N} = 0.7 + 0.3 \left(\frac{C_{sp,mini}}{1.5 h_{ef}} \right) \leq 1.0$$

$$\psi_{sp,N} = \text{MAX} \left(\frac{C_{sp,mini}}{C_{sp}}, \frac{1.5 h_{ef}}{C_{sp}} \right) \leq 1.0$$

$$N_b = k_c \lambda_a \sqrt{f_c'} h_{ef}^{1.5}$$

Variables	k_{sp}	h_{ef} [in.]	$C_{sp,mini}$ [in.]	$\psi_{c,N}$
	1	2.000	6.000	1.000
	C_{vc} [in.]	k_c	λ_a	f_c' [psi]
	4.375	21	1.000	2,500

Calculations

A_{vc} [in. ²]	A_{vc0} [in. ²]	$\psi_{ed,N}$	$\psi_{sp,N}$	N_b [lb]
36.00	36.00	1.000	1.000	2,970

Results

V_{sp} [lb]	$\phi_{concrete}$	$\phi_{stainless}$	$\phi_{ductile}$	ϕV_{sp} [lb]	V_{ult} [lb]
2,970	0.700	1.000	1.000	2,079	300

Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 1205-2022 Hilti AG, P.O. Box 2589, Hilti is a registered trademark of Hilti AG, Schaan



Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC. Page: 6
 Address: 376 SW Bluff Dr., Suite 8 Specifier: nburnam
 Phone I Fax: 541-389-9659 E-Mail: 8/6/2022
 Design: NWC-(1) KB-TZ2-0.375X2.0
 Fastening point: Base of Shelving Unit

4.3 Concrete edge failure in direction x*

$$V_{ed} = \left(\frac{A_{vc}}{A_{vc0}} \right) \psi_{ed,V} \psi_{c,V} \psi_{h,V} \psi_{per,ed,V} V_o$$

$$\phi V_{ed} \geq V_{ult}$$

$$A_{vc} \text{ see ACI 318-14, Section 17.5.2.1, Fig. R 17.5.2.1(b)}$$

$$A_{vc0} = 4.5 c_{st}^2$$

$$\psi_{ed,V} = 0.7 + 0.3 \left(\frac{C_{ed}}{1.5 c_{st}} \right) \leq 1.0$$

$$\psi_{h,V} = \sqrt{\frac{1.5 c_{st}}{h_e}} \geq 1.0$$

$$V_o = \left(7 \left(\frac{\lambda_a}{0.3} \right)^{0.2} \sqrt{f_c'} \right) \lambda_a \sqrt{f_c'} c_{st}^{1.5}$$

Variables	C_{ed} [in.]	$\psi_{c,V}$	$\psi_{h,V}$ [in.]	h_e [in.]	k_e [in.]
	6.000	1.000	4.000	2.000	2.000
	λ_a	d_e [in.]	f_c' [psi]	$\psi_{per,ed,V}$	V_o [lb]
	1.000	0.375	2,500	1.000	4,403

Calculations

A_{vc} [in. ²]	A_{vc0} [in. ²]	$\psi_{ed,V}$	$\psi_{h,V}$	V_o [lb]
60.00	162.00	0.900	1.500	4,403

Results

V_{ed} [lb]	$\phi_{concrete}$	$\phi_{stainless}$	$\phi_{ductile}$	ϕV_{ed} [lb]	V_{ult} [lb]
2,201	0.700	1.000	1.000	1,541	300

5 Combined tension and shear loads

β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
0.345	0.195	5/3	24	OK

$$\beta_{N,V} = \beta_N^2 + \beta_V^2 < 1$$

Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 1205-2022 Hilti AG, P.O. Box 2589, Hilti is a registered trademark of Hilti AG, Schaan



Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC. Page: 7
 Address: 376 SW Bluff Dr., Suite 8 nburnam
 Phone | Fax: 541-389-9659 | E-Mail:
 Design: NWC- (1) KB-TZ2-0.375X2.0 8/6/2022
 Fastening point: Base of Shelving Unit

6 Warnings

- The anchor design methods in PROFIS Engineering require rigid anchor plates per current regulations (AS 5216:2021, ETAG 001/Annex C, EOTA TR029 etc.). This means load re-distribution on the anchors due to elastic deformations of the anchor plate are not considered - the anchor plate is assumed to be sufficiently stiff; in order not to be deformed when subjected to the design loading. PROFIS Engineering calculates the minimum required anchor plate thickness with CBFEM to limit the stress of the anchor plate based on the assumptions explained above. The proof of the rigid anchor plate assumption is valid is not carried out by PROFIS Engineering. Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies where the potential concrete failure surfaces are crossed by supplementary reinforcement proportioned to tie the potential concrete failure prism into the structural member. Condition B applies where such supplementary reinforcement is not provided, or where pullout or pryout strength governs.
- Refer to the manufacturer's product literature for cleaning and installation instructions.
- For additional information about ACI 318 strength design provisions, please go to <https://submittals.us.hilti.com/PROFISAnchorDesignGuide/>
- An anchor design approach for structures assigned to Seismic Design Category C, D, E or F is given in ACI 318-14, Chapter 17, Section 17.2.3.4.3 (a) that requires the governing design strength of an anchor or group of anchors be limited by ductile steel failure. If this is NOT the case, the connection design (tension) shall satisfy the provisions of Section 17.2.3.4.3 (b), Section 17.2.3.4.3 (c), or Section 17.2.3.4.3 (d). The connection design (shear) shall satisfy the provisions of Section 17.2.3.5.3 (a), Section 17.2.3.5.3 (b), or Section 17.2.3.5.3 (c).
- Section 17.2.3.4.3 (b) / Section 17.2.3.5.3 (a) require the attachment the anchors are connecting to the structure be designed to undergo ductile yielding at a load level corresponding to anchor forces no greater than the controlling design strength. Section 17.2.3.4.3 (c) / Section 17.2.3.5.3 (b) waive the ductility requirements and require the anchors to be designed for the maximum tension / shear that can be transmitted to the anchors by a non-yielding attachment. Section 17.2.3.4.3 (d) / Section 17.2.3.5.3 (c) waive the ductility requirements and require the design strength of the anchors to equal or exceed the maximum tension / shear obtained from design load combinations that include E, with E increased by ψ_{E_0} .
- Hilti post-installed anchors shall be installed in accordance with the Hilti Manufacturer's Printed Installation Instructions (MPII), Reference ACI 318-14, Section 17.8.1.

PRCTI20230176

Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 1200-2022 Hilti AG, P-CodeStar Scheien Hilti is a registered trademark of Hilti AG, Scheien



Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC. Page: 8
 Address: 376 SW Bluff Dr., Suite 8 nburnam
 Phone | Fax: 541-389-9659 | E-Mail:
 Design: NWC- (1) KB-TZ2-0.375X2.0 8/6/2022
 Fastening point: Base of Shelving Unit

7 Installation data

Anchor type and diameter: Kwik Bolt TZ2 - CS 3/8 (2)
 hnom2
 Item number: 2210236 KB-TZ2 3/8x3
 Maximum installation torque: 361 in.lb
 Hole diameter in the base material: 0.375 in.
 Hole depth in the base material: 2.750 in.
 Minimum thickness of the base material: 4.000 in.

Profile: -
 Hole diameter in the fixture: -
 Plate thickness (input): -

Drilling method: Hammer drilled
 Cleaning: Manual cleaning of the drilled hole according to instructions for use is required.

Hilti KB-TZ2 stud anchor with 2.5 in embedment, 3/8 (2) hnom2, Carbon steel, installation per ESR-4266

7.1 Recommended accessories

Drilling	Cleaning	Setting
<ul style="list-style-type: none"> Suitable Rotary Hammer Properly sized drill bit 	<ul style="list-style-type: none"> Manual blow-out pump 	<ul style="list-style-type: none"> Torque controlled cordless impact tool Torque wrench Hammer

Coordinates Anchor in.

Anchor	x	y	c _x	c _y	c _x	c _y
1	0.000	0.000	30.000	6.000	30.000	6.000

Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 1200-2022 Hilti AG, P-CodeStar Scheien Hilti is a registered trademark of Hilti AG, Scheien



Hilti PROFIS Engineering 3.0.79

www.hilti.com			
Company:	ECLIPSE ENGINEERING, INC.	Page:	9
Address:	376 SW Bluff Dr., Suite 8	Specifier:	nburnam
Phone Fax:	541-389-9659	E-Mail:	
Design:	NWC- (1) KB-TZ2-0.375X2.0	Date:	8/6/2022
Fastening point:	Base of Shelving Unit		

8 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

PRCTI20230176



Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC. Page: 1
 Address: 376 SW Bluff Dr., Suite 8 nburnam
 Phone | Fax: 541-389-9659 E-Mail: 8/6/2022
 Design: NWC-(2) KB-TZ2-0.375X2.0
 Fastening point: Base of Shelving Units

Specifier's comments: ANCHOR PAIR CONDITION


1 Input data

Anchor type and diameter: Kwik Bolt TZ2 - CS 3/8 (2) Innom2
Item number: 2210236 KB-TZ2 3/8x3
Effective embedment depth: $h_{ef,act} = 2.000$ in., $h_{nom} = 2.500$ in.
Material: Carbon Steel
Evaluation Service Report: ESR-4266
Issued | Valid: 12/17/2021 | 12/1/2023
Proof: Design Method ACI 318-14 / Mech
Stand-off installation: $\phi_s = 0.000$ in. (no stand-off), $t = 0.118$ in.
Anchor plate^R: $l_x \times l_y \times t = 3.000$ in. x 7.000 in. x 0.118 in.; (Recommended plate thickness: not calculated)
Profile: no profile
Base material: cracked concrete, 2500, $f'_c = 2,500$ psi; $h = 4,000$ in.
Installation: hammer drilled hole, **Installation condition:** Dry
Reinforcement: tension: condition B, shear: condition B; no supplemental splitting reinforcement present
 edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)
 Tension load: yes (17.2.3.4.3 (d))
 Shear load: yes (17.2.3.5.3 (c))



^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [lb, in.-lb]



Input data and results must be checked for conformity with the existing conditions and for plausibility! PROFIS Engineering (c) 1200-2022 Hilti AG, P.O. Box 2022, Hilti AG, Schaan. Hilti is a registered trademark of Hilti AG, Schaan.



Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC. Page: 2
 Address: 376 SW Bluff Dr., Suite 8 nburnam
 Phone | Fax: 541-389-9659 E-Mail: 8/6/2022
 Design: NWC-(2) KB-TZ2-0.375X2.0
 Fastening point: Base of Shelving Units

1.1 Design results

Case	Description	Forces [lb] / Moments [in.-lb]	Seismic	Max. Util. Anchor [%]
1	Load case: Design loads	N = 1,000; V _x = 800; V _y = 0; M _x = 0; M _y = 0; M _z = 0;	yes	38


2 Load case/Resulting anchor forces

Anchor reactions [lb]

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	500	400	400	0
2	500	400	400	0

max. concrete compressive strain: - [‰]
 max. concrete compressive stress: - [psi]
 resulting tension force in (x/y): (0.000/0.000); 1,000 [lb]
 resulting compression force in (x/y): (0.000/0.000); 0 [lb]

Anchor forces are calculated based on the assumption of a rigid anchor plate.



3 Tension load

	Load N _{un} [lb]	Capacity ϕN_n [lb]	Utilization $\beta_N = N_{un} / \phi N_n$	Status
Steel Strength*	500	4,869	11	OK
Pullout Strength*	N/A	N/A	N/A	N/A
Concrete Breakout Failure**	1,000	2,654	38	OK

THIS IS THE LIMITING TENSION VALUE FOR A SINGLE ANCHOR. 1,327 LBS PER ANCHOR

2,654

* highest loaded anchor ** anchor group (anchors in tension)

Input data and results must be checked for conformity with the existing conditions and for plausibility! PROFIS Engineering (c) 1200-2022 Hilti AG, P.O. Box 2022, Hilti AG, Schaan. Hilti is a registered trademark of Hilti AG, Schaan.



www.hilti.com

Company: ECLIPSE ENGINEERING, INC.
Address: 376 SW Bluff Dr., Suite 8
Phone | Fax: 541-389-9659 |
Design: NWC-(2) KB-TZ2-0.375X2.0
Fastening point: Base of Shelving Units

Page: 3
Specifier: nburnam
E-Mail:
Date: 8/6/2022

3.1 Steel Strength

N_{sa} = ESR value refer to ICC-ES ESR-4266
φ N_{sa} ≥ N_{sa} ACI 318-14 Table 17.3.1.1

Variables

Table with 2 columns: Variable, Value. A_{sa,N} [in.²] = 0.05, f_{sa} [psi] = 126,204

Calculations

Table with 2 columns: Variable, Value. N_{sa} [lb] = 6,493

Results

Table with 4 columns: Variable, Value, Variable, Value. N_{sa} [lb] = 6,493, φ_{steel} = 0.750, φ N_{sa} [lb] = 4,869, N_{sa} [lb] = 500



www.hilti.com

Company: ECLIPSE ENGINEERING, INC.
Address: 376 SW Bluff Dr., Suite 8
Phone | Fax: 541-389-9659 |
Design: NWC-(2) KB-TZ2-0.375X2.0
Fastening point: Base of Shelving Units

Page: 4
Specifier: nburnam
E-Mail:
Date: 8/6/2022

3.2 Concrete Breakout Failure

N_{dog} = (A_{sa,N} / A_{sa,c}) V_{ec,N} V_{ed,N} V_{en,N} V_{ep,N} N_b ACI 318-14 Eq. (17.4.2.1b)
φ N_{dog} ≥ N_{sa} ACI 318-14 Table 17.3.1.1
A_{sa,c} see ACI 318-14, Section 17.4.2.1, Fig. R 17.4.2.1(b)
A_{sa,c} = 9 h_{ef}² ACI 318-14 Eq. (17.4.2.1c)
V_{ec,N} = (1 / (1 + 2 β₁)) ≤ 1.0 ACI 318-14 Eq. (17.4.2.4)
V_{ed,N} = 0.7 + 0.3 (C_{br,N} / 1.5 h_{ef}) ≤ 1.0 ACI 318-14 Eq. (17.4.2.5b)
V_{en,N} = MAX (C_{br,N} / C_{br,c}, 1.5 h_{ef} / C_{br,c}) ≤ 1.0 ACI 318-14 Eq. (17.4.2.7b)
N_b = k_c λ_a √(f_c h_{ef}^{1.5}) ACI 318-14 Eq. (17.4.2.2a)

Variables

Table with 4 columns: Variable, Value, Variable, Value. h_{ef} [in.] = 2.000, e_{2,N} [in.] = 0.000, e_{3,N} [in.] = 6.000, V_{en,N} = 1.000, C_{br,c} [in.] = 4.375, k_c = 21, λ_a = 1.000, f_c [psi] = 2,500

Calculations

Table with 6 columns: Variable, Value, Variable, Value, Variable, Value. A_{sa,c} [in.²] = 66.00, A_{sa,N} [in.²] = 36.00, V_{ec,N} = 1.000, V_{ed,N} = 1.000, V_{en,N} = 1.000, V_{ep,N} = 1.000, N_b [lb] = 5,445, φ_{concrete} = 0.650, φ_{reinforce} = 1.000, φ N_{dog} [lb] = 2,654, N_{sa} [lb] = 1,000, N_b [lb] = 2,970

Results

Table with 4 columns: Variable, Value, Variable, Value. N_{dog} [lb] = 5,445, φ_{concrete} = 0.650, φ_{reinforce} = 1.000, φ N_{dog} [lb] = 2,654, N_{sa} [lb] = 1,000, N_b [lb] = 2,970

PRCTI20230176

Input data and results must be checked for conformity with the existing conditions and for plausibility. PROFIS Engineering (c) 2020-2022 Hilti AG, P.O. Box 8000, Schaan. Hilti is a registered trademark of Hilti AG, Schaan.

Input data and results must be checked for conformity with the existing conditions and for plausibility. PROFIS Engineering (c) 2020-2022 Hilti AG, P.O. Box 8000, Schaan. Hilti is a registered trademark of Hilti AG, Schaan.



Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC.
 Address: 376 SW Bluff Dr., Suite 8
 Phone | Fax: 541-389-9659 |
 Design: NWC-(2) KB-TZ2-0.375X2.0
 Fastening point: Base of Shelving Units

Page: 5
 Specifier: nburnam
 E-Mail:
 Date: 8/6/2022

4 Shear load

Steel Strength*	Load V_{ed} [lb]	Capacity ϕV_n [lb]	Utilization $\rho_V = V_{ed} / \phi V_n$	Status
Steel failure (with lever arm)*	400	2,201	19	OK
Pryout Strength**	N/A	N/A	N/A	N/A
Concrete edge failure in direction x***	800	3,811	21	OK
** highest loaded anchor **anchor group (relevant anchors)	800	2,331	35	OK

4.1 Steel Strength

$V_{s,eq} = \text{ESR value}$ refer to ICC-ES ESR-4266
 $\phi V_{s,eq} \geq V_{ed}$ ACI 318-14 Table 17.3.1.1

Variables

$A_{s,eq}$ [in. ²]	f_{st} [psi]	$\alpha_{V,eq}$
0.05	126,204	1.000

Calculations

$V_{s,eq}$ [lb]
3,386

Results

$V_{s,eq}$ [lb]	ϕ_{steel}	$\phi_{nominal}$	$\phi V_{s,eq}$ [lb]	V_{ed} [lb]
3,386	0.650	1.000	2,201	400

THIS IS THE LIMITING SHEAR VALUE FOR A SINGLE ANCHOR. 1,165 LBS PER ANCHOR



Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC.
 Address: 376 SW Bluff Dr., Suite 8
 Phone | Fax: 541-389-9659 |
 Design: NWC-(2) KB-TZ2-0.375X2.0
 Fastening point: Base of Shelving Units

Page: 6
 Specifier: nburnam
 E-Mail:
 Date: 8/6/2022

4.2 Pryout Strength

$V_{ed} = k_{tp} \left[\left(\frac{A_{bc}}{A_{br}} \right) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{sp,N} N_b \right]$ ACI 318-14 Eq. (17.5.3.1b)
 $\phi V_{ed} \geq V_{ed}$ ACI 318-14 Table 17.3.1.1
 $A_{bc} = 9 h_{ef}^2$ see ACI 318-14, Section 17.4.2.1, Fig. R 17.4.2.1(b)
 $A_{br} = 9 h_{br}^2$ ACI 318-14 Eq. (17.4.2.1c)
 $\psi_{ec,N} = \left(\frac{1}{1 + 2 \frac{e_{c,N}}{h_{ef}}} \right) \leq 1.0$ ACI 318-14 Eq. (17.4.2.4)
 $\psi_{ed,N} = 0.7 + 0.3 \left(\frac{C_{br,ini}}{1.5 h_{br}} \right) \leq 1.0$ ACI 318-14 Eq. (17.4.2.5b)
 $\psi_{sp,N} = \text{MAX} \left(\frac{C_{br,ini}}{C_{br}}, \frac{1.5 h_{br}}{C_{br}} \right) \leq 1.0$ ACI 318-14 Eq. (17.4.2.7b)
 $N_b = k_c \lambda_a \sqrt{f_c'} h_{br}^{1.5}$ ACI 318-14 Eq. (17.4.2.2a)

Variables

k_{tp}	h_{br} [in.]	$e_{c,N}$ [in.]	$e_{ed,N}$ [in.]	$C_{br,ini}$ [in.]	$C_{br,min}$ [in.]
1	2.000	0.000	0.000	6.000	6.000
$\psi_{ed,N}$	C_{br} [in.]	k_c	λ_a	f_c' [psi]	h_{br} [in.]
1.000	4.375	21	1.000	2,500	2.500

Calculations

A_{bc} [in. ²]	A_{br} [in. ²]	$\psi_{ec,N}$	$\psi_{ed,N}$	$\psi_{sp,N}$	$V_{ed,N}$	N_b [lb]
66.00	36.00	1.000	1.000	1.000	1,000	2,970

Results

V_{ed} [lb]	$\phi_{concrete}$	$\phi_{nominal}$	ϕV_{ed} [lb]	V_{ed} [lb]
5,445	0.700	1.000	3,811	800

Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 1200-2022 Hilti AG, P-Cadpa Schaan Hilti is a registered trademark of Hilti AG, Schaan



Hilti PROFIS Engineering 3.0.79

www.hilti.com
Company: ECLIPSE ENGINEERING, INC.
Address: 376 SW Bluff Dr., Suite 8
Phone I Fax: 541-389-9659
Design: NWC-(2) KB-TZ2-0.375X2.0
Fastening point: Base of Shelving Units
Page: 8
Specifier: nburnam
E-Mail:
Date: 8/6/2022

6 Warnings

- The anchor design methods in PROFIS Engineering require rigid anchor plates per current regulations (AS 5216:2021, ETAG 001/Annex C, EOTA TR029 etc.). This means load re-distribution on the anchors due to elastic deformations of the anchor plate are not considered - the anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the design loading. PROFIS Engineering calculates the minimum required anchor plate thickness with CBFEEM to limit the stress of the anchor plate based on the assumptions explained above. The proof of the rigid anchor plate assumption is valid is not carried out by PROFIS Engineering. Input data and results must be checked for agreement with the existing conditions and for plausibility!
Condition A applies where the potential concrete failure surfaces are crossed by supplementary reinforcement proportioned to tie the potential concrete failure prism into the structural member. Condition B applies where such supplementary reinforcement is not provided, or where pullout or pryout strength governs.
Refer to the manufacturer's product literature for cleaning and installation instructions.
For additional information about ACI 318 strength design provisions, please go to https://submittals.us.hilti.com/PROFISAnchorDesignGuide/
An anchor design approach for structures assigned to Seismic Design Category C, D, E or F is given in ACI 318-14, Chapter 17, Section 17.2.3.4.3 (a) that requires the governing design strength of an anchor or group of anchors be limited by ductile steel failure. If this is NOT the case, the connection design (tension) shall satisfy the provisions of Section 17.2.3.4.3 (b), Section 17.2.3.4.3 (c), or Section 17.2.3.4.3 (d). The connection design (shear) shall satisfy the provisions of Section 17.2.3.5.3 (a), Section 17.2.3.5.3 (b), or Section 17.2.3.5.3 (c).
Section 17.2.3.4.3 (b) / Section 17.2.3.5.3 (a) require the attachment the anchors are connecting to the structure be designed to undergo ductile yielding at a load level corresponding to anchor forces no greater than the controlling design strength. Section 17.2.3.4.3 (c) / Section 17.2.3.5.3 (b) waive the ductility requirements and require the anchors to be designed for the maximum tension / shear that can be transmitted to the anchors by a non-yielding attachment. Section 17.2.3.4.3 (d) / Section 17.2.3.5.3 (c) waive the ductility requirements and require the design strength of the anchors to equal or exceed the maximum tension / shear obtained from design load combinations that include E, with E increased by phi_p.
Hilti post-installed anchors shall be installed in accordance with the Hilti Manufacturer's Printed Installation Instructions (MPII), Reference ACI 318-14, Section 17.8.1.



Hilti PROFIS Engineering 3.0.79

www.hilti.com
Company: ECLIPSE ENGINEERING, INC.
Address: 376 SW Bluff Dr., Suite 8
Phone I Fax: 541-389-9659
Design: NWC-(2) KB-TZ2-0.375X2.0
Fastening point: Base of Shelving Units
Page: 7
Specifier: nburnam
E-Mail:
Date: 8/6/2022

4.3 Concrete edge failure in direction x*

Phi_Vdog = (A_vc / A_vc0) * Psi_ecv * Psi_ecv * Psi_nv * Psi_psm * A_v
Phi_Vdog >= V_dog
A_vc see ACI 318-14, Section 17.5.2.1, Fig. R 17.5.2.1(b)
A_vc0 = 4.5 * C_p1
Psi_ecv = (1 - 26_x) / (1 + 36_x) <= 1.0
Psi_ecv = 0.7 + 0.3 * (C_c2 / (1.5 * C_p1)) <= 1.0
Psi_nv = sqrt(1.5 * C_p1) >= 1.0
V_b = (7 * (1 / C_p1)^0.2 * sqrt(C_c2)) * lambda_a * sqrt(f_c) * C_p1^1.5

Variables

Table with 5 columns: Variable, Value, Unit, Reference, Value. Rows include C_p1, e_cv, psi_ecv, lambda_a, d_n, f_c, psi_nv, psi_psm, V_b.

Calculations

Table with 5 columns: Variable, Value, Unit, Reference, Value. Rows include A_vc, psi_ecv, psi_nv, psi_psm, V_b.

Results

Table with 5 columns: Variable, Value, Unit, Reference, Value. Rows include V_dog, phi_concrete, phi_ductile, phi_Vdog, V_dog.

5 Combined tension and shear loads

Table with 5 columns: beta_N, beta_V, zeta, Utilization beta_N,V [%], Status. Values: 0.377, 0.343, 5/3, 37, OK.

beta_NV = sqrt(beta_N^2 + beta_V^2) <= 1

Fastening meets the design criteria!

Input data and results must be checked for conformity with the existing conditions and for plausibility! PROFIS Engineering (c) 1206-2022 Hilti AG, P.O. Box 2580, Schaan. Hilti is a registered trademark of Hilti AG, Schaan.

PRCTI20230176



Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC. Page: 9
 Address: 376 SW Bluff Dr., Suite 8 nburnam
 Phone | Fax: 541-389-9659 E-Mail:
 Design: NWC-(2) KB-TZ2-0.375x2.0 8/6/2022
 Fastening point: Base of Shelving Units


7 Installation data

Anchor type and diameter: Kwik Bolt TZ2 - CS 3/8 (2)
 hnom2
 Item number: 2210236 KB-TZ2 3/8x3
 Maximum installation torque: 361 in.lb
 Hole diameter in the fixture: $d_f = 0.438$ in.
 Plate thickness (input): 0.118 in.
 Recommended plate thickness: not calculated
 Drilling method: Hammer drilled
 Cleaning: Manual cleaning of the drilled hole according to instructions for use is required.

Hilti KB-TZ2 stud anchor with 2.5 in embedment, 3/8 (2) hnom2, Carbon steel, installation per ESR-4266

7.1 Recommended accessories

- | Drilling | Cleaning | Setting |
|--|--|---|
| <ul style="list-style-type: none"> Suitable Rotary Hammer Properly sized drill bit | <ul style="list-style-type: none"> Manual blow-out pump | <ul style="list-style-type: none"> Torque controlled cordless impact tool Torque wrench Hammer |



Coordinates Anchor [in.]

Anchor	x	y	c_{xx}	c_{yy}	c_{xy}
1	-0.000	-2.500	30.000	6.000	28.750
2	-0.000	2.500	30.000	6.000	33.750

Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 2206-2022 Hilti AG, P-Card® System Hilti is a registered trademark of Hilti AG, Schaan




Hilti PROFIS Engineering 3.0.79

www.hilti.com
 Company: ECLIPSE ENGINEERING, INC. Page: 10
 Address: 376 SW Bluff Dr., Suite 8 nburnam
 Phone | Fax: 541-389-9659 E-Mail:
 Design: NWC-(2) KB-TZ2-0.375x2.0 8/6/2022
 Fastening point: Base of Shelving Units

8 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc.; that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 2206-2022 Hilti AG, P-Card® System Hilti is a registered trademark of Hilti AG, Schaan





2966 WILSON DRIVE NW
 GRAND RAPIDS, MI 49534
 TEL: 800.234.7477
 FAX: 616.791.9916
 WWW.PIPMOBILE.COM

MOBILE STORAGE SYSTEMS INC.
 E-MAIL: CUSTOMERSERV@PIPMOBILE.COM


INSTALLATION INSTRUCTIONS FOR MOBILE UNITS

UNITS WILL BE 10' HIGH
 WITH 6 SHELVES 5 OPENINGS
 SHELVING UNIT PARTS:



PRCTI20230176

(4) X-BRACES PER
 CARRIAGE





2966 WILSON DRIVE NW
 GRAND RAPIDS, MI 49534
 TEL: 800.234.7477
 FAX: 616.791.9916
 WWW.PIPMOBILE.COM

MOBILE STORAGE SYSTEMS INC.
 E-MAIL: CUSTOMERSERV@PIPMOBILE.COM


INSTALLATION INSTRUCTIONS FOR STATIONARY UNITS

UNITS WILL BE 10' HIGH
 WITH 5 SHELVES 5 OPENINGS
 SHELVING UNIT PARTS:



(4) X-BRACES PER
 CARRIAGE

BOTTOM LEVEL NO SHELF
 AND NO FRONT SUPPORT



2966 WILSON DRIVE NW
 GRAND RAPIDS, MI 49534
 TEL: 800.234.7477
 FAX: 616.791.9916
 WWW.PIPMOBILE.COM



MOBILE STORAGE SYSTEMS INC.

E-MAIL: CUSTOMERSERV@PIPMOBILE.COM

INSTALLATION INSTRUCTIONS FOR STATIONARY UNITS

UNITS WILL BE 10' HIGH
 WITH 5 SHELVES 5 OPENINGS
 SHELVING UNIT PARTS:

UNITS MARKED WITH " / "



PRCTI20230176