



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 28, 2023

Inspection Result: NOT READY

Permit Number: B-21-0311

Property Address: 117 N LEVEE RD;

Contractor: GARY HARPER CONSTRUCTION 14831 223RD ST SE SNOHOMISH, WA 98296 (360) 863-1955

To construct: 85SF ADDITION TO EXISTIN CMU BLDG FOR OPERATING /MAINTAINING N. LEVEE PUMP STATION TO INCLUDE REROOF OF ENTIRE STRUCTURE; 9'-6' IN HEIGHT PERIMETER FENCE BLDG/MECH

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. complete forms prior to next inspection
2. complete rebar tie in to existing foundation and provide special inspection reports to support
3. not ready

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590