

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

| Date of Inspection: | Feb 28, 2023 | Inspection Result: | PARTIAL PASS |
|---------------------|--|------------------------|----------------------|
| Permit Number: | B-21-0311 | | |
| Property Address: | 117 N LEVEE RD; | | |
| Contractor: | GARY HARPER CONSTR 98296 (360) 863-1955 | RUCTION 14831 223RD ST | se snohomish, wa |
| To construct: | 85SF ADDITION TO EXI | STIN CMU BLDG FOR OPI | ERATING /MAINTAING |
| | N. LEVEE PUMP STATIC | N TO INCLUDE REROOF | OF ENTIRE STRUCTURE; |
| | 9'-6' IN HEIGHT PERIM | ETER FENCE | |
| | BLDG/MECH | | |

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

excludes patio footing
excludes patio footing
excludes pour pending special inspection report of bar tie ins at footing as discussed with contractor
if poured during freezing weather contractor to protect concrete

Sincerely,

Kevin Spruell Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590