



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 01, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20221223

Property Address: 1450 5TH ST SE, PUYALLUP, WA 98372;

Contractor: COLVOS CONSTRUCTION LLC - AJ SILVERS 711 COURT C TACOMA, WA 98402

To construct: A 1455 SF Tenant Improvement to the third story of a medical office building. Work includes architectural, mechanical, plumbing, and electrical. There is no structural scope of work. - WOMEN'S CLINIC

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1.R/I plumbing approved
- 2.perform run test at tie in by final

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590