



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 08, 2023

Inspection Result: STOP WORK

Permit Number: E-20-0612

Property Address: 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374;

Contractor: PEASE & SONS PO BOX 44100 TACOMA, WA 98444 Brandon Haskins
10601 Waller Rd E Tacoma, WA 98446 (253) 370-6559

To construct: CIVILS ~ FERRUCCI JHS REMODEL & ADDITION**2021 STORM SDC FEES
UPDATED**

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The silt in the French drain has not been fixed. After multiple warnings not to backfill the before fixing the contractor started backfilling the french drain.

I have issued a stop work order until the the rock is replaced. The stop work order also is on the multiple erosion issues that have not been fixed throughout the site. see pictures in the Ferrucci E&S file in documents and images.

Corrections:

- 1 finish testing and tv'ing storm lines. fix all bellies and failed storm lines. retest and camera.
Once passed finish grout all CB's and MH's and install ladders
- 2 raise all castings from paving
- 3 fix grade bust on the curb at the exit of the parent drop off and Wildwood DR.
- 4 all the wheelchair ramps are out of ada compliance. Remove ramps and install per current ADA standards.
two ramps remaining.
- 6 grind and overlay damaged areas in Wildwood Park Drive from equipment.
- 7 once final paved remove temp striping and repaint
- 8 replace all cracked and broken curb and sidewalk
- 9 remove contaminated rock from the French drain. From CB 111 to CB 105.
inspector must visually inspect rock and fabric before it can be backfilled



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424