



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Mar 08, 2023

**Inspection Result:** **FAILED**

**Permit Number:** PRCTI20221702

**Property Address:** 709 RIVER RD, PUYALLUP, WA 98371;

**Contractor:** REEVE-KNIGHT CONSTRUCTION INC 128 ASCOT DR ROSEVILLE, CA 95661

**To construct:** Tenant Improvement of 1,453 SF in vacant space to create new hair salon, G Clips.

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. remove screws from top of wall that connect to gridded ceiling
2. provide bracing detail for top of wall as discussed with contractor
3. OWNER HAS OPTED TO NOT INSTALL DRYER PER APPROVED CITY PLANS AT TIME OF INSPECTION NO ELECTRICAL OR DRYER VENT WAS INSTALLED

Sincerely,

Kevin Spruell  
Building Inspector I  
[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)  
(253) 841-5590