



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 09, 2023 **Inspection Result:** **NOT READY**

Permit Number: PRCA20220091

Property Address: 300 RIVER RD, PUYALLUP, WA 98371;

Contractor: WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW
GIG HARBOR, WA 98332 WASHINGTON PATRIOT CONST LLC 10421
BURNHAM DR SUITE NW GIG HARBOR, WA 98332

To construct: Demolition of existing showroom module; Construction of a new 10,636
SF showroom module; renovation of an existing vehicle service
module.NOTE: We have already completed SEPA and Site Plan
Review.Project #P-21-0052

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. provide electrical cover approval
- 2.provide fire cover approval
- 3.provide special inspection per city approved plans
4. not ready

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590