

City of Puyallup **Engineering Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Mar 09, 2023	Inspection Result:	FAILED
Permit Number: Property Address:		PUYALLUP, WA 98374;	
Contractor:		1410 316th st e GRAHAM, DN 11410 316th st e GRAF	· · ·
To construct:	PARKING LOT EXPA	NSION W. 675 STALLS,CFG	S~SHB-TC PARKING

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: I received a call from the city's stormwater specialist at 2pm regarding a complaint filed for track out on 39th.

I notified the contractor right away asking them to sweep the road. A sweeper arrived on site around 230pm. On site I spoke with the contractor about more ways to mitigate the track out.

- They have a sweeper on site that does not work very well and another one will be here tomorrow.

- They added more spalls to the 150 to 200' construction road.

- A street sweeper has been coming to the site twice a day.

See corrections.

Corrections must be implemented ASAP or project will be shut down until implemented. Thank you

Corrections:

- 1 Maintain CESCL inspections and SWPPP on site.
 - Zero track out. Keep asphalt clean.
 - Dust on roadway is trackout.

(Possible solutions: begin with sweeper on site ALL day, wash tires, turn spalls at end of each day, install construction road around entire site, etc..) These are suggestions to help mitigate track out. In no way is the city dictating means and methods.

- May need to add a swale along the south side after cutting to grade.
- Protect slopes.



City of Puyallup **Engineering Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Sincerely,

Jason Little Engineering Tech IV JLittle@PuyallupWA.gov (253) 435-3636