



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 15, 2023

Inspection Result: **NOT READY**

Permit Number: PRCTI20221484

Property Address: 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

Contractor: THE SCI CONSTRUCTION GROUP, INC 2616 SKILLMAN AVE, STE B
LONG ISLAND CITY , NY 11101--4433

To construct: MACYS:INTERIOR TI ON 1ST FLOOR, DEMO OF NON-STRUCTURAL
ELEMENTS, CONSTRUCTION OF NON-LOADBEARING PARTITIONS, AND
MODIFICATIONS TO AFFECTED CEILINGS. NO CHANGE TO BUILDING
ENVELOPE. BLDG/MECH ONLY 03/09/2023 - REVISION (1) ADD
PARTITION AT EXISTING MEZZANINE

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 ; complete all framing. mechanical rough-in,& electrical cover approval from L&I prior to next frame inspection. (not ready)
- 2 1 ; complete mechanical rough-in as discussed with contractor.

Sincerely,

Shannon King
Building Inspector 2



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

ShannonK@PuyallupWA.gov

(253) 840-6684