



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 16, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20221484

Property Address: 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

Contractor: THE SCI CONSTRUCTION GROUP, INC 2616 SKILLMAN AVE, STE B
LONG ISLAND CITY , NY 11101--4433

To construct: MACYS:INTERIOR TI ON 1ST FLOOR, DEMO OF NON-STRUCTURAL
ELEMENTS, CONSTRUCTION OF NON-LOADBEARING PARTITIONS, AND
MODIFICATIONS TO AFFECTED CEILINGS. NO CHANGE TO BUILDING
ENVELOPE. BLDG/MECH ONLY 03/09/2023 - REVISION (1) ADD
PARTITION AT EXISTING MEZZANINE

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: This inspection is for the area demo'ed and reconstructed by Pine Ridge Construction in Macy's of South Hill Mall.

Corrections:

- 1 ; complete all framing. mechanical rough-in,& electrical cover approval from L&I prior to next frame inspection. (not ready)
- 2 1 ; provide complete set of City approved plans with revision for added framing as discussed with contractor. not ready

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684