



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 01, 2023                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** E-20-0070

**Property Address:** 3601 9TH ST SW;

**Contractor:** THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND  
58104

**To construct:** CIVILS ~ HOMEWOOD SUITES SOUTH HILL MALL MOTEL\*\*2021 STORM  
SDC FEES UPDATED\*\*APP EXT TO 12/30/21 BLDG PERMIT B-20-0180

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** NWC is flushing the water line with fruitland water

**Corrections:**

Sincerely,

Jeff Hill  
Engineering Tech IV  
Jhill@PuyallupWA.gov  
(253) 841-5424