



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 20, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: E-20-0070

Property Address: 3601 9TH ST SW;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND
58104

To construct: CIVILS ~ HOMEWOOD SUITES SOUTH HILL MALL MOTEL**2021 STORM
SDC FEES UPDATED**APP EXT TO 12/30/21 BLDG PERMIT B-20-0180

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: NWC is working on the west retention system and CF&G

Corrections:

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424