



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Feb 16, 2023                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCCP20220092

**Property Address:** 300 RIVER RD, PUYALLUP, WA 98371;

**Contractor:** WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW  
GIG HARBOR, WA 98332

**To construct:** Construct underground utilities, storm drainage, replacements of  
concrete curb, gutter, sidewalk, re-align driveway, replace driveways.  
Remove & replace asphalt paving.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Peterson installed CB#1. 8" concrete line under the sidewalk on 4th between cb#1&2. it is in conflict with the 12" storm. Collections department will be onsite at 7:30 am 2/17 to camera the existing concrete line.

**Corrections:**

Sincerely,

Jeff Hill  
Engineering Tech IV  
Jhill@PuyallupWA.gov  
(253) 841-5424