

City of Puyallup **Engineering Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Mar 21, 2023	Inspection Result:	PARTIAL PASS
Permit Number: Property Address:	E-20-0612 3213 WILDWOOD PARK	DR, PUYALLUP, WA 983	74;
Contractor:	PEASE & SONS PO BOX 10601 Waller Rd E Tacc		
To construct:	CIVILS ~ FERRUCCI JHS I UPDATED**	REMODEL & ADDITION*	*2021 STORM SDC FEES

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: unearth has removed the contaminated rock in the french drain. The rock and pipe have been replaced and backfilled. There are still multiple areas through out the site that need to be fixed. Rills in the lower pond, trash in the lower pond, cleaning of the upper and lower parking lots, clean out all socks in CB's, BMP's around exposed soils in the upper lot, and staking down waddles.

Corrections:

- 1 install erosion control measures around the exposed soils in the ball field.
- 2 Fix all erosion control issue throughout site.
- 3 Provide the CESCL reports from the DOE NPDES permit

Sincerely,

Jeff Hill Engineering Tech IV Jhill@PuyallupWA.gov (253) 841-5424