



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 21, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20221802

Property Address: 3500 S MERIDIAN, Unit: 235, PUYALLUP, WA 98373;

Contractor: CANYON CONTRACTING CORP 2821 SKYE RD WASOUGALW, WA 98671

To construct: TI - remodel of (E) retail space including doors, partitions, ceilings, lighting fixtures, etc - Bath & Body Works (Occupant load of 68) - BATH & BODY WORKS

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. walls only no lids
2.no rated door area
3. no soffits

Corrections:

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590