



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 21, 2023                      **Inspection Result:**     **NOT READY**

**Permit Number:** PRCTI20230029

**Property Address:** 3500 S MERIDIAN, Unit: 930, PUYALLUP, WA 98373;

**Contractor:** DOUBLE J ENTERPRISES LLC (DBA JEM CONSTRUCTION 29506 8TH AVENUE S    ROY, WA 98580

**To construct:** Construction of demising walls to create a new rated exit hall with new doors in the exterior wall and start of hall for Units 900-20 (New Level 360) and Unit 930 (Goldfish Swim School).

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. provide city approved plans at time of next inspection
2. complete fire taping
3. complete wall tie ins at tilt up walls on pool side
4. drywall over lap needs to be able to move freely southwall
5. all penetrations thru wall need to be fire caulked
6. [not ready]

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590