

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 22, 2023 Inspection Result: PARTIAL PASS

Permit Number: PRCNC20221036

Property Address: 1601 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: ABSHER CONSTRUCTION CO. PO BOX 280 PUYALLUP, WA 98371-0152

To construct: New ~54,000 SF building containing labs, classrooms, faculty and

student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS & DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS

(NO CHANGE IN SQ FTG OR COST)

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1; progressing with special inspection at 3 columns at grid line - D1,C11-C16.

Corrections:

Sincerely,

Shannon King Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684