

REVISIONS TO EXISTING RESIDENTIAL OR COMMERCIAL APPLICATIONS

THIS APPLICATION MUST BE ACCOMPANIED BY 2 (TWO) SETS OF CONSTRUCTION DRAWINGS AND 3 (THREE) ACCURATE, FULLY DIMENSIONED SITE PLANS (IF APPLICABLE)

PERMIT #: PR5920230131 **PROJECT NAME:** Athena's Axe Throwing Sign

SITE ADDRESS: 4301 S Meridian, unit B, Puyallup, WA 98373

CONTACT PERSON: Brayden Seims **PHONE #:** 253-358-2008

CONTACT EMAIL: brayden@tacoma sign company.com

DESCRIPTION OF REVISIONS: Corrections for Building and Planning notes. more detail on 2nd page.

NOTE BELOW ANY REVISIONS THAT APPLY TO THE PROJECT:

Indicate if you are increasing or decreasing square footage:

Building Area (sq. ft.) +/-

1 st floor	<u> </u> new	<u> </u> remodel	2 nd floor	<u> </u> new	<u> </u> remodel
Garage	<u> </u> new	<u> </u> remodel	Deck	<u> </u> new	<u> </u> remodel
Basement	<u> </u> new	<u> </u> remodel	Other	<u> </u> new	<u> </u> remodel

Revised Project Valuation: \$

Plumbing Changes	Mechanical Changes
Example: +1 sink or -2 water closets	Example: 1+exhaust fan or -1 heat pump
<u> </u> sink/lavatories	<u> </u> furnace+/-100k
<u> </u> water closet	<u> </u> air-conditioner
<u> </u> tub/shower	<u> </u> gas piping
<u> </u> dishwasher	<u> </u> hood
<u> </u> water heater	<u> </u> diffusers
<u> </u> lawn sprinkler/backflow	<u> </u> dryer vent
<u> </u> garbage disposal	<u> </u> heat pump
<u> </u> floor drains	<u> </u> duct work
<u> </u> misc	<u> </u> fireplace
	<u> </u> exhaust fans
	<u> </u> boiler
	<u> </u> misc

If this is a change of contractor, please provide the following:

Contractor Phone

Address City State Zip

License # Expiration Date

I HEREBY CERTIFY THAT THE INFORMATION PROVIDED IS CORRECT AND THAT THE CONSTRUCTION ON THE ABOVE DESCRIBED PROPERTY, THE OCCUPANCY, AND USE WILL BE IN ACCORDANCE WITH THE LAWS, RULES, AND REGULATIONS OF THE STATE OF WASHINGTON AND THE CITY OF PUYALLUP MUNICIPAL CODE.

 253-358-2008 **DATE:** 3/23/23

SIGNATURE OWNER / AUTHORIZED AGENT **PHONE #**

OFFICE USE ONLY:

() Building: staff initials Date () Plan: staff initials Date

() Eng: staff initials Date () Fire: staff initials Date

() Traffic: staff initials Date *REVISION FEES DUE

Building Review

David Leahy (253)435-3618 DLeahy@PuyallupWA.gov

- Need to define the actual location of anchors in the details. Need to make sure they are either galvanized or stainless for the exterior use. Note on page 2 of plans.

Addressed on page 2 of plans.

- Plans need to be a minimum of 11" X 17" when resubmitting. Note on page 2 of plans.

Plans have been revised to be of size 11" x 17".

- Provide complete sets of plans a revision-form/submittal form along with a response letter showing how all comments were addressed. The markup plans are available in the Portal with comment letter.

Site Map and Drawings have been combined into one set of plans and submitted.

Planning Review

Gabriel Clark (253)770-3330 GClark@puyallupwa.gov

- Calculated sign area is 35 sq ft. Per PMC 20.60.047 permitted sign size is one sq foot per one foot of lineal wall the sign is attached. Due to the business sharing wall facade, please outline on site plan tenant space for appropriate sign size. See Multiple businesses in the same building shall apportion facade length, building wall, and street frontage such that any maximum is not exceeded for a particular property.

Tenant Frontage is 29'2". This measure has been verified by both the tenant and the landlord. The updated sign dimensions are 128" x 32.5", which constitutes a square footage of 28.9 sqft. Noted on page 1 of updated plans