


TYPICAL HANGER DETAIL




SCOPE OF WORK

MODIFY EXISTING SPRINKLER SYSTEM TO PROTECT NEW TENANT IMPROVEMENT WALL AND CEILING LAYOUT.

GENERAL NOTES

- ———— DENOTES EXISTING FIRE SPRINKLER PIPING.
- DENOTES NEW FIRE SPRINKLER PIPING. . @ DENOTES EXISTING FIRE SPRINKLER TO MOVE.
- 4. DENOTES EXISTING FIRE SPRINKLER PENDENT TO REMAIN.



VICINITY MAP

P POWDER DRIVEN STUD
R EXPANSION BOLT PIPE SPIKE TRUSS EYELET STATE CERTIFICATION SPRINKLER LEGEND ORIFICE SIZES AND TYPE WASHINGTON STATE

CERTIFICATE OF COMPETENCY

FIRE PROTECTION SPRINKLER SYSTEMS 9819-0311-C Level 3
Patriot Fire Protection, Inc.
PATRIFP099CF **⇒** 350° FITTING LEGEND PIPE-O-LET APPROVAL REQUIRED PLAIN END FIT FITTING ITY OF PUYALLUP GROOVED SHAPED NIPPLE SPRINKLER HEADS USED

HANGER LEGEND

D BM. CLAMP W/ "STRAP E EYELET

B COACH SCREW ROD

H SIDE BEAM BRACKET K SHORT CLIP

M ALL THREAD ROD N TOGGLE NUT

A "U" HOOK

F FLUSH SHELL G CEILING FLANGE

APPROVED FOR FABRICATION BY

QUALITY CONTROL BY

GENERAL NOTES ALL MATERIAL AND EQUIPMENT TO BE NEW AND UL LISTED OR FM APPROVED.

DATE

DATE

PIPING DIMENSIONS ARE CENTER TO CENTER EXCEPT RISERS AND DIMENSIONS SHOWN THUSLY (1-6) WHICH ARE END TO END.

EARTHQUAKE BRACING SHALL BE PROVIDED IN ACCORDANCE WITH NFPA PAMPHLET NO. 13, APPLICABLE EDITION

NFPA PAMPHLET NO. 13, APPLICABLE EDITION.

JOINING OF PIPE AND FITTINGS, THREADED & WELDED, SHALL BE IN ACCORDANCE WITH NFPA PAMPHLET NO. 13, APPLICABLE EDITION.

OWNER TO PROVIDE ADEQUATE HEAT IN AREAS PROTECTED BY A WET PIPE SPRINKLER SYSTEM TO PREVENT WATER IN PIPES FROM FREEZING.

. ALL WIRING OF ELECTRICAL DEVICES (IF REQUIRED) TO BE PROVIDED BY OTHERS

PAINTING OF PIPE & EQUIPMENT (IF REQUIRED) TO BE PROVIDED BY OTHERS

O. FURRING OF PIPE & EQUIPMENT (IF REQUIRED) TO BE PROVIDED BY OTHERS DESIGN CRITERIA

DESIGN PER NFPA 13 - LIGHT HAZARD OFFFICE.

PIPE NOTES ALL NEW THREADED PIPE TO BE SCH 40 - BLACK.

ALL NEW WELDED PIPE TO BE SCH 10 - BLACK.

REVISIONS

HOWARD S. WRIGHT 415 1ST AVE M STE. 400 SEATTLE, WA 98109

GSH OR 7&8 T.I.

401 15TH AVE SE PUYALLUP, WA 98372



MATT GREENE

2/24/23

12-23252

JOB NO.

PATRIFP099CF WWW.PATRIOTFIRE.COM Travis.Nichols@patriotfire.com

TEL: (253) 926-2290 FAX: (253) 922-6150

Development & Permitting Services **ISSUED PERMIT** Planning Public Works

REVIEWED FOR COMPLIANCE **DDrake** 03/27/2023 6:49:38 AM

City of Puyallup

Fire

Approval of submitted plans is not an approval of omissions or oversight by this office or noncompliance with any applicable regulations of local government. The contractor is responsible for making sure that the building complies with all applicable building codes and regulations of the local government.

Building

Engineering

Fire

Traffic

THE APPROVED CONSTRUCTION

MUST BE POSTED ON THE JOB AT

READILY ACCESSIBLE LOCATION.

ALL INSPECTIONS IN A VISIBLE AND

PLANS AND ALL ENGINEERING