



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 28, 2023                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCNC20221036

**Property Address:** 1601 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** ABSHER CONSTRUCTION CO. PO BOX 280 PUYALLUP, WA 98371-0152

**To construct:** New ~54,000 SF building containing labs, classrooms, faculty and student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS & DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS (NO CHANGE IN SQ FTG OR COST)

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; inspection of slab insulation at grid line - ( D1,C11.3-C16)

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684