

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 31, 2023 Inspection Result: FAILED

Permit Number: PRCTI20230029

Property Address: 3500 S MERIDIAN, Unit: 930, PUYALLUP, WA 98373;

Contractor: DOUBLE J ENTERPRISES LLC (DBA JEM CONSTRUCTION 29506 8TH

AVENUES ROY, WA 98580

To construct: Construction of demising walls to create a new rated exit hall with new

doors in the exterior wall and start of hall for Units 900-20 (New Level

360) and Unit 930 (Goldfish Swim School).

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. provide city approved plans at time of next inspection
 - 2. complete fire taping
 - 3.complete wall tie ins at tilt up walls on pool side
 - 4.drywall over lap needs to able to move freely southwall
 - 5. all penetrations thru wall need to be fire caulked
 - 6. [not ready]
- 2 1; nobody onsite at time of inspection. (10:15 am no access)
 - 2; provide fire final prior to building final.
 - 3; complete all rated doors as discussed with Ron on phone.
 - 4; provide city approved plans at time of inspection not ready
- 3 1; nobody onsite at time of inspection no access 8:45 (door locked)

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684