



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 31, 2023                      **Inspection Result:**      **PASSED W/  
CONDITIONS**

**Permit Number:** PRCTI20221793

**Property Address:** 3500 S MERIDIAN, Unit: 930, PUYALLUP, WA 98373;

**Contractor:** WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW  
GIG HARBOR, WA 98332

**To construct:** Construction of a swim school including the pool in the former Sears  
store located in the South Hill Mall ~ GOLDFISH SWIM SCHOOL

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1    1 ; complete all rebar at f3 footings as per city approved plans.
- 2 ; complete install of holdowns as per plans prior to footing inspection.
- 3 ; provide special inspection approval of epoxy and rebar.
- 4 ; provide geo-tech approval for soil bearing as required per plans.
- 2    1 ; complete all rebar at f3 footings as per city approved plans.
- 2 ; complete install of holdowns as per plans prior to footing inspection.
- 3 ; provide special inspection approval of epoxy and rebar.
- 4 ; provide geo-tech approval for soil bearing as required per plans
- 5 ; approved with special inspection addressing corrections.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style with a large, prominent 'S' and 'K'.

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684