



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 03, 2023

Inspection Result: **FAILED**

Permit Number: PRCTI20221702

Property Address: 709 RIVER RD, PUYALLUP, WA 98371;

Contractor: REEVE-KNIGHT CONSTRUCTION INC 128 ASCOT DR ROSEVILLE, CA 95661

To construct: Tenant Improvement of 1,453 SF in vacant space to create new hair salon, G Clips.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 2 1. provide occupancy signage at front door as discussed with contractor
2. provide open toilet seat
3. provide boot protection at angle stops in bathroom
4. provide hammer arrestors at washing machine

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590