



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Apr 04, 2023

**Inspection Result:** PARTIAL PASS

**Permit Number:** B-21-0311

**Property Address:** 117 N LEVEE RD;

**Contractor:** GARY HARPER CONSTRUCTION 14831 223RD ST SE SNOHOMISH, WA 98296 (360) 863-1955

**To construct:** 85SF ADDITION TO EXISTIN CMU BLDG FOR OPERATING /MAINTAINING N. LEVEE PUMP STATION TO INCLUDE REROOF OF ENTIRE STRUCTURE; 9'-6' IN HEIGHT PERIMETER FENCE BLDG/MECH

On this day we have inspected your construction for **Slab/Insulation Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

1. provide min clearance around rebar at insulation as per city approved plans

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590