



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 31, 2023 **Inspection Result:** **PASSED W/
CONDITIONS**

Permit Number: PRCTI20221793

Property Address: 3500 S MERIDIAN, Unit: 930, PUYALLUP, WA 98373;

Contractor: WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW
GIG HARBOR, WA 98332

To construct: Construction of a swim school including the pool in the former Sears
store located in the South Hill Mall ~ GOLDFISH SWIM SCHOOL

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; complete all rebar at f3 footings as per city approved plans.
 2 ; complete install of holdowns as per plans prior to footing inspection.
 3 ; provide special inspection approval of epoxy and rebar.
 4 ; provide geo-tech approval for soil bearing as required per plans.
- 2 1 ; complete all rebar at f3 footings as per city approved plans.
 2 ; complete install of holdowns as per plans prior to footing inspection.
 3 ; provide special inspection approval of epoxy and rebar.
 4 ; provide geo-tech approval for soil bearing as required per plans
 5 ; approved with special inspection addressing corrections.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive, flowing style.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684