



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 07, 2023

Inspection Result: **NOT READY**

Permit Number: PRCTI20221484

Property Address: 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

Contractor: THE SCI CONSTRUCTION GROUP, INC 2616 SKILLMAN AVE, STE B
LONG ISLAND CITY , NY 11101--4433

To construct: MACYS:INTERIOR TI ON 1ST FLOOR, DEMO OF NON-STRUCTURAL
ELEMENTS, CONSTRUCTION OF NON-LOADBEARING PARTITIONS, AND
MODIFICATIONS TO AFFECTED CEILINGS. NO CHANGE TO BUILDING
ENVELOPE. BLDG/MECH ONLY 03/09/2023 - REVISION (1) ADD
PARTITION AT EXISTING MEZZANINE

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. cancelled by contractor

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590