

VARIOUS REVISIONS TO ORIGINAL PERMIT PRCTI20221802



Reviewed 4/12/2023 DL
Subject to field inspectors approvals.

1400 Goodale Boulevard
Suite 105
Grandview Heights, OH 43212
614.653.7193
www.greenbergfarrow.com
Designing Solutions Together

BULLETIN & SUPPLEMENTAL INSTRUCTIONS

March 31, 2023

Project **Bath & Body Works – South Hill Mall**
Store No. 104.01.0737.01
3500 S. Meridian Street, Space No.235
Puyallup, WA 98373

Arch. Project # 20221012.0

This Bulletin shall modify as stated Construction Documents November 4th, 2022 issued previously. The items listed below shall supersede referenced portions of the Contract Documents for the above-named project and shall become part of the executed contract.

All changes or additions to the documents are noted as **REV2** dated **March 31 2023** and shall replace same documents issued previously. The following clarifications, amendments, additions, and deletions are hereby part of the Construction Documents, and alter the original documents only in the manner to the extent stated below.

THIS IS NOT A CHANGE ORDER NOR A DIRECTION TO PROCEED WITH WORK DESCRIBED HEREIN.

REVISION REQUIRED BY: REV 2 – FD1, FD2, FD3 & Site Updates
*****Items BOLD and *Italic* were not a part of any FD and are new**

DRAWINGS INCLUDED WITH THIS BULLETIN: A00.0, A00.1 A02.1a, A02.1b, A04.1a, A041.b, A101.1a, A11.1b, A11.2, A11.2a, A12.1, A131.1

A00.0 – COVER SHEET

- Updated sheet index to indicate revision changes.
- **Added REV2 information.**
- Updated Structural consultant address.

A00.1 – RESPONSIBILITY AND FINISH SCHEDULES

- **Marked 'Expansion Joint Cover' as used**

A02.1a – CONSTRUCTION PLAN

- Updated WBTDVN-WM-V01 callout to "J/A11.2a".

A02.1b – CONSTRUCTION PLAN

- Added toilet room floor slope per BD comment.

A04.1a – REFLECTED CEILING PLAN

- **Added an expansion joint to Room #2 as requested by the inspector**

A04.1b – REFLECTED CEILING PLAN

- *Added an expansion joint detail 'D'*

A10.1a – BBW FREESTANDING CABINETS DETAILS

- Added notes of anchor to details "B" & "K".
- Added dimensions to outlets in plan "A" & "J".

A11.1b – WBC FREESTANDING CABINETS DETAILS

- Added notes of anchor to details "B" & "G".
- Added dimensions to outlets in plan "A" & "F".

A11.2 – WB TRANSITION, CW & BW DETAILS

- Removed elevation "G".

A11.2a – WB TRANSITION, CW & BW DETAILS

- Added sheet.

A12.1 – PARTITION AND CEILING DETAILS

- *Revised detail 'S' per site information*
- *Added detail 'C' to show strut spacing/details for gyp board ceiling.*

A13.1 – TOILET ROOM AND NON-SALES DETAILS

- Added toilet room floor slope per BD comment.
- Updated toilet signage to "single use restroom" per BD comment.

END OF REVISION SUMMARY

Sofie Vermeulen
419.280.0402
svermeulen@greenbergfarrow.com



Bath & Body Works – South Hill Mall
Puyallup, WA
TBA/jn 2022-1152

Bulletin No. 02

Issued March 31, 2023

Page 1

This Bulletin No. **02** becomes as fully a part of the first issued documents as if originally issued therewith or originally contained therein.

This Bulletin embraces additions to, deductions from, all changes and substitutions in, or clarifications and emphasis on part of requirements of the drawings and specifications, pertaining to ALL TRADES herewith mentioned for the completion of the PROJECT.

DRAWING NO. E02.01

- Shifted cabinet receptacles in Room 1 and Room 2 per design changes. (field directive 1)

DRAWING NO. E03.01

- Added power to storefront signs.

End of Bulletin