



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Apr 12, 2023

**Inspection Result:** **NOT READY**

**Permit Number:** PRCTI20221484

**Property Address:** 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

**Contractor:** THE SCI CONSTRUCTION GROUP, INC 2616 SKILLMAN AVE, STE B  
LONG ISLAND CITY , NY 11101--4433

**To construct:** MACYS:INTERIOR TI ON 1ST FLOOR, DEMO OF NON-STRUCTURAL  
ELEMENTS, CONSTRUCTION OF NON-LOADBEARING PARTITIONS, AND  
MODIFICATIONS TO AFFECTED CEILINGS. NO CHANGE TO BUILDING  
ENVELOPE. BLDG/MECH ONLY 03/09/2023 - REVISION (1) ADD  
PARTITION AT EXISTING MEZZANINE

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; complete all ceiling grid requirements as per city approved plans,
- 2 1. approved for cover in area covered up with out inspections only
- 3 1. cancelled by contractor
- 4 1. complete perimeter wires as discussed with contractor  
2. provide tie wires at all wires that exceed 1 and 6  
3. provide positive attachment at light fixtures as discussed with contractor  
4 complete drywall at wall in shoe storage area as per city approved plans  
5.not ready

Sincerely,

Kevin Spruell



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Building Inspector I

[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)

(253) 841-5590