



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

# Permit Review Correction Letter

**Permit Application #PRCTI20221916**

**(REVISION FOR PAINT BOOTH)**

April 14, 2023

The City has completed the review of the above-mentioned permit REVISION submittal. All of your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

## Re-submittal Instructions

To resubmit, you must address all comments and complete and submit the [resubmittal form](#) and a letter of transmittal.

- 1** WHEN YOU ARE READY TO RESUBMIT FOR THE REVISION, PLEASE CONTACT JULIE JOHNSON (253.864.4165 OPTION 1) AND SHE WILL PROVIDE YOU WITH RESUBMITTAL INSTRUCTIONS AS THE RESUBMITTAL FOR REVISIONS CANNOT BE UPLOADED TO THE CUSTOMER PORTAL.
- 2** ALSO, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

## Corrections

Corrections to be addressed on the next set of resubmitted plans:

Building Review	Janelle Montgomery	(253)770-3328	JMontgomery@PuyallupWA.gov
-----------------	--------------------	---------------	----------------------------

- A3.5 - Provide distance to show minimum separation above roof.
- A3.5 - Provide duct material and manufacture specification of clearance from framing members. Consider heat temperature from ovens to assure spacing and duct material is adequate.
- A3.5 - Provide bracing plan on how duct will be braced from Powder Coat booth to roof penetrations per building code.
- A3.5 - Provide sealed Mechanical Engineer plans for mechanical work.

## Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled in order for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, if "Resolved" means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City's permit portal](#).

Condition Category	Condition	Department	Condition Status
--------------------	-----------	------------	------------------

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center  
 (253) 864-4165 option 1  
[permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov)