



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 20, 2023 **Inspection Result:** **PASSED**

Permit Number: PRCTI20221166

Property Address: 1450 5TH ST SE, PUYALLUP, WA 98372;

Contractor: COLVOS CONSTRUCTION LLC - AJ SILVERS 711 COURT C TACOMA, WA 98402

To construct: All spaces are all Type B occupancy, 4th floor medical office building (non-DOH CRS reviewable).A 860 SF tenant improvement to existing Orthopedics and Sports Medicine Clinic (Suite 4600), including exam rooms and patient and staff support areas. *REV TO RMS 4308 & 4313 FOR HINGED DOOR RATHER THAN AN OVERHEAD SLIDER - 10/12/2022*

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org