



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Apr 17, 2023

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRCTI20221876

**Property Address:** 3500 S MERIDIAN, Unit: 966, PUYALLUP, WA 98373;

**Contractor:** JSE CONSTRUCTION LLC 35059 41ST ST PL S AUBURN, WA 98001

**To construct:** Tenant Improvement for Tea Story project involving prep kitchen, sales counter and seating area constructing demising walls and installing hand sink, 3 compartment sink and kitchen equipment's per plans (no kitchen hood, no new restroom) (Occupant load- 22)

On this day we have inspected your construction for **Plumbing Below Slab Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 ; provide as-built below slab plumbing plans prior to approval.
- 2 ; test tank as per install instructions of equipment.
- 3 ; contractor will need to add 2 floor sinks to plumbing permit prior to approval of below slab inspection.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 840-6684