



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Apr 25, 2023

**Inspection Result:** NOT READY

**Permit Number:** PRCA20220482

**Property Address:** 3303 8TH AVE SE, Unit: A, PUYALLUP, WA 98372;

**Contractor:** CROWN BUILDING PO BOX 726 MILTON, WA 98354-0726

**To construct:** We are finishing the construction of our greenhouse by connecting a 2nd module to the 1st and expanding the foundation to accommodate. This is a prefabricated greenhouse addition (2nd module) to be attached to our existing greenhouse. Most of the required information is included in the construction set or permit (E-21-0440). Structure Valuation \$78,754.10 email March 3, 2023

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. provide city approved plans on site at time of next inspection as discussed with contractor
- 2 1. complete holes on each end of building as discussed with contractor  
2. secure rebar cages to maintain soil to rebar clearances during the pouring process  
3. verify the design mix of the concrete from engineer of record to determine if special inspections are needed  
4. not ready

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 841-5590