

Site Address: 2504 E MAIN
Tax Parcel Number: 0420264065

Call before you dig. It's the law.
Dial 811 or call 1-800-424-5555.

The proposed carport(s) shall not inhibit stormwater flow to the existing trench drains between the proposed carport(s) and structure as depicted on the approved civil plans. The carport(s) shall not be constructed above the trench drains and shall maintain adequate clearance for maintenance of the existing stormwater facilities.

City of Puyallup
Development
Engineering
APPROVED

See permit conditions.
ycharitou
05/01/2023
9:16:04 AM



PRCP20230511 - Carport

Site Plan - No setback provided. minimum from structure is 10 ft

CITY OF PUYALLUP
Planning Division Approved Site Plan
(253) 864-4165
MINIMUM SETBACK REQUIREMENTS
Front Yard: 20' Rear Yard: 0'
Interior Side Yard: Left: 0' Right: 0'
Street Side: N/A
Zoning District: ML
Permit #: PRCP20230511
Additional Conditions/Comments
Carport cannot be enclosed on more than two sides
Staff: NCD
Date: 05/01/2023
52' GATE
Overall



City of Puyallup
Development & Permitting Services
ISSUED PERMIT
Engineering Planning
Fire Public Works
Traffic

It is assumed that that the areas labeled "RETURNABLE STORAGE" and "COMPRESSORS" are the proposed carport(s). Regardless, no proposed footings, posts, anchors, or supports shall be constructed on or above any existing public utility connections without first relocating the utility services or protecting it in place. Existing utilities should be centered between rock anchors, if necessary, to prevent conflicts between anchors and pipe.

REV	DATE	BY	CHKD	APP'D	DESCRIPTION	MAPL	FINISH
0							
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							

RED DOT CORPORATION
10000 1st Avenue, Suite 100
Seattle, WA 98148
RD-X-XXXX