



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 02, 2023 **Inspection Result:** **FAILED**

Permit Number: PRCTI20221223

Property Address: 1450 5TH ST SE, PUYALLUP, WA 98372;

Contractor: COLVOS CONSTRUCTION LLC - AJ SILVERS 711 COURT C TACOMA, WA 98402

To construct: A 1455 SF Tenant Improvement to the third story of a medical office building. Work includes architectural, mechanical, plumbing, and electrical. There is no structural scope of work. - WOMEN'S CLINIC

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide flush controls on open side of toilet.
- 2 2 ; provide vert. grab bars 39"-41" a.f.f. of restroom floor to start of bend of 18" grab bar as discussed with contractor.
- 3 3 ; complete install of all doors and door hardware prior to final.
- 4 4 ; complete plumbing boots at sinks prior to building final.

Sincerely,

Shannon King
Building Inspector 2



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

ShannonK@PuyallupWA.gov

(253) 840-6684