



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 03, 2023                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCTI20221916

**Property Address:** 2504 E MAIN, PUYALLUP, WA 98372;

**Contractor:** POE CONSTRUCTION INC PO BOX 899 AUBURN, WA 98071-0899

**To construct:** Early installation of powder coat paint booth and conveyor system as part of manufacturing shop tenant improvement in existing warehouse space. Permit application also includes a fire sprinkler evaluation report with recommendations for storage of Group A plastics and the proposed location of plastics storage on the architectural plan. - REVISION 4/10/2023 - ADDED STRUCTURAL DESIGN OF PAINT BOOTH EXHAUST PIPE ROOF PENETRATIONS

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; approved gas pipe test at 60 psi as noted on sheet P3.0 Of City approved plans.

**Corrections:**

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)