



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 09, 2023

**Inspection Result:** NOT READY

**Permit Number:** PRRNSF20220550

**Property Address:** 2504 12TH AVE NW, PUYALLUP, WA 98371;

**Contractor:** CHESHIRE CONSTRUCTION LLC P O BOX 716 BUCKLEY, WA 98321

**To construct:** NEW SFR

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. complete poly seal
2. provide vapor barrier under stairs in garage
3. provide access under stairs in garage
4. provide insulation and vapor barrier at tub on main floor
5. provide blocks at roof in entry way where rafters bare on wall
6. provide positive connection at rafters in entry
7. provide roof venting at east roof over master bath /bedroom
8. move heat run from unconditioned space at great room
9. provide insulation baffles at vault in great room
10. DID NOT OPEN PLANS OR TRUSS SPECS
11. NOT A COMPLETE LIST
12. NOT READY

Sincerely,

Kevin Spruell  
Building Inspector I



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)

(253) 841-5590