



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 09, 2023                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** E-21-0313

**Property Address:** 1015 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** DP EXCAVATION 11410 316th st e GRAHAM, WA 98338 (253) 720-7790  
DP EXCAVATION 11410 316th st e GRAHAM, WA 98338 (253) 720-7790

**To construct:** PARKING LOT EXPANSION W. 675 STALLS,CFG~SHB-TC PARKING EXPANSION/BENAROYA

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** dP is excavating for the upper detention gallery. They have a separation due to the existing power. They came across a 12" concrete storm run that ran at a hard angle across the excavation and tied into the MH where the existing loading dock was. They have no idea where it comes from. With the steady stream of water coming from the pipe, I asked them to consider incorporating this into another structure then into the detention system. The existing water main is been removed. It was witin the c/o row and turned underneath the existing power bank. They came across the existing storm MH with 2 pipes entering it. They will remove the pipes and grout the holes. Note: I brought up the water service and fire line shut down to David D. He had concerns of the existing building on the north side not having water for service or fire. I asked dP to send an email confirming the shut down with Benaroya and the north building tenant.

Note: Water purity sample was verbally confirmed "GOOD" from Water Management Labs. in Tacoma. dP and I confirmed that they are "ONLY" performing the 10"/8" water service tie in. The 16" fire line re-route will be performed next week. dP set up the hydrants for both chillers on the north and south side of the building. They will begin the chiller connection and shut down at 5am tomorrow morning.

**Corrections:**

Sincerely,



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Engineering Tech IV

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636