City of Puyallup Building ACCEPTED JMontgomery 05/05/2023 803:22 AM



## CHC Puyallup Cannery HVAC Load Analysis

for

FULL SIZED LEDGIBLE COLOR PLANS ARE REQUIRED TO BE PROVIDED BY THE PERMITEE ON SITE FOR INSPECTION

THE APPROVED CONSTRUCTION PLANS, DOCUMENTS AND ALL ENGINEERING MUST

BE POSTED ON THE JOB AT ALL INSPECTIONS IN A VISIBLE AND READILY

ACCESSIBLE LOCATION.

Miller Hayashi Architect 118 North 35th St. Suite 200 Seattle, WA. 98103





Prepared By:

**Tres West Engineers** 

Friday, October 21, 2022

## PRCTI20221698

Chvac - Full Commercial HVAC Loads Calculation Program
Tres West Engineers
$T_{2}$ COM2 W/A 08/09-7315

Page 2

Building Summary Loads

		0	<u> </u>
Building	neaks	in July	at 5nm

Building peaks in Jul	ly at 5pm.						Fire Traffic
Bldg Load	Area	Sen	%Tot	Lat	Sen	Net	%Net
Descriptions	Quan	Loss	Loss	Gain	Gain	Gain	Gain
Roof	12,090	27,943	3.85	0	14,087	14,087	2.01
Wall	6,985	20,960	2.89	0	16,428	16,428	2.34
Glass	2,266	46,280	6.38	0	76,812	76,812	10.94
Floor Slab	426	12,368	1.71	0	0	0	0.00
Skin Loads		107,551	14.83	0	107,327	107,327	15.28
Lighting	17,410	0	0.00	0	68,317	68,317	9.73
Equipment	27,077	0	0.00	0	106,247	106,247	15.13
People	324	0	0.00	74,520	93,150	167,670	23.87
Partition	0	0	0.00	0	0	0	0.00
Cool. Pret.	0	0	0.00	0	0	0	0.00
Heat. Pret.	0	0	0.00	0	0	0	0.00
Cool. Vent.	15,807	0	0.00	46,997	129,144	176,140	25.08
Heat. Vent.	15,807	537,067	74.07	0	0	0	0.00
Cool. Infil.	1,406	0	0.00	4,101	19,988	24,089	3.43
Heat. Infil.	1,406	80,459	11.10	0	0	0	0.00
Draw-Thru Fan	0	0	0.00	0	25,827	25,827	3.68
Blow-Thru Fan	0	0	0.00	0	0	0	0.00
Reserve Cap.	0	0	0.00	0	26,676	26,676	3.80
Reheat Cap.	0	0	0.00	0	0	0	0.00
Supply Duct	0	0	0.00	0	0	0	0.00
Return Duct	0	0	0.00	0	0	0	0.00
Misc. Supply	0	0	0.00	0	0	0	0.00
Misc. Return	0	0	0.00	0	0	0	0.00
Building Totals		725,076	100.00	125,618	576,676	702,294	100.00

J.

Building	Sen	%Tot	Lat	Sen	Net	%Net
Summary	Loss	Loss	Gain	Gain	Gain	Gain
Ventilation	537,067	74.07	46,997	129,144	176,140	25.08
Infiltration	80,459	11.10	4,101	19,988	24,089	3.43
Pretreated Air	0	0.00	0	0	0	0.00
Zone Loads	107,551	14.83	74,520	401,718	476,238	67.81
Plenum Loads	0	0.00	0	0	0	0.00
Fan/Duct/Misc Loads	0	0.00	0	25,827	25,827	3.68
Building Totals	725,076	100.00	125,618	576,676	702,294	100.00

## **Check Figures**

Total Building Supply Air (based on a 20° TD): Total Building Vent. Air (71.90% of Supply):

Total Conditioned Air Space: Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:

Total Heating Required With Outside Air: Total Cooling Required With Outside Air:

21,984	CFM
15,807	CFM
24,318 0.9040 415.5 0.0024 29.82	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft
725,077 58.52	Btuh Tons

Chvac - F Tres West Tacoma, V	Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 Chy of Paylop Description of Paylop									
Air Handler #1 - FCU1-1 - Summary Loads										
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.			
No	Zone Peak Time	Volume	Htg.CFM CFM/Sqft	CIg.CFM CFM/Sqft	S.Exh W.Exh	Req.CFM Act.CFM	Req.CFM Act.CFM			
1	Waiting 100 2pm July	1,520 45 18,240	8,410 710 0.47	27,253 1,329 0.87	10,421 0 0	2AC/Hr 608 710	2AC/Hr 608 728			
28	Public Restroom 124 3pm July	112 0 1,008	336 28 0.25	821 40 0.36	-2 0 0	4AC/Hr 67 28	4AC/Hr 67 22			
29	Public Restroom 125 3pm July	112 0 1,008	336 28 0.25	825 40 0.36	-2 0 0	4AC/Hr 67 28	4AC/Hr 67 22			
38	Janitor 132 3pm July	71 0 638	213 18 0.25	516 25 0.35	-1 50 50	4AC/Hr 43 18	4AC/Hr 43 14			
	Zone Peak Totals: Total Zones: 4 Unique Zones: 4	1,815 45 20,894	9,296 785 0.43	29,414 1,434 0.79	10,416 50 50	785 785	785 785			

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram			Elite Software Deve CHC Puy City of Puyal Development & Femili ISSNUP PER	lopment, Inc. allup Cannery Ing services Page 4
Air Handler #1 - F0	CU1-1 - Total I	load S	Summary		Building F Engineering Put	tanning Nic Works Traffic
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-1 Constant Ve Draw-Thru with prog 67% motor and fan 0.74	olume - S gram esti efficiency	Sum of Peaks imated horsepower of y with 2 in. water acros Th	0.67 HP ss the fan nis system occ	curs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° WB Clg: 75° DB, 50% R	3, 69.81 H, Htg: 7	grains, Htg: 29° DB ′2° DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Ver	ntilation controls outsic	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	2,323 6,974 35,929 0 0 ss: 0	Btuh Btuh Btuh Btuh Btuh Btuh	122 785	CFM CFM	45,225	Btuh
Heating Supply Air: 9,296 / Winter Vent Outside Air (10	(.986 X 1.08 X 11) = 0.0% of supply) =		785 785	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	27,653 1,693 : 1,684 0 0 0	Btuh Btuh Btuh Btuh Btuh			31,030	Btuh
Cooling Supply Air: 31,084 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 54.8% of supply) =		1,433 785	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 9,361 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	785	CFM	9,361 40,391	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	10,350 395 2,334 dling system: atent gain:	Btuh Btuh Btuh			13,078 53,470	Btuh Btuh
Check Figures						
Total Air Handler Supply Ai Total Air Handler Vent. Air	r (based on a 20° TD (54.76% of Supply):	):	1,433 785	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	<b>):</b>		1,815 0.7898 407.3 0.0025 24.92	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: h Outside Air:		45,225 4.46	Btuh Tons		

Chvac - F Tres West Tacoma, V	Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 Chy of Payling Description of Payling Descriptio									
Air Handler #3 - FCU1-3 - Summary Loads										
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.			
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM			
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM			
3	Reception 101 Work 102 10am July	527 16 5,797	4,567 193 0.37	12,920 630 1.20	3,843 0 0	2AC/Hr 193 193	2AC/Hr 193 226			
4	Storage 103 3pm July	120 0 1,080	360 15 0.13	820 40 0.33	-2 0 0	2AC/Hr 36 15	2AC/Hr 36 14			
5	1st Hall 1 10am July	253 0 2,783	2,678 113 0.45	4,702 229 0.91	78 0 0	2AC/Hr 93 113	2AC/Hr 93 82			
	Zone Peak Totals: Total Zones: 3 Unique Zones: 3	900 16 9,660	7,606 322 0.36	18,442 899 1.00	3,920 0 0	322 322	322 322			

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	D.		Elite Software Dev CHC PL	elopment, Inc. yallup Cannery
Air Handler #3 - F0	CU1-3 - Total I	oad Sum	nmarv		Building Engineering	Planning Public Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-3 Constant V Draw-Thru with prog 67% motor and fan 0.83	olume - Sum gram estimate efficiency with	of Peaks d horsepower of 2 in. water acros	0.42 HP ss the fan nis system occ	curs 1 time(s) in the	e building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° Wf Clg: 75° DB, 50% R	3, 69.81 grain H, Htg: 72° D	s, Htg: 29° DB B			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventilati	on controls outsic	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	4,382 3,224 14,739 0 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	56 322	CFM CFM	22,345	i Btuh
Heating Supply Air: 7,606 / Winter Vent Outside Air (10	(.986 X 1.08 X 22) = 0.0% of supply) =		322 322	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	16,332 783 : 1,056 0 107 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			18,278	Btuh
Cooling Supply Air: 19,491 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 35.8% of supply) =		899 322	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 3,840 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	322	CFM	3,840 22,118	) Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	3,680 182 957 Iling system: atent gain:	Btuh Btuh Btuh			4,820 26,938	) Btuh B Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD 35.82% of Supply):	):	899 322	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	e:		900 0.9987 400.9 0.0025 24.83	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		22,345 2.24	Btuh Tons		

Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 City of Postaling City of									
Zn       Description       Area       Htg.Loss       Sen.Gain       Lat.Gain       Htg.O.A.       O         No       Zone Peak Time       People       Htg.CFM       Clg.CFM       S.Exh       Req.CFM       R         Volume       CFM/Saft       CFM/Saft       W.Exh       Act.CFM       A							Clg.O.A. Req.CFM Act.CFM		
6	Office 104 10am July	113 1 1,243	3,351 137 1.21	5,977 291 2.58	265 0 0	2AC/Hr 41 41	2AC/Hr 41 41		
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	113 1 1,243	3,351 137 1.21	5,977 291 2.58	265 0 0	41 41	41 41		

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software D CHC	evelopment, Inc. Puyallup Cannery City of Puyallup ment & Pormiting Services Page 8
Air Handler #4 - F0	CU1-4 - Total L	oad Su	immary		Bu	Ilding Planning Public Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-4 Constant V Draw-Thru with prog 67% motor and fan 0.96	olume - Su gram estima efficiency w	m of Peaks ated horsepower of vith 2 in. water acro Tl	0.14 HP ss the fan his system oc	curs 1 time(s) in	the building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	10am in July. Clg: 74° DB, 64° WI Clg: 75° DB, 50% R	3, 71.88 gra H, Htg: 72°	ains, Htg: 29° DB ' DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventil	ation controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	2,936 415 1,897 0 0 ss: 0	Btuh Btuh Btuh Btuh Btuh Btuh	7 41	CFM CFM	5,2	47 Btuh
Heating Supply Air: 3,351 / Winter Vent Outside Air (30	(.986 X 1.08 X 23) = .3% of supply) =		137 41	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	5,982 -5 342 0 0 Ny side of coil:	Btuh Btuh Btuh Btuh Btuh			6,3	19 Btuh
Cooling Supply Air: 6,319 / Summer Vent Outside Air (	(.986 X 1.1 X 20) = 14.2% of supply) =		291 41	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 -45 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	41	CFM	- 6,2	45 Btuh 74 Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	230 35 245 dling system: atent gain:	Btuh Btuh Btuh			5 6,7	10 Btuh 84 Btuh
Check Figures Total Air Handler Supply Ai Total Air Handler Vent. Air (	r (based on a 20° TD (14.22% of Supply):	):	291 41	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	e:		113 2.5784 199.9 0.0050 46.44	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: h Outside Air:		5,247 0.57	Btuh Tons		

<b>Chvac - Fu</b> Tres West Tacoma, W	Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 CHC Puyallup Cannery Chy of Payllup Development, Inc. CHC Puyallup Cannery Development Page 9									
Air Handler #5 - FCU1-5 - Summary Loads										
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM			
7	Office 105 3pm July	82 1 896	1,151 47 0.58	1,171 57 0.70	228 0 0	2AC/Hr 30 30	2AC/Hr 30 30			
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	82 1 896	1,151 47 0.58	1,171 57 0.70	228 0 0	30 30	30 30			

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<u>0</u> ,	Elite So	ftware Devel CHC Puya City of Puyalu Development & Permittin	opment, Inc. allup Cannery
Air Handler #5 - F(	CI 11-5 - Total I	oad Su	mmary		ISSUED PERMI Building Pla Engineering Public	ming Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-5 Constant V Draw-Thru with prog 67% motor and fan 0.83	olume - Sun gram estima efficiency w	n of Peaks ted horsepower of th 2 in. water acro Ti	0.03 HP ss the fan his system occurs 1 tim	ne(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	5pm in July. Clg: 86° DB, 67° WI Clg: 75° DB, 50% R	3, 69.39 gra H, Htg: 72°	ins, Htg: 29° DB DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventila	tion controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	851 299 1,368 0 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	5 30	CFM CFM	2,519	Btuh
Heating Supply Air: 1,151 / Winter Vent Outside Air (63	(.986 X 1.08 X 23) = .6% of supply) =		47 30	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	1,093 74 : 67 0 1y side of coil:	Btuh Btuh Btuh Btuh Btuh			1,234	Btuh
Cooling Supply Air: 1,238 / Summer Vent Outside Air (	(.986 X 1.1 X 20) = 52.4% of supply) =		57 30	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 356 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	30	CFM	356 1,591	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	230 15 89 dling system: atent gain:	Btuh Btuh Btuh			334 1,925	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD 52.37% of Supply):	):	57 30	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	ə:		82 0.7001 508.1 0.0020 30.90	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		2,519 0.16	Btuh Tons		

Chvac - F Tres West Tacoma, V	Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 Airel Load House House Foot House Load Load Load Load Load Load Load Load									
Air Handler #6 - FCU1-6 - Summary Loads										
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM			
8	Office 106 3pm July	115 1 1,263	1,892 77 0.67	2,026 99 0.86	228 0 0	2AC/Hr 42 42	2AC/Hr 42 42			
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	115 1 1,263	1,892 77 0.67	2,026 99 0.86	228 0 0	42 42	42 42			

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Development, Inc. CHC Puyallup Cannery City of Poyalup Providence & Persiting Barrise Page 12
Air Handler #6 - F0	CU1-6 - Total L	oad Sur	nmary		Building Ptanning Engineering Public Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-6 Constant V Draw-Thru with prog 67% motor and fan 0.90	olume - Sum gram estimat efficiency wi	of Peaks ed horsepower of th 2 in. water acro Tl	0.05 HP ss the fan his system occu	Irs 1 time(s) in the building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	3pm in July. Clg: 89° DB, 67° Wf Clg: 75° DB, 50% R	3, 65.22 grai H, Htg: 72° [	ns, Htg: 29° DB DB		
Summer: Ventilation contro	ls outside air, Wi	nter: Ventila	tion controls outsid	de air.	
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	1,470 421 1,927 0 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	7 42	CFM CFM	3,819 Btuh
Heating Supply Air: 1,892 / Winter Vent Outside Air (54	(.986 X 1.08 X 23) = .5% of supply) =		77 42	CFM CFM	
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	1,898 129 : 116 0 0 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			2,143 Btuh
Cooling Supply Air: 2,143 / Summer Vent Outside Air (4	(.986 X 1.1 X 20) = 42.6% of supply) =		99 42	CFM CFM	
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 639 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	42	CFM	639 Btuh 2,781 Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	230 -2 -11 dling system: atent gain:	Btuh Btuh Btuh			217 Btuh 2,999 Btuh
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD (42.61% of Supply):	):	99 42	CFM CFM	
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	e:		115 0.8605 459.4 0.0022 33.26	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft	
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		3,819 0.25	Btuh Tons	

<b>Chvac - F</b> Tres Wes Tacoma,	Chvac - Full Commercial HVAC Loads Calculation Program       Elite Software Development, Inc.         Tres West Engineers       CHC Puyallup Cannery         acoma, WA 98409-7315       Page 13         A in L Long ellion #TZ       FOLLUTING									
Air Ha	Air Handler #7 - FCU1-7 - Summary Loads									
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM			
10	Office 108 3pm July	95 1 1,045	1,314 54 0.57	1,501 73 0.77	228 0 0	2AC/Hr 35 35	2AC/Hr 35 35			
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	95 1 1,045	1,314 54 0.57	1,501 73 0.77	228 0 0	35 35	35 35			

Chvac - Full Commercial HVAC Tres West Engineers	C Loads Calculation Pr	ogram	<b>1</b> .		<b>Elite Softwa</b> C	re Deve HC Puy	lopment, Ind allup Canne	c. ry
Air Handler #7 - E(	CII1-7 - Total I	oad Su	mmany			ISSUED PE Building Engineering P	Planning ublic Works	4
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-7 Constant V Draw-Thru with prog 67% motor and fan 0.87	plume - Sun gram estima efficiency wi	n of Peaks ted horsepower of th 2 in. water acro T	0.03 HP oss the fan his system oc	curs 1 time(s)	in the	building	
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	3pm in July. Clg: 89° DB, 67° WB Clg: 75° DB, 50% R	3, 65.22 gra H, Htg: 72°	ins, Htg: 29° DB DB					
Summer: Ventilation control	ls outside air, Wi	nter: Ventila	tion controls outsi	de air.				
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss Total System sensible loss:	966 349 1,594 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	6 35	CFM CFM		2,909	Btuh	
Heating Supply Air: 1,314 / Winter Vent Outside Air (64	(.986 X 1.08 X 23) = .9% of supply) =		54 35	CFM CFM				
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	1,395 106 : 86 0 0 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh				1,587	Btuh	
Cooling Supply Air: 1,587 / Summer Vent Outside Air (4	(.986 X 1.1 X 20) = 47.6% of supply) =		73 35	CFM CFM				
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 529 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	35	CFM		529 2,116	Btuh Btuh	
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and latent gain on air hand	230 -2 -9 Iling system: atent gain:	Btuh Btuh Btuh				219 2,335	Btuh Btuh	
Check Figures								
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD 47.61% of Supply):	):	73 35	CFM CFM				
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		95 0.7701 488.1 0.0020 30.62	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft				
Total Heating Required With Total Cooling Required With	h Outside Air: n Outside Air:		2,909 0.19	Btuh Tons				

Chvac - F Tres West Tacoma, N	<b>Full Commercial HVAC Loads (</b> t Engineers WA 98409-7315	Calculation Prog	jram		E	lite Software De CHC P	velopment, Inc. uyallup Cannery <sup>uyallup</sup> Berkes Page 15
Air Ha	andler #8 - FCU1-2	- Summa	ry Loads			Engineering Fire	Public Works
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM
9	Storage 107	72	709	595	-1	2AC/Hr	2AC/Hr
	3pm July	0	71	29	0	26	26
		788	0.99	0.41	0	71	27
11	Staff Restroom 109	84	251	573	-1	4AC/Hr	4AC/Hr
	3pm July	0	25	28	0	50	50
		752	0.30	0.33	0	25	26
12	MED ROOM 110	84	238	934	229	3AC/Hr	3AC/Hr
	3pm July	1	24	46	0	36	36
		714	0.28	0.54	0	24	43
13	Lab 111	138	391	2,533	918	3AC/Hr	3AC/Hr
	3pm July	4	39	124	0	59	59
		1,173	0.28	0.89	0	39	117
15	Spec Restroom 113	59	176	369	-1	10AC/Hr	10AC/Hr
	3pm July	0	18	18	90	88	88
		527	0.30	0.31	90	18	17
16	1st Hall 2	313	1,709	2,615	-5	2AC/Hr	2AC/Hr
	3pm July	0	171	128	0	104	104
		3,133	0.55	0.41	0	171	121
17	1st Hall 3	310	1,190	2,199	-5	2AC/Hr	2AC/Hr
	3pm July	0	119	107	0	103	103
		3,100	0.38	0.35	0	119	101
26	Consult 122	123	451	1,264	228	2AC/Hr	2AC/Hr
	3pm July	1	45	62	0	45	45
		1,352	0.37	0.50	0	45	58
	Zone Peak Totals:	1,182	5,115	11,083	1,360		
	Total Zones: 8	6	511	540	90	511	511
	Unique Zones: 8	11,538	0.43	0.46	90	511	511

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Deve CHC Pur Output Pur Upwelgenet & Perr Usy 0 Pur	elopment, Inc. vallup Cannery
Air Handler #8 - F0	CU1-2 - Total L	oad Su	mmary		Building Engineering Fire	Ptanning ublic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-2 Constant V Draw-Thru with prog 67% motor and fan 0.90	olume - Sur gram estima efficiency w	n of Peaks ited horsepower of ith 2 in. water acro Tl	0.25 HP ss the fan his system occu	urs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	3pm in July. Clg: 89° DB, 67° Wf Clg: 75° DB, 50% R	3, 65.22 gra H, Htg: 72°	ins, Htg: 29° DB DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventila	ation controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	1,265 3,851 23,403 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	67 511	CFM CFM	28,518	Btuh
Heating Supply Air: 5,115 / Winter Vent Outside Air (10	(.986 X 1.08 X 9) = 0.0% of supply) =		511 511	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	9,908 1,175 : 635 0 0 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			11,717	Btuh
Cooling Supply Air: 11,717 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 94.6% of supply) =		540 511	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 7,761 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	511	CFM	7,761 19,478	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	1,380 -16 -130 dling system: atent gain:	Btuh Btuh Btuh			1,233 20,711	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD (94.62% of Supply):	):	540 511	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		1,182 0.4572 684.7 0.0015 24.13	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		28,518 1.73	Btuh Tons		

<b>Chvac - F</b> Tres West Tacoma, V	ull Commercial HVAC Loads Engineers VA 98409-7315	Calculation Prog	gram		E	lite Software Dev CHC Pr Development a 1990E	velopment, Inc. uyallup Cannery Purallug Bervices Page 17
Air Ha	andler #9 - FCU1-8	3 - Summa	ary Loads			Building Engineering Fire	Planning Public Works
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
18	Exam/Consult 114 3pm July	107 2 909	963 103 0.96	1,512 74 0.69	458 85 85	6AC/Hr 91 103	6AC/Hr 91 67
19	Exam/Consult 115 3pm July	106 2 903	301 32 0.30	1,392 68 0.64	458 85 85	6AC/Hr 90 32	6AC/Hr 90 61
20	Exam/Consult 116 3pm July	107 2 912	304 33 0.30	1,400 68 0.64	458 85 85	6AC/Hr 91 33	6AC/Hr 91 62
21	Provider Pod 117 5pm July	638 14 6,384	6,951 743 1.16	15,148 739 1.16	3,329 640 640	6AC/Hr 638 743	6AC/Hr 638 669
22	Exam/Consult 118 3pm July	92 2 785	262 28 0.30	1,286 63 0.68	459 85 85	6AC/Hr 79 28	6AC/Hr 79 57
23	Exam/Consult 119 3pm July	93 2 791	264 28 0.30	1,291 63 0.68	459 0 0	6AC/Hr 79 28	6AC/Hr 79 57
24	Procedure 120 5pm July	180 3 1,533	2,386 255 1.41	5,646 275 1.53	716 135 135	6AC/Hr 153 255	6AC/Hr 153 249
	Zone Peak Totals: Total Zones: 7 Unique Zones: 7	1,325 27 12,217	11,432 1,222 0.92	27,676 1,349 1.02	6,337 1,115 1,115	1,222 1,222	1,222 1,222

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Deve CHC Pu City of Puy Development & Permi USSUED PER	Allup Cannery
Air Handler #9 - F0	CU1-8 - Total L	oad Su	ummary		Building Engineering Fire	Planning Iblic Works Traffic
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-8 Constant V Draw-Thru with prog 67% motor and fan 0.82	olume - Su gram estim efficiency v	im of Peaks ated horsepower of with 2 in. water acro T	f 0.63 HP oss the fan This system oc	curs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	5pm in July. Clg: 86° DB, 67° Wf Clg: 75° DB, 50% R	3, 69.39 gr H, Htg: 72°	ains, Htg: 29° DB ° DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Venti	lation controls outsi	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	7,354 4,077 32,463 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	71 1,222	CFM CFM	43,895	Btuh
Heating Supply Air: 11,432 Winter Vent Outside Air (10	/ (.986 X 1.08 X 9) = 0.0% of supply) =		1,222 1,222	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	26,588 1,013 : 1,585 0 69 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			29,254	Btuh
Cooling Supply Air: 29,254 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 90.6% of supply) =		1,349 1,222	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 7,784 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	1,222	CFM	7,784 37,039	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	6,210 208 3,632 dling system: atent gain:	Btuh Btuh Btuh			10,050 47,089	Btuh Btuh
Check Figures						
Total Air Handler Supply Ai Total Air Handler Vent. Air	r (based on a 20° TD (90.55% of Supply):	):	1,349 1,222	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		1,325 1.0185 337.6 0.0030 33.14	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		43,895 3.92	Btuh Tons		

Chvac - Full Commercial HVAC Loads Calculation Program       Elite Software Development, II         Tres West Engineers       CHC Puyallup Cann         Tacoma, WA 98409-7315       CHC Puyallup Cann         Air Handler #10 - FCU1-12 - Summary Loads       Tres Voids								
Zn     Description     Area     Htg.Loss     Sen.Gain     Lat.Gain     Htg.O.A.     O       No     Zone Peak Time     People     Htg.CFM     Clg.CFM     S.Exh     Req.CFM     Ro       Volume     CFM/Sqft     CFM/Sqft     W.Exh     Act.CFM     A								
47	Quite Operatory 142 10am July	130 3 1,425	2,232 142 1.10	4,905 239 1.85	730 0 0	6AC/Hr 142 142	6AC/Hr 142 142	
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	130 3 1,425	2,232 142 1.10	4,905 239 1.85	730 0 0	142 142	142 142	

Chvac - Full Commercial HVAC Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Devel CHC Puya City of Puyation City of Puyation	opment, Inc. allup Cannery services Page 20
Air Handler #10 - F Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-12 - Tota FCU1-12 Constant Draw-Thru with prog 67% motor and fan 0.88	<b>al Load S</b> Volume - Su gram estima efficiency w	Summary Im of Peaks ted horsepower of ith 2 in. water acros	0.11 HP ss the fan nis system occi	urs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° WB Clg: 75° DB, 50% R	3, 69.81 gra H, Htg: 72°	ins, Htg: 29° DB DB			
Summer: Ventilation control	ls outside air, Wi	nter: Ventila	ation controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss Total System sensible loss:	1,757 475 6,520 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	8 142	CFM CFM	8,752	Btuh
Heating Supply Air: 2,232 / Winter Vent Outside Air (10	(.986 X 1.08 X 15) = 0.0% of supply) =		142 142	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	4,086 115 : 281 0 0 ly side of coil:	Btuh Btuh Btuh Btuh Btuh			4,482	Btuh
Cooling Supply Air: 5,186 / Summer Vent Outside Air (	(.986 X 1.1 X 20) = 59.6% of supply) =		239 142	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 1,699 n side of coil: andling system:	Btuh Btuh Btuh Btuh	142	CFM	1,699 6,181	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and la	690 27 424 Iling system: atent gain:	Btuh Btuh Btuh			1,140 7,321	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	<sup>r</sup> (based on a 20° TD 59.57% of Supply):	):	239 142	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	e:		130 1.8466 212.3 0.0047 67.59	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required With Total Cooling Required With	n Outside Air: n Outside Air:		8,752 0.61	Btuh Tons		

Chvac - Tres Wes Tacoma,	Chvac - Full Commercial HVAC Loads Calculation Program       Elite Software Development, Inc.         Tres West Engineers       CHC Puyallup Cannery         Tacoma, WA 98409-7315       Development Program         Air Handler #11 - FCU1-9 - Summary Loads       Elite Software Development, Inc.								
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM		
25	Office 121 5pm July	133 1 1,466	1,723 70 0.53	3,295 161 1.21	255 0 0	2AC/Hr 49 49	2AC/Hr 49 49		
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	133 1 1,466	1,723 70 0.53	3,295 161 1.21	255 0 0	49 49	49 49		

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	ŧ		Elite Software Deve CHC Puy City of Puya Development & Penk	allup Cannery
Air Handler #11 - F	- CU1-9 - Total	Load Sum	mary		Building Pui	Manning blic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-9 Constant V Draw-Thru with prog 67% motor and fan 0.93	olume - Sum of gram estimated l efficiency with 2	Peaks norsepower of in. water acros Th	0.08 HP ss the fan nis system occ	curs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	5pm in July. Clg: 86° DB, 67° Wf Clg: 75° DB, 50% R	3, 69.39 grains, H, Htg: 72° DB	Htg: 29° DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventilation	controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	1,234 489 2,237 0 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	9 49	CFM CFM	3,960	Btuh
Heating Supply Air: 1,723 / Winter Vent Outside Air (69	(.986 X 1.08 X 23) = .5% of supply) =		70 49	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	3,173 122 : 189 0 0 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			3,483	Btuh
Cooling Supply Air: 3,483 / Summer Vent Outside Air (	(.986 X 1.1 X 20) = 30.4% of supply) =		161 49	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 583 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	49	CFM	583 4,066	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	230 25 145 Iling system: atent gain:	Btuh Btuh Btuh			400 4,466	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD 30.43% of Supply):	):	161 49	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	ə:		133 1.2049 358.1 0.0028 29.71	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		3,960 0.37	Btuh Tons		

Chvac - Tres We Tacoma	Chvac - Full Commercial HVAC Loads Calculation Program       Elite Software Development, Inc.         Tres West Engineers       CHC Puyallup Cannery         Tacoma, WA 98409-7315       Strement Page 23         Air Handler #12 - FCU1-10 - Summary Loads       Page 23									
All Handler #12 - FC01-10 - Summary Loads										
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.			
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM			
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM			
30	Break Room 126	335	4,284	9,824	2,133	4AC/Hr	4AC/Hr			
	5pm July	9	246	479	0	246	246			
		3,689	0.73	1.43	0	246	246			
	Zone Peak Totals:	335	4,284	9,824	2,133					
	Total Zones: 1	9	246	479	0	246	246			
	Unique Zones: 1	3,689	0.73	1.43	0	246	246			

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>D.</b>		Elite Software Deve CHC Puy	allup Cannery
Air Handler #12 - F		al Load S	ummarv		Development & Permitt /ISSUED PERI Building P Engineering Put	anning lic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-10 Constant Draw-Thru with prog 67% motor and fan 0.83	Volume - Sum gram estimate efficiency with	of Peaks d horsepower of 2 in. water acros	0.22 HP ss the fan nis system oce	curs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	5pm in July. Clg: 86° DB, 67° WB Clg: 75° DB, 50% R	3, 69.39 grain H, Htg: 72° Di	s, Htg: 29° DB B			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventilatio	on controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	3,052 1,231 11,258 0 0 ss: 0	Btuh Btuh Btuh Btuh Btuh Btuh	22 246	CFM CFM	15,542	Btuh
Heating Supply Air: 4,284 / Winter Vent Outside Air (10	(.986 X 1.08 X 16) = 0.0% of supply) =		246 246	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	9,518 306 : 563 0 0 vly side of coil:	Btuh Btuh Btuh Btuh Btuh			10,386	Btuh
Cooling Supply Air: 10,386 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 51.4% of supply) =		479 246	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 2,933 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	246	CFM	2,933 13,320	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and l	2,070 63 731 dling system: atent gain:	Btuh Btuh Btuh			2,864 16,184	Btuh Btuh
Check Figures						
Total Air Handler Supply Ai Total Air Handler Vent. Air	r (based on a 20° TD (51.35% of Supply):	):	479 246	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	ə:		335 1.4280 248.7 0.0040 46.34	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: h Outside Air:		15,542 1.35	Btuh Tons		

Chvac - F Tres Wes Tacoma,	Chvac - Full Commercial HVAC Loads Calculation Program       Elite Software Development, Inc.         Tres West Engineers       CHC Puyallup Cannery         Tacoma, WA 98409-7315       Page 25         Air Handler #13 - FCU1-13 - Summary Loads       Events								
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM		
31	DA Station 127 5pm July	101 1 1,112	1,395 83 0.82	2,891 141 1.39	249 0 0	2AC/Hr 37 83	2AC/Hr 37 72		
32	Quite Operatory 128 5pm July	126 3 1,069	1,419 84 0.67	3,603 176 1.40	708 0 0	6AC/Hr 107 84	6AC/Hr 107 90		
33	Quite Operatory 129 5pm July	126 3 1,069	1,419 84 0.67	3,603 176 1.40	708 0 0	6AC/Hr 107 84	6AC/Hr 107 90		
	Zone Peak Totals: Total Zones: 3 Unique Zones: 3	353 7 3,251	4,233 251 0.71	10,098 492 1.40	1,665 0 0	251 251	251 251		

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Deve CHC Puy City of Puyal Development & Permit	lopment, Inc. allup Cannery
Air Handler #13 - F Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-13 - Tota FCU1-13 Constant Draw-Thru with prog 67% motor and fan 0.87	Al Load S /olume - Su gram estimat efficiency wi	m of Peaks ed horsepower of th 2 in. water acros	0.23 HP ss the fan his system occu	rs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	5pm in July. Clg: 86° DB, 67° WI Clg: 75° DB, 50% R	3, 69.39 grai H, Htg: 72° [	ns, Htg: 29° DB DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventila	tion controls outsic	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	3,148 1,085 11,486 0 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	19 251	CFM CFM	15,719	Btuh
Heating Supply Air: 4,233 / Winter Vent Outside Air (10	(.986 X 1.08 X 16) = 0.0% of supply) =		251 251	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	9,828 270 : 578 0 0 ly side of coil:	Btuh Btuh Btuh Btuh Btuh			10,676	Btuh
Cooling Supply Air: 10,676 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 51.0% of supply) =		492 251	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 2,993 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	251	CFM	2,993 13,669	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	1,610 55 746 Iling system: atent gain:	Btuh Btuh Btuh			2,411 16,080	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD 50.97% of Supply):	):	492 251	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	e:		353 1.3959 263.2 0.0038 44.57	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		15,719 1.34	Btuh Tons		

Chvac - Fu Tres West I Tacoma, W	Chvac - Full Commercial HVAC Loads Calculation Program       Elite Software Development, Inc.         Tres West Engineers       CHC Puyallup Cannery         Facoma, WA 98409-7315       Page 27										
Air Ha	ndler #14 - FCU1-	14 - Sum	mary Load	S		Building Engineering Pu	Planning ublic Works Traffic				
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM				
14	Staff Restroom 131 3pm July	59 0 527	176 30 0.50	369 24 0.41	-1 50 50	10AC/Hr 88 30	10AC/Hr 88 24				
34	Changing 151 3pm July	43 0 387	129 22 0.50	377 25 0.57	-1 45 45	4AC/Hr 26 22	4AC/Hr 26 25				
35	Staff Restroom 130 3pm July	55 0 495	165 28 0.50	435 28 0.52	-1 50 50	4AC/Hr 33 28	4AC/Hr 33 28				
36	Staff Restroom 130 3pm July	55 0 495	165 28 0.50	435 28 0.52	-1 50 50	4AC/Hr 33 28	4AC/Hr 33 28				
37	Dental Equipment 137 3pm July	94 0 799	267 45 0.48	723 47 0.50	-1 30 30	2AC/Hr 27 45	2AC/Hr 27 47				
39	Lead Provider 133 3pm July	101 1 1,112	371 62 0.62	1,091 71 0.70	228 30 30	2AC/Hr 37 62	2AC/Hr 37 71				
41	Coat Locker 135 3pm July	79 0 668	223 37 0.48	702 46 0.58	-1 45 45	4AC/Hr 45 37	4AC/Hr 45 46				
42	Patient Restroom 136 3pm July	79 0 790	264 44 0.56	575 37 0.47	-1 125 125	10AC/Hr 132 44	10AC/Hr 132 37				
48	1st Hall 6 11am July	348 0 3,824	2,154 362 1.04	3,944 257 0.74	72 127 127	2AC/Hr 127 362	2AC/Hr 127 257				
50	Storage 149 3pm July	112 0 1,008	336 56 0.50	699 46 0.41	-2 20 20	2AC/Hr 34 56	2AC/Hr 34 46				
51	Pano 150 3pm July	78 0 858	286 48 0.62	620 40 0.52	-2 50 50	6AC/Hr 86 48	6AC/Hr 86 40				
52	Provider Pod 145 3pm July	252 8 2,772	925 155 0.62	4,303 280 1.11	1,835 200 200	6AC/Hr 277 155	6AC/Hr 277 281				
53	Storage 146 3pm July	113 0 1,243	415 70 0.62	727 47 0.42	-2 30 30	2AC/Hr 41 70	2AC/Hr 41 47				

Chvac - F Tres West Tacoma, V	hvac - Full Commercial HVAC Loads Calculation Program res West Engineers acoma, WA 98409-7315										
Air Ha	andler #14 - FCU1	1-14 - Sumi	mary Load	ls (cont'd)		/15SUET Building Engineering Fire	Planning Public Works Traffic				
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.				
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM				
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM				
54	Sterile 148	465	1,319	4,440	683	6AC/Hr	6AC/Hr				
	3pm July	3	222	289	390	395	395				
		3,953	0.48	0.62	390	222	289				
55	Kitchenette 154	87	247	669	-1	2AC/Hr	2AC/Hr				
	3pm July	0	41	44	30	25	25				
		740	0.48	0.50	30	41	44				
56	1st Hall 4	382	1,404	3,039	-7	2AC/Hr	2AC/Hr				
	3pm July	0	236	198	140	140	140				
		4,206	0.62	0.52	140	236	198				
57	1st Hall 5	238	872	1,888	-5	2AC/Hr	2AC/Hr				
	3pm July	0	146	123	85	87	87				
		2,614	0.62	0.52	85	146	123				
	Zone Peak Totals:	2,639	9,719	25,037	2,792						
	Total Zones: 17	12	1,632	1,631	1,497	1,632	1,632				
	Unique Zones: 17	26,489	0.62	0.62	1,497	1,632	1,632				

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Deve CHC Puy CHY of Puyal Development A Permit 195000 PERM	lopment, Inc. allup Cannery
Air Handler #14 - F		al Load	Summary		Building P Engineering Put	lanning lic Works Traffic
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-14 Constant Draw-Thru with prog 67% motor and fan 0.92	Volume - S gram estin efficiency	Sum of Peaks nated horsepower of with 2 in. water acro T	0.77 HP ss the fan his system occu	urs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° Wf Clg: 75° DB, 50% R	3, 69.81 g H, Htg: 72	rains, Htg: 29° DB 2° DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Vent	ilation controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	878 8,841 43,218 0 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	155 1,632	CFM CFM	52,937	Btuh
Heating Supply Air: 9,719 / Winter Vent Outside Air (10	(.986 X 1.08 X 6) = 0.0% of supply) =		1,632 1,632	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	22,328 2,146 : 1,916 0 8,588 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			34,978	Btuh
Cooling Supply Air: 35,372 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 100.1% of supply) =		1,631 1,632	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 10,355 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	1,632	CFM	10,355 45,333	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	2,760 500 4,853 Jling system: atent gain:	Btuh Btuh Btuh			8,113 53,447	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	(based on a 20° TD 100.06% of Supply):	):	1,631 1,632	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		2,639 0.6182 592.5 0.0017 20.06	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: h Outside Air:		52,937 4.45	Btuh Tons		

Chvac - Tres We Tacoma	Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 Air Handler #15 - FCU11-15 - Summany Loads									
Air Handler #15 - FCU1-15 - Summary Loads										
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.			
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM			
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM			
46	Quite Operatory 141	130	1,703	3,515	730	6AC/Hr	6AC/Hr			
	10am July	3	142	171	0	142	142			
		1,425	1.10	1.32	0	142	142			
	Zone Peak Totals:	130	1,703	3,515	730					
	Total Zones: 1	3	142	171	0	142	142			
	Unique Zones: 1	1,425	1.10	1.32	0	142	142			

Chvac - Full Commercial HVAC Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Develo CHC Puya City of Puyaling Development & Permiting	opment, Inc. Ilup Cannery services Page 31
Air Handler #15 - F Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	<b>CU1-15 - Tota</b> FCU1-15 Constant Draw-Thru with prog 67% motor and fan 0.84	<b>al Load S</b> Volume - Su gram estima efficiency wi	Summary Im of Peaks ted horsepower of ith 2 in. water acro Ti	0.08 HP ss the fan his system occu	rs 1 time(s) in the t	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° WI Clg: 75° DB, 50% R	3, 69.81 gra H, Htg: 72°	ins, Htg: 29° DB DB			
Summer: Ventilation control	ls outside air, Wi	nter: Ventila	ation controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss Total System sensible loss:	1,228 475 6,520 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	8 142	CFM CFM	8,223	Btuh
Heating Supply Air: 1,703 / Winter Vent Outside Air (10	(.986 X 1.08 X 11) = 0.0% of supply) =		142 142	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	3,023 115 : 201 0 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			3,340	Btuh
Cooling Supply Air: 3,716 / Summer Vent Outside Air (8	(.986 X 1.1 X 20) = 83.1% of supply) =		171 142	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 1,699 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	142	CFM	1,699 5,039	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and latent	690 27 424 dling system: atent gain:	Btuh Btuh Btuh			1,140 6,179	Btuh Btuh
Check Figures Total Air Handler Supply Air	r (based on a 20° TD	):	171	CFM		
Total Air Handler Vent. Air ( Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area: Total Heating Required With	os. 13% of Supply): e: h Outside Δir:		142 130 1.3232 251.5 0.0040 63.50 8 223	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Cooling Required With	n Outside Air:		0,223 0.51	Tons		

Chvac - Tres We Tacoma	Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 Air Handler #16 - FCU1-16 - Summary Loads								
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.		
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM		
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM		
44	West Operatory 139	798	9,686	19,556	1,805	6AC/Hr	6AC/Hr		
	2pm September	9	798	954	0	798	798		
		7,980	1.00	1.19	0	798	798		
	Zone Peak Totals:	798	9,686	19,556	1,805				
	Total Zones: 1	9	798	954	0	798	798		
	Unique Zones: 1	7,980	1.00	1.19	0	798	798		

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Deve CHC Puy CHC Puy City of Puyali Development & Permit	lopment, Inc. allup Cannery
Air Handler #16 - F Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-16 - Tota FCU1-16 Constant Draw-Thru with prog 67% motor and fan 0.91	<b>al Load S</b> Volume - Su gram estima efficiency wi	Summary m of Peaks ted horsepower of th 2 in. water acro Ti	0.45 HP ss the fan his system occ	Curs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	3pm in July. Clg: 89° DB, 67° WI Clg: 75° DB, 50% R	3, 65.22 grai H, Htg: 72° ∣	ins, Htg: 29° DB DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventila	tion controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	7,023 2,663 36,527 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	47 798	CFM CFM	46,213	Btuh
Heating Supply Air: 9,686 / Winter Vent Outside Air (10	(.986 X 1.08 X 11) = 0.0% of supply) =		798 798	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	17,175 813 : 1,120 0 1y side of coil:	Btuh Btuh Btuh Btuh Btuh			19,108	Btuh
Cooling Supply Air: 20,677 Summer Vent Outside Air (8	/ (.986 X 1.1 X 20) = 83.7% of supply) =		954 798	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 12,113 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	798	CFM	12,113 31,220	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	2,070 -14 -203 dling system: atent gain:	Btuh Btuh Btuh			1,853 33,073	Btuh Btuh
Check Figures	r (based on a 20° TD	\.	054	CEM		
Total Air Handler Vent. Air (	(83.69% of Supply):	).	954 798	CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	e:		798 1.1949 289.5 0.0035 57.91	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		46,213 2.76	Btuh Tons		

Chvac - Full Commercial HVAC Loads Calculation Program       Elite Soft         Tres West Engineers       Tacoma, WA 98409-7315         Air Handler #17 - FCU1-17 - Summary Loads							velopment, Inc. uyallup Cannery y <sup>allup</sup> Page 34 Page 34 Pade Vors
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
45	East Operatory 140 2pm September	768 9 7,680	10,145 768 1.00	19,574 954 1.24	1,814 0 0	6AC/Hr 768 768	6AC/Hr 768 768
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	768 9 7,680	10,145 768 1.00	19,574 954 1.24	1,814 0 0	768 768	768 768

Chvac - Full Commercial HVAC Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	J.		Elite Software Deve CHC Puy City of Puyal revelopment & Fernit '1550405 PER-	lopment, Inc. allup Cannery
Air Handler #17 - F		al Load S	Summary		Building P Engineering Put	lanning lic Works Traffic
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-17 Constant Draw-Thru with prog 67% motor and fan 0.90	/olume - Su gram estima efficiency wi	Im of Peaks ted horsepower of ith 2 in. water acro T	0.45 HP ss the fan his system oc	curs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° WB Clg: 75° DB, 50% R	3, 69.81 gra H, Htg: 72°	ins, Htg: 29° DB DB			
Summer: Ventilation control	s outside air, Wi	nter: Ventila	ation controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss Total System sensible loss:	7,581 2,563 35,153 0 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	45 768	CFM CFM	45,298	Btuh
Heating Supply Air: 10,145 Winter Vent Outside Air (10	/ (.986 X 1.08 X 12) = 0.0% of supply) =	=	768 768	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	17,947 622 : 1,121 0 0 ly side of coil:	Btuh Btuh Btuh Btuh Btuh			19,690	Btuh
Cooling Supply Air: 20,695 Summer Vent Outside Air (8	(.986 X 1.1 X 20) = 30.5% of supply) =		954 768	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain: Total sensible gain on return Total sensible gain on air ha	n: 0 9,159 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	768	CFM	9,159 28,850	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and la	2,070 145 2,283 Iling system: atent gain:	Btuh Btuh Btuh			4,498 33,348	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	(based on a 20° TD 80.47% of Supply):	):	954 768	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	2:		768 1.2427 276.4 0.0036 58.98	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required With Total Cooling Required With	n Outside Air: n Outside Air:		45,298 2.78	Btuh Tons		

Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 Elite Software Development, Inc. CHC Puyallup Cannery Development, Inc. CHC P							
Air Handler #19 - FOUT-TT - Summary Loads							
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM
49	Office 143	100	2,067	4,096	258	2AC/Hr	2AC/Hr
	10am July	1	84	200	0	33	33
		1,000	0.84	2.00	0	33	33
	Zone Peak Totals:	100	2,067	4,096	258		
	Total Zones: 1	1	84	200	0	33	33
	Unique Zones: 1	1,000	0.84	2.00	0	33	33
Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software D CHC	evelopm Puyallup of Puyallup & Permitting Services JEP PERMIT	<b>ent, Inc.</b> Cannery Page 37
---	--	--	--	---	-------------------------	---	--
Air Handler #19 - F	-CU1-11 - Tota	al Load S	Summarv		Buildin	Planning Public Works	
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU1-11 Constant Draw-Thru with prog 67% motor and fan 0.94	Volume - Su gram estima efficiency wi	m of Peaks ted horsepower of th 2 in. water acro Tl	0.09 HP ss the fan nis system occ	urs 1 time(s) in t	he build	ling
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	10am in July. Clg: 74° DB, 64° WB Clg: 75° DB, 50% R	3, 71.88 gra H, Htg: 72°	ins, Htg: 29° DB DB				
Summer: Ventilation contro	ls outside air, Wi	nter: Ventila	tion controls outsid	de air.			
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	1,733 334 1,526 0 0 ss: 0	Btuh Btuh Btuh Btuh Btuh Btuh	6 33	CFM CFM	3,5	92 Btul	n
Heating Supply Air: 2,067 / Winter Vent Outside Air (39	(.986 X 1.08 X 23) = .5% of supply) =		84 33	CFM CFM			
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	4,100 -4 : 235 0 0 vly side of coil:	Btuh Btuh Btuh Btuh Btuh			4,3	30 Btuł	n
Cooling Supply Air: 4,330 / Summer Vent Outside Air (	(.986 X 1.1 X 20) = 16.7% of supply) =		200 33	CFM CFM			
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 -36 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	33	CFM	- 4,2	36 Btul 94 Btul	ו ז
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	230 28 197 dling system: atent gain:	Btuh Btuh Btuh			4. 4,7-	55 Btuł 49 Btuł	า า
Check Figures							
Total Air Handler Supply Ai Total Air Handler Vent. Air	r (based on a 20° TD (16.69% of Supply):	):	200 33	CFM CFM			
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	<b>;</b>		100 1.9967 252.7 0.0040 35.92	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft			
Total Heating Required Wit Total Cooling Required Wit	n Outside Air: n Outside Air:		3,592 0.40	Btuh Tons			

Chvac - Tres Wes Tacoma,	Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 Air Handler #20 - MDE 12.3 - Summary Loads									
	anulei #20 - IVIDF	123 - Sum	mary Luau	3		Fire	Traffic			
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.			
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM			
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM			
27	MDF 123	85	255	6,073	-1	2AC/Hr	2AC/Hr			
	3pm July	0	26	313	0	26	26			
		765	0.30	3.68	0	26	26			
	Zone Peak Totals:	85	255	6,073	-1					
	Total Zones: 1	0	26	313	0	26	26			
	Unique Zones: 1	765	0.30	3.68	0	26	26			

Chvac - Full Commercial HVAC Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Deve CHC Puy. City of Puyal Bevelopment & Fernil 185000 PEr	lopment, Inc. allup Cannery <sup>up</sup> Services Page 39
Air Handler #20 - N	/DF 123 - Tota	al Load	Summarv		Building F Engineering Put	lanning blic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	MDF 123 Constant Draw-Thru with prog 67% motor and fan 1.00	Volume - S gram estim efficiency v	Sum of Peaks ated horsepower of with 2 in. water acros Th	0.15 HP ss the fan nis system occu	urs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	3pm in July. Clg: 89° DB, 67° Wf Clg: 75° DB, 50% R	3, 65.22 gr H, Htg: 72°	ains, Htg: 29° DB ° DB			
Summer: Ventilation control	ls outside air, Wi	nter: Venti	lation controls outsic	le air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss Total System sensible loss:	0 255 1,167 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	4 26	CFM CFM	1,423	Btuh
Heating Supply Air: 255 / (.9 Winter Vent Outside Air (10	986 X 1.08 X 9) = 0.0% of supply) =		26 26	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	5,995 78 : 367 0 0 ly side of coil:	Btuh Btuh Btuh Btuh Btuh			6,441	Btuh
Cooling Supply Air: 6,441 / Summer Vent Outside Air (8	(.986 X 1.1 X 19) = 3.2% of supply) =		313 26	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 387 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	26	CFM	387 6,828	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and la	1 -1 -7 dling system: atent gain:	Btuh Btuh Btuh			-7 6,821	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 19° TD 8.16% of Supply):	):	313 26	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		85 3.6781 149.4 0.0067 16.74	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required With Total Cooling Required With	h Outside Air: n Outside Air:		1,423 0.57	Btuh Tons		
Note: Due to the system's n	egative latent gain, t	onnage is l	based solely on sen	sible gain.		

<b>Chvac - F</b> Tres West Tacoma, V	Invac - Full Commercial HVAC Loads Calculation Program       Elite Software Development, Inc.         es West Engineers       CHC Puyallup Cannery         coma, WA 98409-7315       Provide Stress										
Air Ha	andler #21 - FCU2-	1 - Sumr	nary Loads			Building Engineering Fire	Planning Public Works Traffic				
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM				
58	Waiting 200, Level 2 Landing 235 3pm July	670 20 8,040	4,232 223 0.33	12,222 596 0.89	4,586 0 0	2AC/Hr 268 223	2AC/Hr 268 270				
59	Work Room 202, Reception 201 11am July	490 7 4,900	4,250 224 0.46	8,377 408 0.83	1,702 0 0	2AC/Hr 163 224	2AC/Hr 163 185				
60	Public Rest Room 273 2pm July	47 0 400	242 13 0.27	442 22 0.46	2 50 50	4AC/Hr 27 13	4AC/Hr 27 10				
97	Jan. 236 3pm July	73 0 657	388 20 0.28	683 33 0.46	-1 50 50	2AC/Hr 22 20	2AC/Hr 22 15				
	Zone Peak Totals: Total Zones: 4 Unique Zones: 4	1,280 27 13,997	9,112 480 0.37	21,724 1,059 0.83	6,289 100 100	480 480	480 480				

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram			Elite Software Devel CHC Puy: City of Puyling Development A Paymit	opment, Inc. allup Cannery Page 41
Air Handler #21 - F	-CU2-1 - Total	Load Su	nmary		ISSUED PER Building Pr Engineering Pub	anning ic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-1 Constant V Draw-Thru with prog 67% motor and fan 0.78	olume - Sum o gram estimate efficiency with	of Peaks d horsepower of 2 in. water acros Th	0.50 HP ss the fan nis system occ	eurs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° Wf Clg: 75° DB, 50% R	3, 69.81 grains H, Htg: 72° DI	s, Htg: 29° DB 3			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventilatio	on controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	4,440 4,671 21,965 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	82 480	CFM CFM	31,076	Btuh
Heating Supply Air: 9,112 / Winter Vent Outside Air (10	(.986 X 1.08 X 18) = 0.0% of supply) =		480 480	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	20,306 1,134 : 1,244 0 183 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			22,867	Btuh
Cooling Supply Air: 22,960 Summer Vent Outside Air (4	/ (.986 X 1.1 X 20) = 45.3% of supply) =		1,059 480	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 5,723 5 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	480	CFM	5,723 28,590	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	6,210 264 1,427 Jling system: atent gain:	Btuh Btuh Btuh			7,901 36,491	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD 45.32% of Supply):	):	1,059 480	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		1,280 0.8272 420.9 0.0024 24.28	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		31,076 3.04	Btuh Tons		

Chvac - Full Commercial HVAC Loads Calculation Program       Elite Software Develop         Tres West Engineers       CHC Puyall         Tacoma, WA 98409-7315       CHC Puyall         Air Handler #22 - FCU2-5 - Summary Loads       Descent Point							
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
90	Exam/ Consult 227 2pm July	99 2 841	510 84 0.85	1,496 83 0.84	463 84 84	6AC/Hr 84 84	6AC/Hr 84 84
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	99 2 841	510 84 0.85	1,496 83 0.84	463 84 84	84 84	84 84

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	D.		Elite Softwa	CHC Puya CHC Puya	opment, Inc. allup Cannery Page 43
Air Handler #22 - F	- CU2-5 - Total	Load Su	mmarv			ISSUED PERMIT Building Plan Engineering Public	ting Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-5 Constant V Draw-Thru with prog 67% motor and fan 0.80	olume - Sum gram estimate efficiency with	of Peaks d horsepower of 2 in. water acro Tl	0.04 HP ss the fan his system occ	curs 1 time(s	Fire Tra	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	2pm in July. Clg: 88° DB, 67° WB Clg: 75° DB, 50% R	3, 66.47 grain H, Htg: 72° D	s, Htg: 29° DB B				
Summer: Ventilation control	ls outside air, Wi	nter: Ventilati	on controls outsid	de air.			
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss Total System sensible loss:	229 281 3,852 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	5 84	CFM CFM		4,361	Btuh
Heating Supply Air: 510 / (.9 Winter Vent Outside Air (10	986 X 1.08 X 6) = 0.0% of supply) =		84 84	CFM CFM			
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	1,415 81 : 98 0 210 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh				1,804	Btuh
Cooling Supply Air: 1,804 / Summer Vent Outside Air (*	(.986 X 1.1 X 20) = 101.2% of supply) =		83 84	CFM CFM			
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 1,186 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	84	CFM		1,186 2,990	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and la	460 3 69 Iling system: atent gain:	Btuh Btuh Btuh				532 3,522	Btuh Btuh
Total Air Handler Supply Air Total Air Handler Vent. Air (	(based on a 20° TD 101.17% of Supply):	):	83 84	CFM CFM			
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	3:		99 0.8402 337.3 0.0030 44.06	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft			
Total Heating Required Witl Total Cooling Required With	ו Outside Air: ו Outside Air:		4,361 0.29	Btuh Tons			

<b>Chvac - F</b> Tres West Tacoma, V	hvac - Full Commercial HVAC Loads Calculation Program res West Engineers acoma, WA 98409-7315										
Air Ha	andler #23 - FCU2	-2 - Summ	nary Loads			Building Engineering Fire	Planning Public Works Traffic				
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.				
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM				
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM				
61	Office 203	115	1,579	3,124	262	2AC/Hr	2AC/Hr				
	10am July	1	65	152	0	38	38				
		1,150	0.56	1.32	0	59	71				
62	Office 204	337	2,299	5,042	555	2AC/Hr	2AC/Hr				
	10am July	2	94	246	0	112	112				
		3,370	0.28	0.73	0	86	114				
63	Dental Flex 206	260	4,390	6,300	509	2AC/Hr	2AC/Hr				
	11am July	2	179	307	0	87	87				
		2,600	0.69	1.18	0	163	143				
68	2nd Hall 5	321	2,088	2,891	-6	2AC/Hr	2AC/Hr				
	3pm July	0	85	141	0	118	118				
		3,531	0.27	0.44	0	78	66				
69	2nd Hall 6	275	1,891	2,767	12	2AC/Hr	2AC/Hr				
	2pm July	0	77	135	0	101	101				
		3,025	0.28	0.49	0	70	63				
	Zone Peak Totals:	1,308	12,247	20,124	1,332						
	Total Zones: 5	5	500	981	0	456	456				
	Unique Zones: 5	13,676	0.38	0.75	0	456	456				

Chvac - Full Commercial HVAC Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Deve CHC Puy Development A Permit	lopment, Inc. allup Cannery <sup>P</sup> g services Page 45
Air Handler #23 - F	FCU2-2 - Total	Load S	ummary		ISSUED PERI Building P Engineering Put	anning ic Works raffic
Supply Air Fan: Fan Input: Sensible Heat Ratio:	Draw-Thru with prog 67% motor and fan 0.94	gram estima efficiency w	ited horsepower of ith 2 in. water acro T	0.46 HP ss the fan his system occ	curs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° WI Clg: 75° DB, 50% R	3, 69.81 gra H, Htg: 72°	ins, Htg: 29° DB DB			
Summer: Ventilation control	s outside air, Wi	nter: Ventila	ation controls outsid	de air.		
Zone Space sensible loss:	7,682	Btuh	80	OFM		
Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss Total System sensible loss:	4,564 20,866 0 0 s: 0	Btuh Btuh Btuh Btuh	456	CFM	33,113	Btuh
Heating Supply Air: 12,247 Winter Vent Outside Air (91	/ (.986 X 1.08 X 23) = .1% of supply) =	=	500 456	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	18,101 1,108 : 1,152 0 784	Btuh Btuh Btuh Btuh Btuh			21 145	Btub
Cooling Supply Air: 21,269 Summer Vent Outside Air (4	/ (.986 X 1.1 X 20) = 46.5% of supply) =		981 456	CFM CFM	21,140	Blan
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain:	0 n: 0 5,437	Btuh Btuh Btuh	456	CFM		
Blow-thru fan sensible gain: Total sensible gain on retur Total sensible gain on air ha	n side of coil: andling system:	Btuh			5,437 26,582	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain:	1,150 258 1,355	Btuh Btuh Btuh				
Total latent gain on air hand Total system sensible and la	lling system: atent gain:				2,764 29,346	Btuh Btuh
Check Figures	<i>"</i>	<u></u>		0514		
Total Air Handler Supply Air Total Air Handler Vent. Air (	(based on a 20° TD 46.48% of Supply):	):	981 456	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		1,308 0.7499 534.9 0.0019 25.32	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required With Total Cooling Required With	n Outside Air: n Outside Air:		33,113 2.45	Btuh Tons		

Chvac - F Tres West Tacoma, V	<b>full Commercial HVAC Loads</b> t Engineers NA 98409-7315	Scalculation Prog	gram		E	Elite Software De CHC P City of P Development A (SSUED	velopment, Inc. uyallup Cannery <sup>uyallup</sup> Service Page 46
Air Ha	andler #24 - FCU2	?-3 - Summ	nary Loads			Building Engineering Fire	Planning Public Works Traffic
Zn No	Description Zone Peak Time	Area People	Htg.Loss Htg.CFM	Sen.Gain Clg.CFM	Lat.Gain S.Exh	Htg.O.A. Req.CFM	Clg.O.A. Req.CFM
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM
70	Provider Pod 207 3pm July	635 12 6,985	3,415 541 0.85	9,202 600 0.94	2,748 693 693	6AC/Hr 699 541	6AC/Hr 699 600
71	Exam/Consult 208 3pm July	91 2 876	504 80 0.87	1,435 94 1.02	458 86 86	6AC/Hr 88 80	6AC/Hr 88 94
72	Exam/Consult 209 3pm July	92 2 883	507 80 0.87	1,441 94 1.02	458 86 86	6AC/Hr 88 80	6AC/Hr 88 94
73	Exam/Consult 210 3pm June	91 2 874	1,799 285 3.13	2,424 158 1.74	432 90 90	6AC/Hr 87 285	6AC/Hr 87 158
74	Exam/Consult 211 3pm July	95 2 908	522 83 0.87	1,466 96 1.01	458 90 90	6AC/Hr 91 83	6AC/Hr 91 96
75	Exam/Consult 212 3pm July	92 2 883	507 80 0.87	1,441 94 1.02	458 86 86	6AC/Hr 88 80	6AC/Hr 88 94
76	Exam/Consult 213 3pm July	94 2 900	517 82 0.87	1,458 95 1.01	458 90 90	6AC/Hr 90 82	6AC/Hr 90 95
	Zone Peak Totals: Total Zones: 7 Unique Zones: 7	1,190 24 12,310	7,772 1,231 1.03	18,867 1,230 1.03	5,471 1,221 1,221	1,231 1,231	1,231 1,231

Chvac - Full Commercial HVAC Tres West Engineers	C Loads Calculation Pr	ogram	*		Elite Software Deve CHC Puy	allup Cannery
Air Handler #24 - F	CI 12-3 - Total	Load Sum	marv		Development & Permitin ISSUED PERM Building Pub Engineering Pub	g services Faye 47
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-3 Constant V Draw-Thru with prog 67% motor and fan 0.82	olume - Sum of l gram estimated h efficiency with 2	Peaks horsepower of in. water acros Tl	0.58 HP ss the fan nis system occ	curs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° WI Clg: 75° DB, 50% R	3, 69.81 grains, l H, Htg: 72° DB	Htg: 29° DB			
Summer: Ventilation control	s outside air, Wi	nter: Ventilation	controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss Total System sensible loss:	3,663 4,109 30,661 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	72 1,231	CFM CFM	38,433	Btuh
Heating Supply Air: 7,772 / Winter Vent Outside Air (10	(.986 X 1.08 X 6) = 0.0% of supply) =		1,231 1,231	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	17,473 997 : 1,445 0 6,377 ly side of coil:	Btuh Btuh Btuh Btuh Btuh			26,293	Btuh
Cooling Supply Air: 26,679 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 100.1% of supply) =		1,230 1,231	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain: Total sensible gain on return Total sensible gain on air ha	n: 0 7,341 n side of coil: andling system:	Btuh Btuh Btuh Btuh	1,231	CFM	7,341 33,633	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and la	5,520 233 3,660 Iling system: atent gain:	Btuh Btuh Btuh			9,413 43,046	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD 100.06% of Supply):	):	1,230 1,231	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	<del>)</del> :		1,190 1.0341 331.7 0.0030 32.30	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required With Total Cooling Required With	n Outside Air: n Outside Air:		38,433 3.59	Btuh Tons		

Chvac - F Tres West Tacoma, W	hvac - Full Commercial HVAC Loads Calculation Program res West Engineers acoma, WA 98409-7315 Air Handler #25 - FCU2-4 - Summary Loads									
				a a :	I C I	Fire Fire				
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.			
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM			
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM			
67	2nd Hall 4	270	1.783	2.614	-5	2AC/Hr	2AC/Hr			
•	3pm July	0	147	127	77	99	99			
	-1	2,970	0.54	0.47	77	147	128			
77	Restroom 214	65	335	577	2	4AC/Hr	4AC/Hr			
	2pm July	0	28	28	50	37	37			
		553	0.42	0.43	50	28	28			
78	Restroom 215	65	335	597	2	4AC/Hr	4AC/Hr			
	2pm July	0	28	29	50	37	37			
		553	0.42	0.45	50	28	29			
80	Storage 217	103	530	958	3	2AC/Hr	2AC/Hr			
	2pm July	0	44	47	30	29	29			
		876	0.42	0.45	30	44	47			
81	Consult 218	146	752	1,933	465	6AC/Hr	6AC/Hr			
	2pm July	2	62	94	125	124	124			
		1,241	0.42	0.65	125	62	94			
82	Consult 219	150	1,857	2,735	458	6AC/Hr	6AC/Hr			
	3pm July	2	153	133	128	128	128			
		1,275	1.02	0.89	128	153	134			
	Zone Peak Totals:	799	5,590	9,415	925					
	Total Zones: 6	4	460	459	460	453	453			
	Unique Zones: 6	7,467	0.58	0.57	460	460	460			

Chvac - Full Commercial HVAC Tres West Engineers Tacoma, WA 98409-7315	Loads Calculation Pr	ogram			Elite Software Deve CHC Puy City of Puya Development & Permit	lopment, Inc. allup Cannery fing Services Page 49
Air Handler #25 - F	CU2-4 - Total	Load Summa	ary aks		Building Building Fire	Mit Planning blic Works Traffic
Supply Air Fan: Fan Input: Sensible Heat Ratio:	Draw-Thru with prog 67% motor and fan 0.90	gram estimated hors efficiency with 2 in.	sepower of water acros Th	0.22 HP ss the fan nis system occ	urs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° WE Clg: 75° DB, 50% R	3, 69.81 grains, Htg H, Htg: 72° DB	: 29° DB			
Summer: Exhaust controls of	utside air, Winte	er: Exhaust controls	outside air			
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss:	3,098 2,492 11,239 0 0	Btuh Btuh Btuh Btuh Btuh	44 460	CFM CFM		
Return Plenum sensible loss Total System sensible loss:	: 0	Btuh			16,829	Btuh
Heating Supply Air: 5,590 / (. Winter Vent Outside Air (100	986 X 1.08 X 11) = .0% of supply) =		460 460	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain:	8,597 605 539 0 0	Btuh Btuh Btuh Btuh Btuh			0.740	Ptub
Cooling Supply Air: 9,954 / (. Summer Vent Outside Air (10	986 X 1.1 X 20) = 00.2% of supply) =		459 460	CFM CFM	3,742	Dian
Return duct sensible gain: Return plenum sensible gain Outside air sensible gain: Blow-thru fan sensible gain: Total sensible gain on return Total sensible gain on air har	: 0 1,496 0 side of coil: ndling system:	Btuh Btuh Btuh Btuh	460	CFM	1,496 11,238	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air handl Total system sensible and la	920 141 1,368 ing system: tent gain:	Btuh Btuh Btuh			2,429 13,667	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (1	(based on a 20° TD 00.21% of Supply):	):	459 460	CFM CFM		
Total Conditioned Air Space: Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:			799 0.5745 701.6 0.0014 21.06	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required With Total Cooling Required With	Outside Air: Outside Air:		16,829 1.14	Btuh Tons		

<b>Chvac - F</b> Tres Wes Tacoma, V	Full Commercial HVAC Loads ( t Engineers WA 98409-7315	Calculation Pro	gram		E	lite Software De CHC P	velopment, Inc. uyallup Cannery <sup>wallup</sup> Page 50
Air Ha	andler #26 - FCU2-	9 - Sumr	nary Loads			Building Engineering	Planning Public Works
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM
66	2nd Hall 3	407	2,163	3,759	-6	2AC/Hr	2AC/Hr
	3pm July	0	176	183	125	122	122
		3,663	0.43	0.45	125	176	165
93	Restroom 230	63	324	560	2	4AC/Hr	4AC/Hr
	2pm July	0	26	27	50	36	36
		536	0.42	0.43	50	26	25
94	Dirty 231, Clean 232	160	824	1,181	5	10AC/Hr	10AC/Hr
	2pm July	0	67	58	230	227	227
		1,360	0.42	0.36	230	67	52
95	Kitchenette 233	137	1,928	4,433	20	2AC/Hr	2AC/Hr
	5pm July	0	157	216	40	39	39
		1,165	1.15	1.58	40	157	194
96	Charging / Supply	135	718	1,142	-2	2AC/Hr	2AC/Hr
	3pm July	0	58	56	40	41	41
		1,215	0.43	0.41	40	58	50
	Zone Peak Totals:	902	5,957	11,075	19		
	Total Zones: 5	0	485	540	485	464	464
	Unique Zones: 5	7,938	0.54	0.60	485	485	485

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram			Elite Software Deve CHC Puy City of Puyal Development & Permit	lopment, Inc. allup Cannery <sup>m</sup> g Service: Page 51
Air Handler #26 - F	-CU2-9 - Total	Load Summ	narv		/ ISSUED PERI Building P Engineering Put	III: Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-9 Constant V Draw-Thru with prog 67% motor and fan 0.99	olume - Sum of Pe gram estimated ho efficiency with 2 in	eaks rsepower of . water acros Th	0.25 HP ss the fan nis system occu	urs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	5pm in July. Clg: 86° DB, 67° WI Clg: 75° DB, 50% R	3, 69.39 grains, Ht H, Htg: 72° DB	g: 29° DB			
Summer: Exhaust controls	outside air, Winte	er: Exhaust contro	ls outside air			
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	3,307 2,649 11,530 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	46 485	CFM CFM	17,487	Btuh
Heating Supply Air: 5,957 / Winter Vent Outside Air (10	(.986 X 1.08 X 12) = 0.0% of supply) =		485 485	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	9,948 658 : 634 0 414 ly side of coil:	Btuh Btuh Btuh Btuh Btuh			11,654	Btuh
Cooling Supply Air: 11,700 Summer Vent Outside Air (8	/ (.986 X 1.1 X 20) = 39.9% of supply) =		540 485	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 1,578 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	485	CFM	1,578 13,231	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	0 135 1,442 dling system: atent gain:	Btuh Btuh Btuh			1,577 14,808	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD 89.89% of Supply):	):	540 485	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		902 0.5982 731.0 0.0014 19.39	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		17,487 1.23	Btuh Tons		

<b>Chvac - F</b> Tres West Tacoma, V	ull Commercial HVAC Loads Engineers NA 98409-7315	Calculation Prog	gram		E	Lite Software De CHC P City of P Development A P	velopment, Inc. uyallup Cannery <sup>tyallup</sup> Service Page 52
Air Ha	andler #27 - FCU2	-6 - Summ	nary Loads			Building Engineering Fire	Planning Public Works Traffic
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
83	Provider Pod 220 5pm July	916 20 7,784	8,858 908 0.99	21,730 1,060 1.16	4,732 778 778	6AC/Hr 778 908	6AC/Hr 778 869
84	Tele Health 221 2pm July	47 1 402	244 25 0.53	728 35 0.75	232 27 27	4AC/Hr 27 25	4AC/Hr 27 29
85	Tele Health 222 2pm July	47 1 402	244 25 0.53	728 35 0.75	232 27 27	4AC/Hr 27 25	4AC/Hr 27 29
86	Exam/ Consult 223 2pm July	97 2 825	499 51 0.53	1,478 72 0.74	463 82 82	6AC/Hr 82 51	6AC/Hr 82 59
87	Exam/ Consult 224 2pm July	98 2 833	505 52 0.53	1,487 72 0.74	463 83 83	6AC/Hr 83 52	6AC/Hr 83 59
88	Exam/ Consult 225 2pm July	97 2 825	499 51 0.53	1,478 72 0.74	463 82 82	6AC/Hr 82 51	6AC/Hr 82 59
89	Exam/ Consult 226 2pm July	99 2 841	510 52 0.53	1,496 73 0.74	463 84 84	6AC/Hr 84 52	6AC/Hr 84 60
	Zone Peak Totals: Total Zones: 7 Unique Zones: 7	1,401 30 11,912	11,358 1,164 0.83	29,124 1,420 1.01	7,048 1,163 1,163	1,164 1,164	1,164 1,165

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>A</b>		Elite Software Deve CHC Puy Development & Permi	lopment, Inc. allup Cannery
Air Handler #27 - F	-CU2-6 - Total	Load S	ummary		Building Engineering Pr	MIT Planning Iblic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-6 Constant V Draw-Thru with prog 67% motor and fan 0.81	plume - Sur gram estima efficiency w	n of Peaks ated horsepower of ith 2 in. water acro T	0.67 HP ss the fan his system oce	curs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	5pm in July. Clg: 86° DB, 67° WB Clg: 75° DB, 50% R	3, 69.39 gra H, Htg: 72°	iins, Htg: 29° DB DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventila	ation controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	7,382 3,976 28,832 0 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	69 1,164	CFM CFM	40,189	Btuh
Heating Supply Air: 11,358 Winter Vent Outside Air (10	/ (.986 X 1.08 X 9) = 0.0% of supply) =		1,164 1,164	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	27,841 988 : 1,668 0 285 Ily side of coil:	Btuh Btuh Btuh Btuh Btuh			30,782	Btuh
Cooling Supply Air: 30,782 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 82.0% of supply) =		1,420 1,164	CFM CFM		
Return duct sensible gain: Return plenum sensible gain Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air h	n: 0 6,943 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	1,164	CFM	6,943 37,725	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and l	6,900 203 3,462 dling system: atent gain:	Btuh Btuh Btuh			10,565 48,290	Btuh Btuh
Check Figures						
Total Air Handler Supply Ai Total Air Handler Vent. Air	r (based on a 20° TD (82.03% of Supply):	):	1,420 1,164	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		1,401 1.0130 348.2 0.0029 28.68	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: h Outside Air:		40,189 4.02	Btuh Tons		

Chvac - Tres We Tacoma	Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 Air Handler #28 - FCU2-7 - Summary Loads											
All Handler #26 - FCU2-7 - Summary Loads												
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.					
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM					
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM					
91	Exam/ Consult 228	111	571	1,608	464	6AC/Hr	6AC/Hr					
	2pm July	2	94	94	94	94	94					
		944	0.85	0.85	94	94	94					
	Zone Peak Totals:	111	571	1,608	464							
	Total Zones: 1	2	94	94	94	94	94					
	Unique Zones: 1	944	0.85	0.85	94	94	94					

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	_ <b>.</b>		Elite Software CH	Develop C Puyallu Sity of Puyallup	ment, Inc. p Cannery Page 55
Air Handler #28 - F	-CU2-7 - Total	Load	Summary		Buil	SSUED PERMIT sing Planning tering Public Works	
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-7 Constant V Draw-Thru with prog 67% motor and fan 0.81	olume - S gram estir efficiency	oum of Peaks nated horsepower of with 2 in. water acros Th	0.04 HP ss the fan his system occ	curs 1 time(s) ir	e Traffic	lding
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	2pm in July. Clg: 88° DB, 67° WB Clg: 75° DB, 50% R	3, 66.47 g H, Htg: 72	grains, Htg: 29° DB 2° DB				
Summer: Ventilation contro	ls outside air, Wi	nter: Ven	tilation controls outsic	de air.			
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	257 315 4,319 0 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	6 94	CFM CFM	4,	890 Bt	uh
Heating Supply Air: 571 / (.9 Winter Vent Outside Air (10	986 X 1.08 X 6) = 0.0% of supply) =		94 94	CFM CFM			
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	1,517 91 : 110 0 319 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			2,	037 Bt	uh
Cooling Supply Air: 2,037 / Summer Vent Outside Air (	(.986 X 1.1 X 20) = 100.4% of supply) =		94 94	CFM CFM			
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 1,330 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	94	CFM	1, 3,	330 Bt 367 Bt	uh uh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	460 4 77 dling system: atent gain:	Btuh Btuh Btuh			3,	541 Bt 908 Bt	uh uh
Check Figures							
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD (100.44% of Supply):	):	94 94	CFM CFM			
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	<del>)</del> :		111 0.8463 340.8 0.0029 44.06	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft			
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		4,890 0.33	Btuh Tons			

Chvac - Tres We Tacoma	Chvac - Full Commercial HVAC Loads Calculation Program       Elite Software Development, Inc.         Tres West Engineers       CHC Puyallup Cannery         Tacoma, WA 98409-7315       Page 56         Air Handler #29 - FCU2-8 - Summary Loads       Page 56										
Zn     Description     Area     Htg.Loss     Sen.Gain     Lat.Gain     Htg.O.A.       No     Zone Peak Time     People     Htg.CFM     Clg.CFM     S.Exh     Req.CFM       Volume     CFM/Sqft     CFM/Sqft     W.Exh     Act.CFM											
92	Exam/ Consult 229 5pm July	98 2 833	1,140 83 0.85	2,923 143 1.45	474 0 0	6AC/Hr 83 83	6AC/Hr 83 83				
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	98 2 833	1,140 83 0.85	2,923 143 1.45	474 0 0	83 83	83 83				

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>	Elite Softw	CHC Puy	lopment, Inc. allup Cannery Based 57
Air Handler #29 - F	-CU2-8 - Total	Load	d Summary		Building Pl Engineering Pub	ic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-8 Constant V Draw-Thru with prog 67% motor and fan 0.87	olume - gram es efficiend	Sum of Peaks stimated horsepower of cy with 2 in. water acros Th	0.07 HP ss the fan his system occurs 1 time(	s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	5pm in July. Clg: 86° DB, 67° Wf Clg: 75° DB, 50% R	3, 69.39 H, Htg:	9 grains, Htg: 29° DB 72° DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Ve	entilation controls outsic	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	862 278 3,813 0 0 ss: 0	Btuh Btuh Btuh Btuh Btuh Btuh	5 83	CFM CFM	4,953	Btuh
Heating Supply Air: 1,140 / Winter Vent Outside Air (10	(.986 X 1.08 X 13) = 0.0% of supply) =		83 83	CFM CFM	ŗ	
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	2,854 69 167 0 0 Ny side of coil:	Btuh Btuh Btuh Btuh Btuh			3,090	Btuh
Cooling Supply Air: 3,090 / Summer Vent Outside Air (	(.986 X 1.1 X 20) = 58.5% of supply) =		142 83	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 993 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	83	CFM	993 4,084	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	460 14 248 dling system: atent gain:	Btuh Btuh Btuh			722 4,806	Btuh Btuh
Check Figures						
Total Air Handler Supply Ai Total Air Handler Vent. Air	r (based on a 20° TD (58.46% of Supply):	):	142 83	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		98 1.4541 244.7 0.0041 50.54	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: h Outside Air:		4,953 0.40	Btuh Tons		

Chvac - Tres We Tacoma,	Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 A in L Loss elloss for the sector of the s										
Air Handler #30 - FCU2-10 - Summary Loads											
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM				
100	Exam/ Consult 239 5pm July	99 2 841	1,142 84 0.85	2,928 143 1.44	474 0 0	6AC/Hr 84 84	6AC/Hr 84 84				
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	99 2 841	1,142 84 0.85	2,928 143 1.44	474 0 0	84 84	84 84				

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Deve CHC Puy CHY of Puya Development & from	vallup Cannery Page 59
Air Handler #30 - F	-CU2-10 - Tota	al Load	Summary		Building Pu Engineering Pu	Planning blic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-10 Constant Draw-Thru with prog 67% motor and fan 0.87	Volume - S gram estin efficiency	Sum of Peaks nated horsepower of with 2 in. water acro TI	0.07 HP ss the fan his system occ	curs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	5pm in July. Clg: 86° DB, 67° WB Clg: 75° DB, 50% R	3, 69.39 g H, Htg: 72	rains, Htg: 29° DB 2° DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Vent	ilation controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	861 281 3,852 0 0 ss: 0	Btuh Btuh Btuh Btuh Btuh Btuh	5 84	CFM CFM	4,994	Btuh
Heating Supply Air: 1,142 / Winter Vent Outside Air (10	(.986 X 1.08 X 13) = 0.0% of supply) =		84 84	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	2,858 70 : 168 0 0 vly side of coil:	Btuh Btuh Btuh Btuh Btuh			3,095	Btuh
Cooling Supply Air: 3,095 / Summer Vent Outside Air (	(.986 X 1.1 X 20) = 59.0% of supply) =		143 84	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 1,004 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	84	CFM	1,004 4,099	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	460 14 250 dling system: atent gain:	Btuh Btuh Btuh			725 4,823	Btuh Btuh
Check Figures						
Total Air Handler Supply Ai Total Air Handler Vent. Air	r (based on a 20° TD (58.96% of Supply):	):	143 84	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	э:		99 1.4417 246.3 0.0041 50.44	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		4,994 0.40	Btuh Tons		

Chvac - Full Commercial HVAC Loads Calculation Program       Elite Software         Tres West Engineers       CH         Tacoma, WA 98409-7315       CH         Air Handler #31 - FCU2-11 - Summary Loads       CH									
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM		
99	Exam/ Consult 238 2pm July	110 2 935	566 94 0.85	1,599 93 0.85	464 0 0	6AC/Hr 94 94	6AC/Hr 94 94		
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	110 2 935	566 94 0.85	1,599 93 0.85	464 0 0	94 94	94 94		

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	0.		Elite Software Deve CHC Pu	vallup Cannery Page 61
Air Handler #31 - F		al Load S	Summarv		ISSUED PER Building Engineering Pu	MIT Planning blic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-11 Constant Draw-Thru with prog 67% motor and fan 0.81	Volume - Su gram estimat efficiency wi	m of Peaks red horsepower of th 2 in. water acro Tl	0.04 HP ss the fan his system occu	urs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	2pm in July. Clg: 88° DB, 67° WI Clg: 75° DB, 50% R	3, 66.47 grai H, Htg: 72° l	ns, Htg: 29° DB DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventila	tion controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	254 312 4,280 0 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	5 94	CFM CFM	4,846	Btuh
Heating Supply Air: 566 / (. Winter Vent Outside Air (10	986 X 1.08 X 6) = 0.0% of supply) =		94 94	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	1,509 90 : 109 0 311 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			2,019	Btuh
Cooling Supply Air: 2,019 / Summer Vent Outside Air (*	(.986 X 1.1 X 20) = 100.4% of supply) =		93 94	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 1,318 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	94	CFM	1,318 3,337	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	460 4 77 dling system: atent gain:	Btuh Btuh Btuh			540 3,877	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD (100.43% of Supply):	):	93 94	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		110 0.8464 340.4 0.0029 44.06	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		4,846 0.32	Btuh Tons		

<b>Chvac - F</b> Tres West Tacoma, V	Avac - Full Commercial HVAC Loads Calculation Program es West Engineers coma, WA 98409-7315 City of Payallup Cannery City of Payallup Cannery									
Air Ha	andler #32 - FCU2	-12 - Sum	mary Load	s		Building Engineering	Planning Public Works Traffic			
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Saft	Sen.Gain Clg.CFM CFM/Soft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM			
101	Provide Pod 240 5pm July	936 20 7,956	8,448 883 0.94	21,733 1,060 1.13	4,735 790 790	6AC/Hr 796 883	6AC/Hr 796 869			
102	Exam/ Consult 241 2pm July	99 2 841	510 53 0.54	1,496 73 0.74	463 85 85	6AC/Hr 84 53	6AC/Hr 84 60			
103	Exam/ Consult 242 2pm July	97 2 825	499 52 0.54	1,478 72 0.74	463 85 85	6AC/Hr 82 52	6AC/Hr 82 59			
104	Exam/ Consult 243 2pm July	98 2 833	505 53 0.54	1,487 72 0.74	463 85 85	6AC/Hr 83 53	6AC/Hr 83 59			
105	Exam/ Consult 244 2pm September	106 2 901	1,176 123 1.16	2,756 134 1.27	430 95 95	6AC/Hr 90 123	6AC/Hr 90 110			
106	Tele Health 245 2pm July	46 1 391	237 25 0.54	716 35 0.76	232 15 15	6AC/Hr 39 25	6AC/Hr 39 29			
107	Tele Health 246 2pm July	46 1 391	237 25 0.54	716 35 0.76	232 15 15	6AC/Hr 39 25	6AC/Hr 39 29			
	Zone Peak Totals: Total Zones: 7 Unique Zones: 7	1,428 30 12,138	11,611 1,214 0.85	30,380 1,481 1.04	7,018 1,170 1,170	1,214 1,214	1,214 1,214			

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	h.		Elite Software Deve CHC Puy City of Puyali City of Puyali City of Puyali	lopment, Inc. allup Cannery
Air Handler #32 - F		al Load S	ummary		Building Pub Engineering Pub	ic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-12 Constant Draw-Thru with prog 67% motor and fan 0.82	Volume - Sum gram estimate efficiency with	of Peaks d horsepower of 2 in. water acro Ti	0.70 HP ss the fan his system occ	urs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	5pm in July. Clg: 86° DB, 67° WI Clg: 75° DB, 50% R	3, 69.39 grain H, Htg: 72° Di	s, Htg: 29° DB B			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventilatio	on controls outsid	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	7,560 4,051 30,946 0 0 ss: 0	Btuh Btuh Btuh Btuh Btuh Btuh	71 1,214	CFM CFM	42,557	Btuh
Heating Supply Air: 11,611 Winter Vent Outside Air (10	/ (.986 X 1.08 X 9) = 0.0% of supply) =		1,214 1,214	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	28,617 1,006 1,740 0 585 Ily side of coil:	Btuh Btuh Btuh Btuh Btuh			31,948	Btuh
Cooling Supply Air: 32,110 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 82.0% of supply) =		1,481 1,214	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 7,356 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	1,214	CFM	7,356 39,304	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and l	6,900 207 3,609 dling system: atent gain:	Btuh Btuh Btuh			10,715 50,020	Btuh Btuh
Check Figures						
Total Air Handler Supply Ai Total Air Handler Vent. Air	r (based on a 20° TD (81.97% of Supply):	):	1,481 1,214	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	e:		1,428 1.0370 342.6 0.0029 29.80	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: h Outside Air:		42,557 4.17	Btuh Tons		

<b>Chvac - Fu</b> Tres West Tacoma, W	hvac - Full Commercial HVAC Loads Calculation Program res West Engineers acoma, WA 98409-7315 Elite Software Development, Inc. CHC Puyallup Cannery Development Servers Page 64									
Air Ha	ndler #33 - FCU2	?-13 - Sum	mary Load	ls		Building Engineering	Planning Public Works Traffic			
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM			
65	2nd Hall 2 2pm July	436 0 3,924	2,485 152 0.35	4,125 201 0.46	15 130 130	2AC/Hr 131 152	2AC/Hr 131 127			
108	Med Room 271 2pm July	103 2 876	530 32 0.32	1,533 75 0.73	463 0 0	2AC/Hr 29 32	2AC/Hr 29 47			
109	Elec. 270 2pm July	112 0 952	577 35 0.32	1,042 51 0.45	4 35 35	2AC/Hr 32 35	2AC/Hr 32 32			
110	Storage 272 2pm July	40 0 340	206 13 0.32	372 18 0.45	1 11 11	2AC/Hr 11 13	2AC/Hr 11 11			
111	Consult 250 2pm July	157 2 1,335	808 50 0.32	2,036 99 0.63	465 135 135	6AC/Hr 133 50	6AC/Hr 133 63			
112	Office 251 2pm July	150 1 1,275	772 47 0.32	1,683 82 0.55	235 45 45	2AC/Hr 43 47	2AC/Hr 43 52			
113	Office 252 2pm September	150 1 1,275	1,500 92 0.61	2,902 142 0.94	188 0 0	2AC/Hr 43 92	2AC/Hr 43 89			
	Zone Peak Totals: Total Zones: 7 Unique Zones: 7	1,148 6 9,976	6,878 422 0.37	13,694 668 0.58	1,371 356 356	422 422	422 422			

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>)</b> ,		Elite Software Deve CHC Puy CHC Puy City of Puya	lopment, Inc. allup Cannery Page 65
Air Handler #33 - F	-CU2-13 - Tota	al Load S	Summary		Building Engineering Pu	Planning blic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-13 Constant Draw-Thru with prog 67% motor and fan 0.90	Volume - Su gram estimat efficiency wi	m of Peaks ed horsepower of th 2 in. water acros Th	0.31 HP ss the fan nis system oc	curs 1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° Wf Clg: 75° DB, 50% R	3, 69.81 grai H, Htg: 72° l	ns, Htg: 29° DB DB			
Summer: Ventilation contro	ls outside air, Wi	nter: Ventila	tion controls outsic	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	3,548 3,330 11,804 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	58 422	CFM CFM	18,682	Btuh
Heating Supply Air: 6,878 / Winter Vent Outside Air (10	(.986 X 1.08 X 15) = 0.0% of supply) =		422 422	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	12,578 808 : 784 0 89 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			14,259	Btuh
Cooling Supply Air: 14,470 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 63.2% of supply) =		667 422	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 2,860 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	422	CFM	2,860 17,119	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	1,380 188 1,253 Jling system: atent gain:	Btuh Btuh Btuh			2,822 19,941	Btuh Btuh
Check Figures						
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 20° TD 63.16% of Supply):	):	667 422	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	ə:		1,148 0.5813 690.8 0.0014 16.27	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: n Outside Air:		18,682 1.66	Btuh Tons		

Chvac - Full Commercial HVAC Loads Calculation Program       Elite Software Development         Tres West Engineers       CHC Puyallup Calculation Program         Tacoma, WA 98409-7315       Page 1000         Air Handler #34 - FCU2-16 - Summary Loads       Elite Software Development							
Zn       Description       Area       Htg.Loss       Sen.Gain       Lat.Gain       Htg.O.A.       Clg.         No       Zone Peak Time       People       Htg.CFM       Clg.CFM       S.Exh       Req.CFM       Req         Volume       CFM/Sqft       CFM/Sqft       W.Exh       Act.CFM       Act							
98	Exam/ Consult 237 2pm July	98 2 833	505 83 0.85	1,487 82 0.84	463 0 0	6AC/Hr 83 83	6AC/Hr 83 83
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	98 2 833	505 83 0.85	1,487 82 0.84	463 0 0	83 83	83 83

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Development, Inc. CHC Puyallup Cannery City of Puyallup Page 67
Air Handler #34 - F	- - CU2-16 - Tota	al Load	Summarv		Development & Permitting Services (ISSUED PERMIT) Building Planning Evolution Duble More
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-16 Constant V Draw-Thru with prog 67% motor and fan 0.79	Volume - S gram estima efficiency w	um of Peaks ated horsepower of vith 2 in. water acro T	0.04 HP ss the fan his system occ	curs 1 time(s) in the building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	2pm in July. Clg: 88° DB, 67° Wf Clg: 75° DB, 50% R	3, 66.47 gra H, Htg: 72°	ains, Htg: 29° DB DB		
Summer: Ventilation contro	ls outside air, Wi	nter: Ventil	ation controls outsid	de air.	
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	227 278 3,813 0 0 ss: 0	Btuh Btuh Btuh Btuh Btuh Btuh	5 83	CFM CFM	4,317 Btuh
Heating Supply Air: 505 / ( Winter Vent Outside Air (10	986 X 1.08 X 6) = 0.0% of supply) =		83 83	CFM CFM	
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	1,407 80 97 0 203 Ny side of coil:	Btuh Btuh Btuh Btuh Btuh			1,786 Btuh
Cooling Supply Air: 1,786 / Summer Vent Outside Air (	(.986 X 1.1 X 20) = 101.1% of supply) =		82 83	CFM CFM	
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 1,174 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	83	CFM	1,174 Btuh 2,960 Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	460 3 68 dling system: atent gain:	Btuh Btuh Btuh			532 Btuh 3,492 Btuh
Check Figures					
Total Air Handler Supply Ai Total Air Handler Vent. Air	r (based on a 20° TD (101.13% of Supply):	):	82 83	CFM CFM	
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	<b>):</b>		98 0.8405 336.8 0.0030 44.06	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft	
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: h Outside Air:		4,317 0.29	Btuh Tons	

<b>Chvac - F</b> Tres Wes Tacoma, V	hvac - Full Commercial HVAC Loads Calculation Program res West Engineers acoma, WA 98409-7315 Elite Software Development, Inc. CHC Puyallup Cannery Page 68									
Air Ha	andler #35 - FCU2	-14 - Sum	mary Load	s		Building Engineering Pu	Planning blic Works Traffic			
Zn	Description	Area	Htg.Loss	Sen.Gain	Lat.Gain	Htg.O.A.	Clg.O.A.			
No	Zone Peak Time	People	Htg.CFM	Clg.CFM	S.Exh	Req.CFM	Req.CFM			
		Volume	CFM/Sqft	CFM/Sqft	W.Exh	Act.CFM	Act.CFM			
114	Provider Pod 253	630	4,493	10,582	2,787	6AC/Hr	6AC/Hr			
	2pm July	12	685	663	700	693	693			
		6,930	1.09	1.05	700	685	663			
115	Procedure 254	147	811	1,959	458	6AC/Hr	6AC/Hr			
	3pm July	2	124	123	145	141	141			
		1,411	0.84	0.83	145	124	123			
116	Exam/ Consult 255	96	529	1,479	458	6AC/Hr	6AC/Hr			
	3pm July	2	81	93	95	92	92			
		922	0.84	0.97	95	81	93			
117	Exam/ Consult 256	99	546	1,507	458	6AC/Hr	6AC/Hr			
	3pm July	2	83	94	100	95	95			
		950	0.84	0.95	100	83	94			
118	Exam/ Consult 257	110	607	1,611	458	6AC/Hr	6AC/Hr			
	3pm July	2	92	101	110	106	106			
		1,056	0.84	0.92	110	92	101			
119	Exam/ consult 258	105	579	1,564	458	6AC/Hr	6AC/Hr			
	3pm July	2	88	98	100	101	101			
		1,008	0.84	0.93	100	88	98			
120	Exam/ Consult 259	109	1,294	2,837	425	6AC/Hr	6AC/Hr			
	2pm September	2	197	178	100	105	105			
		1,046	1.81	1.63	100	197	178			
	Zone Peak Totals:	1,296	8,858	21,538	5,503					
	Total Zones: 7	24	1,350	1,349	1,350	1,332	1,332			
	Unique Zones: 7	13,324	1.04	1.04	1,350	1,350	1,350			

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>	Elite \$	Software Deve CHC Puy City of Puyallup Development & Permitting	lopment, Inc. allup Cannery Page 69
Air Handler #35 - F		al Load	Summary		Building Plan Engineering Public	ning Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-14 Constant Draw-Thru with prog 67% motor and fan 0.84	Volume - S gram estim efficiency v	Sum of Peaks ated horsepower of with 2 in. water acros Th	0.63 HP ss the fan his system occurs 1 t	ime(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° Wi Clg: 75° DB, 50% R	3, 69.81 gr H, Htg: 72	ains, Htg: 29° DB ° DB			
Summer: Exhaust controls	outside air, Winte	er: Exhaus	t controls outside air			
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	4,411 4,447 33,018 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	78 1,350	CFM CFM	41,876	Btuh
Heating Supply Air: 8,858 / Winter Vent Outside Air (10	(.986 X 1.08 X 6) = 0.0% of supply) =		1,350 1,350	CFM CFM		
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	20,019 1,080 : 1,585 0 6,285 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			28,968	Btuh
Cooling Supply Air: 29,259 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 100.1% of supply) =		1,349 1,350	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 4,391 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	1,350	CFM	4,391 33,359	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	5,520 252 4,014 dling system: atent gain:	Btuh Btuh Btuh			9,785 43,145	Btuh Btuh
Check Figures						
Total Air Handler Supply Ai Total Air Handler Vent. Air	r (based on a 20° TD (100.05% of Supply):	):	1,349 1,350	CFM CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	ə:		1,296 1.0411 360.5 0.0028 32.31	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required Wit Total Cooling Required With	h Outside Air: n Outside Air:		41,876 3.60	Btuh Tons		

Chvac - Fu Tres West Tacoma, W	Chvac - Full Commercial HVAC Loads Calculation Program       Elite Software Development,         Tres West Engineers       CHC Puyallup Can         Tacoma, WA 98409-7315       Page         Air Handler #36 - FCU2-15 - Summary Loads       Page								
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM		
64	2nd Hall 1 2pm July	765 0 8,415	5,639 296 0.39	8,893 434 0.57	33 0 0	2AC/Hr 281 296	2AC/Hr 281 249		
121	Foster / Adoption 260 1pm July	290 2 3,190	3,882 203 0.70	6,284 306 1.06	520 0 0	2AC/Hr 106 203	2AC/Hr 106 176		
122	Storage 261 3pm July	72 0 720	407 21 0.30	681 33 0.46	-1 0 0	2AC/Hr 24 21	2AC/Hr 24 19		
123	Nutri / Infant 262 10am July	110 2 1,100	1,671 88 0.80	3,897 190 1.73	491 0 0	2AC/Hr 37 88	2AC/Hr 37 109		
124	Lab 263 10am July	160 2 1,600	2,478 130 0.81	5,519 269 1.68	505 0 0	6AC/Hr 160 130	6AC/Hr 160 154		
125	Blood 264 10am July	55 1 550	835 44 0.80	1,948 95 1.73	246 0 0	6AC/Hr 55 44	6AC/Hr 55 55		
126	Lab Wait 265 3pm July	55 3 550	311 16 0.30	1,383 67 1.23	689 0 0	2AC/Hr 18 16	2AC/Hr 18 39		
127	Spec Restroom 266 2pm July	51 0 434	263 14 0.27	452 22 0.43	2 0 0	10AC/Hr 72 14	10AC/Hr 72 13		
128	Spec Restroom 267 2pm July	51 0 434	263 14 0.27	452 22 0.43	2 0 0	10AC/Hr 72 14	10AC/Hr 72 13		
	Zone Peak Totals: Total Zones: 9 Unique Zones: 9	1,609 10 16,992	15,748 825 0.51	29,508 1,439 0.89	2,486 0 0	825 825	825 826		

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	Ŋ.	Elit	e Software Deve CHC Puy CHC Puyal	lopment, Inc. allup Cannery
Air Handler #36 - F	-CU2-15 - Tota	al Load S	ummarv		ISSUED PERM Building Pub	ic Works
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	FCU2-15 Constant Draw-Thru with prog 67% motor and fan 0.92	Volume - Sur gram estimate efficiency wit	n of Peaks ed horsepower of n 2 in. water acros Th	0.68 HP ss the fan nis system occurs	1 time(s) in the	building
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	1pm in July. Clg: 86° DB, 67° WI Clg: 75° DB, 50% R	3, 69.81 grair H, Htg: 72° D	ns, Htg: 29° DB B			
Summer: Ventilation control	ls outside air, Wi	nter: Ventilat	ion controls outsic	de air.		
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	10,077 5,671 37,778 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	99 825	CFM CFM	53 526	Btub
Heating Supply Air: 15,748 Winter Vent Outside Air (10	/ (.986 X 1.08 X 18) = 0.0% of supply) =	=	825 825	CFM CFM	00,020	Dian
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	26,227 1,377 : 1,690 0 1,867 Iy side of coil:	Btuh Btuh Btuh Btuh Btuh			31,160	Btuh
Cooling Supply Air: 31,189 Summer Vent Outside Air (	/ (.986 X 1.1 X 20) = 57.4% of supply) =		1,438 825	CFM CFM		
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 9,843 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	825	CFM	9,843 41,003	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and latent gain on air hand	2,300 321 2,454 Jling system: atent gain:	Btuh Btuh Btuh			5,075 46,078	Btuh Btuh
Check Figures Total Air Handler Supply Air	r (based on a 20° TD	):	1,438	CFM		
Total Air Handler Vent. Air (	57.38% of Supply):		825	CFM		
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	9:		1,609 0.8939 419.0 0.0024 33.27	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft		
Total Heating Required With Total Cooling Required With	h Outside Air: n Outside Air:		53,526 3.84	Btuh Tons		

Chvac - Fu Tres West I Tacoma, W	Chvac - Full Commercial HVAC Loads Calculation Program Tres West Engineers Tacoma, WA 98409-7315 CHC Puyallup Cannery Page 72									
Air Handler #38 - IDF - Summary Loads										
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM			
79	IDF 216 2pm July	86 0 731	443 73 0.85	6,211 320 3.72	3 0 0	6AC/Hr 73 73	6AC/Hr 73 73			
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	86 0 731	443 73 0.85	6,211 320 3.72	3 0 0	73 73	73 73			
Chvac - Full Commercial HVAC Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Development, Inc. CHC Puyallup Cannery Development & Promiss Arrowski					
--	--	--	--	---	--					
Air Handler #38 - I	DF - Total Loa	d Sumn	narv		ISSUED PERMIT Building Planning Engineering Public Works					
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	IDF Constant Volum Draw-Thru with prog 67% motor and fan 1.00	ie - Sum of gram estima efficiency w	Peaks ited horsepower of ith 2 in. water acros Th	0.15 HP ss the fan his system occ	curs 1 time(s) in the building					
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	3pm in July. Clg: 89° DB, 67° Wf Clg: 75° DB, 50% R	3, 65.22 gra H, Htg: 72°	ins, Htg: 29° DB DB							
Summer: Ventilation control	s outside air, Wi	nter: Ventila	ation controls outsic	de air.						
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss Total System sensible loss:	199 244 3,346 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	4 73	CFM CFM	3,789 Btuh					
Heating Supply Air: 443 / (. Winter Vent Outside Air (10	986 X 1.08 X 6) = 0.0% of supply) =		73 73	CFM CFM						
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	6,137 74 : 376 0 0 ly side of coil:	Btuh Btuh Btuh Btuh Btuh			6,587 Btuh					
Cooling Supply Air: 6,587 / Summer Vent Outside Air (2	(.986 X 1.1 X 19) = 22.9% of supply) =		320 73	CFM CFM						
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 1,110 n side of coil: andling system:	Btuh Btuh Btuh Btuh	73	CFM	1,110 Btuh 7,696 Btuh					
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and la	1 -1 -19 Iling system: atent gain:	Btuh Btuh Btuh			-19 Btuh 7,678 Btuh					
Check Figures										
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 19° TD 22.86% of Supply):	):	320 73	CFM CFM						
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	e:		86 3.7180 134.1 0.0075 44.06	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft						
Total Heating Required With Total Cooling Required With	n Outside Air: n Outside Air:		3,789 0.64	Btuh Tons						
Note: Due to the system's n	egative latent gain, t	onnage is b	ased solely on sen	sible gain.						

PRCTI20221698

Chvac - Tres Wes Tacoma,	lite Software De CHC P Destopment & Per USSUED USSUED Engineering	velopment, Inc. uyallup Cannery y <sup>allup</sup> Page 74 Planneg Public Works					
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
40	Elec 134 3pm July	140 0 1,256	419 42 0.30	1,081 56 0.40	-2 0 0	2AC/Hr 42 42	2AC/Hr 42 42
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	140 0 1,256	419 42 0.30	1,081 56 0.40	-2 0 0	42 42	42 42

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	1		Elite Software CH	City of Puyallup	opment, Inc. Ilup Cannery Page 75
Air Handler #39 - E	Elec 134 - Tota	l Load	Summarv		Bu	ISSUED PERMIT uilding Plann ineering Public V	ing /orks
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	Elec 134 Constant V Draw-Thru with prog 67% motor and fan 1.00	/olume - S gram estim efficiency	Sum of Peaks nated horsepower of with 2 in. water acro Ti	0.03 HP ss the fan his system occ	curs 1 time(s) i	in the t	vuilding
Air System Peak Time:3pm in July.Outdoor Conditions:Clg: 89° DB, 67° WB, 65.22 grains, Htg: 29° DBIndoor Conditions:Clg: 75° DB, 50% RH, Htg: 72° DB							
Summer: Ventilation control	ls outside air, Wi	nter: Venti	ilation controls outsid	de air.			
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss Total System sensible loss:	0 419 1,917 0 0 s: 0	Btuh Btuh Btuh Btuh Btuh Btuh	7 42	CFM CFM	2	2,336	Btuh
Heating Supply Air: 419 / (.9 Winter Vent Outside Air (10	986 X 1.08 X 9) = 0.0% of supply) =		42 42	CFM CFM			
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	953 128 : 65 0 0 ly side of coil:	Btuh Btuh Btuh Btuh Btuh			1	1,146	Btuh
Cooling Supply Air: 1,146 / Summer Vent Outside Air (7	(.986 X 1.1 X 19) = 75.3% of supply) =		56 42	CFM CFM			
Return duct sensible gain: Return plenum sensible gai Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air ha	n: 0 636 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	42	CFM	1	636 1,782	Btuh Btuh
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and la	0 -2 -11 dling system: atent gain:	Btuh Btuh Btuh			1	-12 1,770	Btuh Btuh
Check Figures							
Total Air Handler Supply Air Total Air Handler Vent. Air (	r (based on a 19° TD 75.31% of Supply):	):	56 42	CFM CFM			
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	ə:		140 0.3984 940.0 0.0011 16.74	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft			
Total Heating Required With Total Cooling Required With	h Outside Air: n Outside Air:		2,336 0.15	Btuh Tons			
Note: Due to the system's n	egative latent gain, t	onnage is	based solely on sen	sible gain.			

Chvac - Full Commercial HVAC Loads Calculation Program         Tres West Engineers         Tacoma, WA 98409-7315         Air Handler #40 - Fire Sprinkler 100A - Summary Loads							Elite Software Development, Inc. CHC Puyallup Cannery Criter of Puyallup Cannery Page 76		
Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM		
2	Fire Spinkler 100A 10am July	20 0 200	380 16 0.78	277 14 0.68	6 0 0	2AC/Hr 7 7	2AC/Hr 7 7		
	Zone Peak Totals: Total Zones: 1 Unique Zones: 1	20 0 200	380 16 0.78	277 14 0.68	6 0 0	7 7	7 7		

Chvac - Full Commercial HVA Tres West Engineers Tacoma, WA 98409-7315	C Loads Calculation Pr	ogram	<b>.</b>		Elite Software Deve CHC Pu	elopment, Inc vallup Canner	<b>c.</b> ry 77
Air Handler #40 - H	Fire Sprinkler 1	00A -	Total Load Su	mmarv	ISSUED PI Building Engineering	Planning ublic Works	
Air Handler Description: Supply Air Fan: Fan Input: Sensible Heat Ratio:	Fire Sprinkler 100A Draw-Thru with prog 67% motor and fan 0.99	Constant gram estin efficiency	Volume - Sum of Pe nated horsepower of with 2 in. water acro Tl	aks 0.01 HP ss the fan his system occ	curs 1 time(s) in the	building	
Air System Peak Time: Outdoor Conditions: Indoor Conditions:	11am in July. Clg: 79° DB, 65° Wl Clg: 75° DB, 50% R	3, 69.80 g H, Htg: 72	rains, Htg: 29° DB 2° DB				
Summer: Ventilation contro	Is outside air, W	nter: Vent	ilation controls outsid	de air.			
Zone Space sensible loss: Infiltration sensible loss: Outside Air sensible loss: Supply Duct sensible loss: Return Duct sensible loss: Return Plenum sensible loss: Total System sensible loss:	313 67 305 0 0 ss: 0	Btuh Btuh Btuh Btuh Btuh Btuh	1 7	CFM CFM	685	Btuh	
Heating Supply Air: 380 / (. Winter Vent Outside Air (42	986 X 1.08 X 23) = 2.9% of supply) =		16 7	CFM CFM			
Zone space sensible gain: Infiltration sensible gain: Draw-thru fan sensible gain: Supply duct sensible gain: Reserve sensible gain: Total sensible gain on supp	261 6 16 0 0 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9	Btuh Btuh Btuh Btuh Btuh			283	Btuh	
Cooling Supply Air: 293 / (.4 Summer Vent Outside Air (	986 X 1.1 X 20) = 49.5% of supply) =		13 7	CFM CFM			
Return duct sensible gain: Return plenum sensible gain Outside air sensible gain: Blow-thru fan sensible gain Total sensible gain on retur Total sensible gain on air h	in: 0 29 : 0 n side of coil: andling system:	Btuh Btuh Btuh Btuh	7	CFM	29 312	Btuh Btuh	
Zone space latent gain: Infiltration latent gain: Outside air latent gain: Total latent gain on air hand Total system sensible and I	0 4 25 dling system: atent gain:	Btuh Btuh Btuh			29 341	Btuh Btuh	
Check Figures							
Total Air Handler Supply Ai Total Air Handler Vent. Air	r (based on a 20° TD (49.50% of Supply):	):	13 7	CFM CFM			
Total Conditioned Air Space Supply Air Per Unit Area: Area Per Cooling Capacity: Cooling Capacity Per Area: Heating Capacity Per Area:	e:		20 0.6734 704.4 0.0014 34.26	Sq.ft CFM/Sq.ft Sq.ft/Ton Tons/Sq.ft Btuh/Sq.ft			
Total Heating Required Wit Total Cooling Required Wit	h Outside Air: h Outside Air:		685 0.03	Btuh Tons			