



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 15, 2023                      **Inspection Result:**     **NOT READY**

**Permit Number:** PRCA20220482

**Property Address:** 3303 8TH AVE SE, Unit: A, PUYALLUP, WA 98372;

**Contractor:** CROWN BUILDING PO BOX 726 MILTON, WA 98354-0726

**To construct:** We are finishing the construction of our greenhouse by connecting a 2nd module to the 1st and expanding the foundation to accommodate. This is a prefabricated greenhouse addition (2nd module) to be attached to our existing greenhouse. Most of the required information is included in the construction set or permit (E-21-0440). Structure Valuation \$78,754.10 email March 3, 2023

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. Called in in error
- 2 1. provide corner bars at foundation as discussed with contractor
2. provide min clearance from rebar to forms
3. provide min clearance from rebar to ground
4. remove all rebar drove in the ground
5. protect pipe from concrete as discussed with contractor
6. provide test on plumbing as discussed with contractor at the time of next inspection

Sincerely,

Kevin Spruell  
Building Inspector I



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)

(253) 841-5590