

# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L20-R031-Plans

Calculation Date: 4/21/2023

## Design

Remote Area Number: 1  
Remote Area Location: BOILER ROOM  
Occupancy Classification: Ordinary Group I  
Commodity Classification: N/A

Density: 0.15gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 922ft<sup>2</sup>)  
Coverage per Sprinkler: 99ft<sup>2</sup>  
Type of sprinklers calculated: Upright  
No. of sprinklers calculated: 19  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 250.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 563.54 @ 43.557 (Safety Margin = 16.016)  
Type of System: WET  
Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

## Notes:

Automatic peaking results Left: N/A Right: 43.557

FPET NICET #106245 LEVEL IV, MSME




# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: 1

N<sup>1.85</sup>

Date: 4/21/2023

**Water Supply  
Summary Sheet  
Node: 1**





# Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	1000	22.33	14.85	5.6	15.895		
Sprinkler	1001	21.11	14.85	5.6	14.208		
Sprinkler	1002	15.73	14.85	5.6	7.886		
Sprinkler	1003	15.82	14.85	5.6	7.979		
Sprinkler	1004	15.35	14.85	5.6	7.512		
Sprinkler	1005	15.44	14.85	5.6	7.602		
Sprinkler	1006	15.14	14.85	5.6	7.312		
Sprinkler	1007	19.79	14.85	5.6	12.483		
Sprinkler	1008	15.23	14.85	5.6	7.393		
Sprinkler	1009	20.01	14.85	5.6	12.771		
Sprinkler	1010	16.15	14.85	5.6	8.316		
Sprinkler	1011	14.87	14.85	5.6	7.051		
Sprinkler	1012	14.96	14.85	5.6	7.135		
Sprinkler	1013	15.76	14.85	5.6	7.924		
⇒ Sprinkler	<b>1014</b>	<b>14.85</b>	<b>14.85</b>	<b>5.6</b>	<b>7.032</b>		
Sprinkler	1015	14.94	14.85	5.6	7.115		
Sprinkler	1016	15.55	14.85	5.6	7.711		
Sprinkler	1017	15.27	14.85	5.6	7.439		
Sprinkler	1018	15.25	14.85	5.6	7.416		

⇒ Most Demanding Sprinkler Data

<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	64.000	20.000	1950.00	59.573	563.54	43.557

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-15'-0	Supply	43.557	313.54	
1000	0'-5	Sprinkler	15.895	22.33	
1001	0'-5	Sprinkler	14.208	21.11	
1002	0'-4½	Sprinkler	7.886	15.73	
1003	0'-4½	Sprinkler	7.979	15.82	
1004	0'-4	Sprinkler	7.512	15.35	
1005	0'-4	Sprinkler	7.602	15.44	
1006	0'-4	Sprinkler	7.312	15.14	
1007	0'-2½	Sprinkler	12.483	19.79	
1008	0'-4	Sprinkler	7.393	15.23	
1009	0'-4½	Sprinkler	12.771	20.01	
1010	0'-4½	Sprinkler	8.316	16.15	
1011	0'-3½	Sprinkler	7.051	14.87	
1012	0'-3½	Sprinkler	7.135	14.96	
1013	0'-4	Sprinkler	7.924	15.76	
1014	0'-3½	Sprinkler	7.032	14.85	
1015	0'-3½	Sprinkler	7.115	14.94	
1016	0'-4	Sprinkler	7.711	15.55	
1017	0'-3½	Sprinkler	7.439	15.27	

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1018	0'-3½	Sprinkler	7.416	15.25	
2	-15'-0		43.417		
3	-15'-0		41.389		
6	-15'-0		39.579		
7	-8'-9½		36.503		
100	-7'-0		35.723		
101	-4'-9½		25.221		
102	-1'-5		18.459		
103	-1'-4		16.554		
104	-1'-3		14.898		
105	-1'-3		14.669		
106	-0'-3		9.750		
107	-0'-3½		9.306		
108	-0'-3½		8.959		
109	-0'-4		8.757		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
1014	0'-3½	5.6	14.85	1½	(See Notes)	9'-0	120	7.032	••••• Route 1 ••••• Sprinkler
1015	0'-3½		14.85	1.6100			0.009313	-0.001	
						9'-0		0.084	
1015	0'-3½	5.6	14.94	1½	(See Notes)	8'-11½	120	7.115	Sprinkler
1018	0'-3½		29.79	1.6100			0.033757	-0.001	
						8'-11½		0.303	
1018	0'-3½	5.6	15.25	1½	(See Notes)	2'-5	120	7.416	Sprinkler, E(4'-0), PO(8'-0)
110	-0'-4		45.04	1.6100		12'-0	0.072531	0.271	
						14'-5		1.046	
110	-0'-4			2½		4'-6½	120	8.733	
109	-0'-4		45.04	2.6350			0.006585	-0.006	
						4'-6½		0.030	
109	-0'-4		45.10	2½		9'-0	120	8.757	Flow (q) from Route 2
108	-0'-3½		90.14	2.6350			0.023771	-0.012	
						9'-0		0.214	
108	-0'-3½		45.92	2½		7'-0	120	8.959	Flow (q) from Route 3
107	-0'-3½		136.06	2.6350			0.050915	-0.009	
						7'-0		0.356	
107	-0'-3½		46.55	2½		5'-1½	120	9.306	Flow (q) from Route 4
106	-0'-3		182.61	2.6350			0.087757	-0.007	
						5'-1½		0.450	
106	-0'-3		47.69	2½	(See Notes)	8'-7½	120	9.750	Flow (q) from Route 5 3E(8'-3)
105	-1'-3		230.31	2.6350		24'-8½	0.134808	0.428	
						33'-4		4.491	
105	-1'-3		19.79	2½		1'-5	120	14.669	Flow (q) from Route 6
104	-1'-3		250.09	2.6350			0.157012	0.005	
						1'-5		0.224	
104	-1'-3		20.01	2½		8'-11½	120	14.898	Flow (q) from Route 7
103	-1'-4		270.10	2.6350			0.181042	0.031	
						8'-11½		1.625	
103	-1'-4		21.11	2½		9'-0	120	16.554	Flow (q) from Route 8
102	-1'-5		291.21	2.6350			0.208083	0.031	
						9'-0		1.874	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
102	-1'-5		22.33	2½	(See Notes)	5'-8½	120	18.459	Flow (q) from Route 9 2E(8'-3)
101	-4'-9½		313.54	2.6350		16'-5½	0.238554	1.468	
						22'-2½		5.294	
101	-4'-9½			3	(See Notes)	40'-7	120	25.221	f(-3.000), CV(7'-1½), E(9'-5), PO(20'-2)
100	-7'-0		313.54	3.2600		36'-8½	0.084610	0.964	
						77'-3½		9.538	
100	-7'-0			6		1'-9½	120	35.723	
7	-8'-9½		313.54	6.3570			0.003273	0.774	
						1'-9½		0.006	
7	-8'-9½			6	(See Notes)	86'-3½	140	36.503	3E(23'-1½)
6	-15'-0		313.54	6.3400		69'-4	0.002493	2.688	
						155'-7½		0.388	
6	-15'-0			6	(See Notes)	4'-1½	140	39.579	BFP(-1.738)
3	-15'-0		313.54	6.3400			0.002493		
						4'-1½		1.811	
3	-15'-0			6	(See Notes)	11'-2½	140	41.389	PIV(-2.000)
2	-15'-0		313.54	6.3400			0.002493		
						11'-2½		2.028	
2	-15'-0			6	(See Notes)	21'-7	140	43.417	E(23'-1½), EE(11'-6½), S
1	-15'-0		313.54	6.3400			0.002493		
						56'-3		0.140	
			250.00					43.557	Hose Allowance At Source
1			563.54						Total(Pt) Route 1
1011	0'-3½	5.6	14.87	1½	(See Notes)	9'-0	120	7.051	..... Route 2 ..... Sprinkler
1012	0'-3½		14.87	1.6100			0.009337	0.000	
						9'-0		0.084	
1012	0'-3½	5.6	14.96	1½	(See Notes)	8'-11½	120	7.135	Sprinkler
1017	0'-3½		29.83	1.6100			0.033844	0.000	
						8'-11½		0.304	
1017	0'-3½	5.6	15.27	1½	(See Notes)	2'-5	120	7.439	Sprinkler, E(4'-0), PO(8'-0)
109	-0'-4		45.10	1.6100			0.072725	0.270	
						14'-5		1.048	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes  Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
					Total (Foot)			Friction(Pf)	
								8.757	Total(Pt) Route 2
1006	0'-4	5.6	15.14	1½	(See Notes)	8'-0	120	7.312	***** Route 3 ***** Sprinkler
1008	0'-4		15.14	1.6100		8'-0	0.009656	0.004	
1008	0'-4	5.6	15.23	1½	(See Notes)	8'-11½	120	7.393	Sprinkler
1016	0'-4		30.37	1.6100		8'-11½	0.034987	0.004	
1016	0'-4	5.6	15.55	1½	(See Notes)	1'-0	120	7.711	Sprinkler, E(4'-0), PO(8'-0)
108	-0'-3½		45.92	1.6100		12'-0	0.075180	0.271	
						13'-0		0.977	
								8.959	Total(Pt) Route 3
1004	0'-4	5.6	15.35	1½	(See Notes)	9'-0	120	7.512	***** Route 4 ***** Sprinkler
1005	0'-4		15.35	1.6100		9'-0	0.009900	0.000	
1005	0'-4	5.6	15.44	1½	(See Notes)	8'-11½	120	7.602	Sprinkler
1013	0'-4		30.79	1.6100		8'-11½	0.035887	0.000	
1013	0'-4	5.6	15.76	1½	(See Notes)	2'-5	120	7.924	Sprinkler, E(4'-0), PO(8'-0)
107	-0'-3½		46.55	1.6100		12'-0	0.077109	0.271	
						14'-5		1.112	
								9.306	Total(Pt) Route 4
1002	0'-4½	5.6	15.73	1½	(See Notes)	9'-0	120	7.886	***** Route 5 ***** Sprinkler
1003	0'-4½		15.73	1.6100		9'-0	0.010355	0.000	
1003	0'-4½	5.6	15.82	1½	(See Notes)	8'-11½	120	7.979	Sprinkler
1010	0'-4½		31.54	1.6100		8'-11½	0.037534	0.000	
1010	0'-4½	5.6	16.15	1½	(See Notes)	2'-5	120	8.316	Sprinkler, E(4'-0), PO(8'-0)
106	-0'-3		47.69	1.6100		12'-0	0.080642	0.271	
						14'-5		1.163	
								9.750	Total(Pt) Route 5



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
1007	0'-2½	5.6	19.79	1	(See Notes)	3'-2½	120	12.483		
105	-1'-3		19.79	1.0490		9'-0	0.127557	0.627		
						12'-2½		1.560		
								14.669	Total(Pt) Route 6	
1009	0'-4½	5.6	20.01	1	(See Notes)	3'-10½	120	12.771		
104	-1'-3		20.01	1.0490		7'-0	0.130278	0.710		
						10'-10½		1.417		
								14.898	Total(Pt) Route 7	
1001	0'-5	5.6	21.11	1	(See Notes)	4'-0	120	14.208		
103	-1'-4		21.11	1.0490		7'-0	0.143787	0.764		
						11'-0		1.582		
								16.554	Total(Pt) Route 8	
1000	0'-5	5.6	22.33	1	(See Notes)	4'-1	120	15.895		
102	-1'-5		22.33	1.0490		7'-0	0.159511	0.797		
						11'-1		1.767		
								18.459	Total(Pt) Route 9	

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L21-R041-Plans

Calculation Date: 5/16/2023

## Design

Remote Area Number: 2  
Remote Area Location: FAB LAB  
Occupancy Classification: Ordinary Group II  
Commodity Classification: N/A

Density: 0.20gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 1027ft<sup>2</sup>)  
Coverage per Sprinkler: 100ft<sup>2</sup>  
Type of sprinklers calculated: Upright, Pendent  
No. of sprinklers calculated: 15  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 250.00 at Node: 1 Type: Allowance at Source


Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 637.25 @ 47.625 (Safety Margin = 10.818)  
Type of System: WET  
Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

Notes:

Automatic peaking results Left: N/A Right: N/A

FPET NICET #106245 LEVEL IV,MSME




# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: 2

N<sup>1.85</sup>

Date: 5/16/2023

**Supply  
Summary Sheet  
Node: 1**





# Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	2600	27.07	20.00	5.6	23.370		
Sprinkler	2601	27.10	20.00	5.6	23.421		
Sprinkler	2602	26.00	20.00	5.6	21.554		
Sprinkler	2603	26.36	20.00	5.6	22.156		
Sprinkler	2604	25.55	20.00	5.6	20.809		
Sprinkler	2605	25.45	20.00	5.6	20.657		
Sprinkler	2606	25.42	20.00	5.6	20.599		
Sprinkler	2607	24.92	20.00	5.6	19.801		
Sprinkler	2608	24.59	20.00	5.6	19.286		
Sprinkler	2609	25.62	20.00	5.6	20.925		
Sprinkler	2610	24.45	20.00	5.6	19.063		
Sprinkler	2611	25.86	20.00	5.6	21.329		
Sprinkler	2612	26.70	26.00	5.6	22.733		
Sprinkler	2613	26.16	26.00	5.6	21.824		
⇒ Sprinkler	<b>2614</b>	<b>26.00</b>	<b>26.00</b>	<b>5.6</b>	<b>21.556</b>		

⇒ Most Demanding Sprinkler Data

<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	64.000	20.000	1950.00	58.443	637.25	47.625

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-15'-0	Supply	47.625	387.25	
2600	13'-9½	Sprinkler	23.370	27.07	
2601	13'-9½	Sprinkler	23.421	27.10	
2602	13'-9½	Sprinkler	21.554	26.00	
2603	13'-9½	Sprinkler	22.156	26.36	
2604	13'-9½	Sprinkler	20.809	25.55	
2605	13'-9	Sprinkler	20.657	25.45	
2606	13'-9½	Sprinkler	20.599	25.42	
2607	13'-9½	Sprinkler	19.801	24.92	
2608	13'-9½	Sprinkler	19.286	24.59	
2609	13'-9½	Sprinkler	20.925	25.62	
2610	13'-9½	Sprinkler	19.063	24.45	
2611	13'-9½	Sprinkler	21.329	25.86	
2612	8'-7½	Sprinkler	22.733	26.70	
2613	8'-7½	Sprinkler	21.824	26.16	
2614	8'-7½	Sprinkler	21.556	26.00	
2	-15'-0		47.417		
3	-15'-0		45.376		
6	-15'-0		43.393		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
7	-8'-9½"		40.132		
8	2'-6½"		35.030		
200	11'-5"		27.428		
201	12'-2"		27.057		
202	13'-2"		26.233		
203	13'-2"		26.339		
204	11'-5"		26.740		
205	12'-0"		25.684		
206	12'-0"		26.314		
207	12'-0"		25.738		
208	12'-0"		24.395		
209	12'-0"		23.757		
210	12'-0"		22.966		
211	12'-0"		22.791		
212	12'-0"		26.278		
213	12'-0"		22.742		
214	12'-0"		23.706		
215	12'-0"		24.146		
216	12'-0"		22.236		
217	12'-0"		21.349		
218	12'-0"		21.269		
219	12'-0"		21.112		
220	12'-0"		23.089		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
221	12'-0		26.264		
222	12'-0		21.004		
223	12'-0		21.895		
224	12'-0		21.938		
225	12'-0		20.728		



Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
2614	8'-7½"	5.6	26.00	1	(See Notes)	1'-0"	120	21.556	••••• Route 1 ••••• Sprinkler, E(2'-0), fd
225	12'-0"		26.00	1.0490		2'-0"	0.211435	-1.462	
						3'-0"		0.634	
225	12'-0"			1½"	(See Notes)	2'-7"	120	20.728	E(4'-0), PO(8'-0)
219	12'-0"		26.00	1.6100		12'-0"	0.026249		
						14'-7"		0.383	
219	12'-0"		24.45	2		7'-3½"	120	21.112	Flow (q) from Route 4
218	12'-0"		50.45	2.1570		7'-3½"	0.021533	0.157	
218	12'-0"		26.16	2		1'-8½"	120	21.269	Flow (q) from Route 2
217	12'-0"		76.61	2.1570		1'-8½"	0.046639	0.080	
217	12'-0"		24.59	2		7'-0"	120	21.349	Flow (q) from Route 5
223	12'-0"		101.20	2.1570		7'-0"	0.078059	0.546	
223	12'-0"		24.92	2		2'-11"	120	21.895	Flow (q) from Route 6
216	12'-0"		126.12	2.1570		2'-11"	0.117294	0.340	
216	12'-0"		26.70	2		5'-1"	120	22.236	Flow (q) from Route 3
220	12'-0"		152.82	2.1570		5'-1"	0.167324	0.853	
220	12'-0"		25.62	2		2'-9"	120	23.089	Flow (q) from Route 10
214	12'-0"		178.44	2.1570		2'-9"	0.222878	0.617	
214	12'-0"			2½"		5'-3"	120	23.706	Flow (q) from Route 11 PO(16'-5½")
215	12'-0"		178.44	2.6350		5'-3"	0.084085	0.440	
215	12'-0"		25.86	2½"	(See Notes)	3'-1½"	120	24.146	Flow (q) from Route 11 PO(16'-5½")
221	12'-0"		204.30	2.6350		16'-5½"	0.108010		
						19'-7½"		2.118	
221	12'-0"			6		9'-0"	120	26.264	Flow (q) from Route 11 PO(16'-5½")
212	12'-0"		204.30	6.3570		9'-0"	0.001482	0.013	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
212	12'-0		128.77	6		10'-0	120	26.278	Flow (q) from Route 7
206	12'-0		333.08	6.3570		10'-0	0.003660	0.037	
206	12'-0		54.17	6	(See Notes)	18'-3	120	26.314	Flow (q) from Route 14 2EE(8'-9½)
204	11'-5		387.25	6.3570		17'-7	0.004837	0.253	
						35'-10½		0.173	
204	11'-5			6	(See Notes)	135'-10	120	26.740	E(17'-7)
200	11'-5		371.65	6.3570		17'-7	0.004483	0.000	
						153'-5½		0.688	
200	11'-5		15.60	6	(See Notes)	30'-1	120	27.428	Flow (q) from Route 16 3E(17'-7), f(-0.000), f(-3.000), CV(17'-2½), BV(17'-7), PO(37'-8½)
8	2'-6½		387.25	6.3570		125'-4½	0.004837	3.849	
						155'-5½		3.752	
8	2'-6½			6	(See Notes)	21'-0½	120	35.030	E(17'-7)
7	-8'-9½		387.25	6.3570		17'-7	0.004837	4.915	
						38'-7½		0.187	
7	-8'-9½			6	(See Notes)	86'-3½	140	40.132	3E(23'-1½)
6	-15'-0		387.25	6.3400		69'-4	0.003685	2.688	
						155'-7½		0.573	
6	-15'-0			6	(See Notes)	4'-1½	140	43.393	BFP(-1.810)
3	-15'-0		387.25	6.3400		4'-1½	0.003685	1.983	
3	-15'-0			6	(See Notes)	11'-2½	140	45.376	PIV(-2.000)
2	-15'-0		387.25	6.3400		11'-2½	0.003685	2.041	
2	-15'-0			6	(See Notes)	21'-7	140	47.417	E(23'-1½), EE(11'-6½), S
1	-15'-0		387.25	6.3400		34'-8	0.003685		
						56'-3		0.207	
			250.00					47.625	Hose Allowance At Source
1			637.25						Total(Pt) Route 1
2613	8'-7½	5.6	26.16	1	(See Notes)	1'-0	120	21.824	••••• Route 2 ••••• Sprinkler, E(2'-0), fd
						2'-0	0.213869	-1.462	
222	12'-0		26.16	1.0490		3'-0		0.642	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
	Node 2		Elev 2 (Foot)	Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)		Elev(Pe)
Total (Foot)		Friction(Pf)								
222	12'-0			1½	(See Notes)	1'-11½	120	21.004		PO(8'-0)
218	12'-0		26.16	1.6100		8'-0	0.026551		0.265	
						9'-11½				
								21.269	Total(Pt) Route 2	
2612	8'-7½	5.6	26.70	1	(See Notes)	1'-0	120	22.733	..... Route 3 ..... Sprinkler, E(2'-0), fd	
224	12'-0		26.70	1.0490		2'-0	0.222096			-1.462
						3'-0				0.666
224	12'-0			1½	(See Notes)	2'-9½	120	21.938	PO(8'-0)	
216	12'-0		26.70	1.6100		8'-0	0.027572			0.298
						10'-9½				
								22.236	Total(Pt) Route 3	
2610	13'-9½	5.6	24.45	1	(See Notes)	1'-9½	120	19.063	..... Route 4 ..... Sprinkler, PO(5'-0)	
219	12'-0		24.45	1.0490		5'-0	0.188712			0.770
						6'-9½				1.279
								21.112	Total(Pt) Route 4	
2608	13'-9½	5.6	24.59	1	(See Notes)	1'-9½	120	19.286	..... Route 5 ..... Sprinkler, PO(5'-0)	
217	12'-0		24.59	1.0490		5'-0	0.190758			0.770
						6'-9½				1.293
								21.349	Total(Pt) Route 5	
2607	13'-9½	5.6	24.92	1	(See Notes)	1'-9½	120	19.801	..... Route 6 ..... Sprinkler, PO(5'-0)	
223	12'-0		24.92	1.0490		5'-0	0.195461			0.770
						6'-9½				1.324
								21.895	Total(Pt) Route 6	
2606	13'-9½	5.6	25.42	1	(See Notes)	1'-9½	120	20.599	..... Route 7 ..... Sprinkler, PO(5'-0)	
213	12'-0		25.42	1.0490		5'-0	0.202734			0.770
						6'-9½				1.374
213	12'-0			2		8'-0	120	22.742	Flow (q) from Route 8	
211	12'-0		25.42	2.1570		8'-0	0.006057			0.049
						8'-0				
211	12'-0		25.45	2		8'-0	120	22.791	Flow (q) from Route 8	
210	12'-0		50.87	2.1570		8'-0	0.021864			0.175

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	
							Friction(Pf)		
210	12'-0		25.55	2	(See Notes)	7'-2½	120	22.966	
209	12'-0		76.41	2.1570		9'-10	0.046416	0.000	
						17'-0½		0.791	
209	12'-0		26.00	2		8'-0	120	23.757	Flow (q) from Route 12
208	12'-0		102.41	2.1570		8'-0	0.079791	0.638	
208	12'-0		26.36	2	(See Notes)	3'-1½	120	24.395	Flow (q) from Route 13 PO(12'-3½)
212	12'-0		128.77	2.1570		12'-3½	0.121890		
						15'-5½		1.882	
								26.278	Total(Pt) Route 7
2605	13'-9	5.6	25.45	1	(See Notes)	1'-9	120	20.657	..... Route 8 ..... Sprinkler, PO(5'-0)
211	12'-0		25.45	1.0490		5'-0	0.203264	0.761	
						6'-9		1.373	
								22.791	Total(Pt) Route 8
2604	13'-9½	5.6	25.55	1	(See Notes)	1'-9½	120	20.809	..... Route 9 ..... Sprinkler, PO(5'-0)
210	12'-0		25.55	1.0490		5'-0	0.204649	0.770	
						6'-9½		1.387	
								22.966	Total(Pt) Route 9
2609	13'-9½	5.6	25.62	1	(See Notes)	1'-9½	120	20.925	..... Route 10 ..... Sprinkler, PO(5'-0)
220	12'-0		25.62	1.0490		5'-0	0.205704	0.770	
						6'-9½		1.394	
								23.089	Total(Pt) Route 10
2611	13'-9½	5.6	25.86	1	(See Notes)	2'-9½	120	21.329	..... Route 11 ..... Sprinkler, E(2'-0), PO(5'-0)
215	12'-0		25.86	1.0490		7'-0	0.209375	0.770	
						9'-9½		2.047	
								24.146	Total(Pt) Route 11
2602	13'-9½	5.6	26.00	1	(See Notes)	1'-9½	120	21.554	..... Route 12 ..... Sprinkler, PO(5'-0)
209	12'-0		26.00	1.0490		5'-0	0.211418	0.770	
						6'-9½		1.433	
								23.757	Total(Pt) Route 12
2603	13'-9½	5.6	26.36	1	(See Notes)	1'-9½	120	22.156	..... Route 13 ..... Sprinkler, PO(5'-0)
208	12'-0		26.36	1.0490		5'-0	0.216869	0.770	
						6'-9½		1.470	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
								24.395	Total(Pt) Route 13
2600	13'-9½	5.6	27.07	1	(See Notes)	1'-9½	120	23.370	***** Route 14 ***** Sprinkler,  PO(5'-0)
205	12'-0		27.07	1.0490		5'-0	0.227842	0.770	
						6'-9½		1.544	
205	12'-0			2		8'-0	120	25.684	
207	12'-0		27.07	2.1570		8'-0	0.006807	0.054	
207	12'-0		27.10	2	(See Notes)	11'-1½	120	25.738	Flow (q) from Route 15  PO(12'-3½)
						12'-3½	0.024564		
206	12'-0		54.17	2.1570		23'-5½		0.576	
								26.314	Total(Pt) Route 14
2601	13'-9½	5.6	27.10	1	(See Notes)	1'-9½	120	23.421	***** Route 15 ***** Sprinkler,  PO(5'-0)
						5'-0	0.228304	0.770	
207	12'-0		27.10	1.0490		6'-9½		1.547	
								25.738	Total(Pt) Route 15
201	12'-2		15.60	3	(See Notes)	81'-7½	120	27.057	***** Route 16 ***** Flow (q) from Route 17  3E(9'-5), EE(4'-0½), 2Ee1(4'-0½), PO(20'-2)
						60'-5½	0.000328	0.325	
200	11'-5		15.60	3.2600		142'-1½		0.047	
								27.428	Total(Pt) Route 16
202	13'-2			2	(See Notes)	24'-8½	120	26.233	***** Route 17 *****   3E(6'-2)
						18'-5½	0.002455		
203	13'-2		15.60	2.1570		43'-2		0.106	
203	13'-2			2½	(See Notes)	173'-9½	120	26.339	3PO(16'-5½), 11E(8'-3)
						140'-0½	0.000926	0.427	
201	12'-2		15.60	2.6350		313'-10		0.291	
								27.057	Total(Pt) Route 17
204	11'-5			2½	(See Notes)	128'-2½	120	26.740	***** Route 18 ***** PO(16'-5½)  EE(4'-1½), 6E(8'-3), T(16'-5½), 3PO(16'-5½)
						135'-11	0.000926	-0.752	
202	13'-2		15.60	2.6350		264'-1½		0.245	
								26.233	Total(Pt) Route 18

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BalV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L21-R041-Plans

Calculation Date: 5/15/2023

## Design

Remote Area Number: 3  
Remote Area Location: Closely spaced heads @ Floor Opening  
Occupancy Classification: Light Hazard  
Commodity Classification: N/A

Density 0.10gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 1099ft<sup>2</sup>)  
Coverage per Sprinkler: 100ft<sup>2</sup>  
Type of sprinklers calculated: Upright, Pendent  
No. of sprinklers calculated: 22  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source


Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 508.62 @ 48.425 (Safety Margin = 11.913)  
Type of System: Wet  
Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

Notes:

Automatic peaking results Left: N/A Right: N/A

FPET NICET #106245 LEVEL IV,MSME




# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: 3

N<sup>1.85</sup>

Date: 5/15/2023

**Supply  
Summary Sheet  
Node: 1**







# Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	3400	28.32	10.00	5.6	25.579		
Sprinkler	3401	19.56	10.00	5.6	12.196		
Sprinkler	3402	19.31	10.00	5.6	11.884		
Sprinkler	3403	19.47	10.00	5.6	12.084		
Sprinkler	3404	16.93	10.00	5.6	9.141		
Sprinkler	3405	19.20	10.00	5.6	11.750		
Sprinkler	3406	19.19	14.82	5.6	11.739		
Sprinkler	3407	18.71	16.50	5.6	11.165		
Sprinkler	3408	18.98	16.50	5.6	11.486		
Sprinkler	3409	18.37	16.50	5.6	10.758		
Sprinkler	3410	18.27	10.00	5.6	10.646		
Sprinkler	3411	18.24	16.50	5.6	10.605		
Sprinkler	3412	17.14	15.00	5.6	9.372		
Sprinkler	3413	17.05	14.82	5.6	9.270		
⇒ Sprinkler	<b>3414</b>	<b>16.50</b>	<b>16.50</b>	<b>5.6</b>	<b>8.681</b>		
Sprinkler	3415	18.30	14.82	5.6	10.679		
Sprinkler	3416	16.31	15.00	5.6	8.479		
Sprinkler	3417	17.49	15.00	5.6	9.752		
Sprinkler	3418	17.65	15.00	5.6	9.931		
Sprinkler	3419	17.77	15.00	5.6	10.069		
Sprinkler	3420	17.85	15.00	5.6	10.156		
Sprinkler	3421	18.04	15.00	5.6	10.375		

⇒ Most Demanding Sprinkler Data

<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	64.000	20.000	1950.00	60.338	508.62	48.425

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-15'-0	Supply	48.425	408.62	
3400	13'-2½	Sprinkler	25.579	28.32	
3401	13'-4½	Sprinkler	12.196	19.56	
3402	13'-3½	Sprinkler	11.884	19.31	
3403	13'-4½	Sprinkler	12.084	19.47	
3404	13'-3	Sprinkler	9.141	16.93	
3405	13'-3½	Sprinkler	11.750	19.20	
3406	9'-11½	Sprinkler	11.739	19.19	
3407	13'-6½	Sprinkler	11.165	18.71	
3408	13'-6	Sprinkler	11.486	18.98	
3409	13'-6½	Sprinkler	10.758	18.37	
3410	12'-7½	Sprinkler	10.646	18.27	
3411	13'-6	Sprinkler	10.605	18.24	
3412	12'-10	Sprinkler	9.372	17.14	
3413	9'-11½	Sprinkler	9.270	17.05	
3414	13'-7½	Sprinkler	8.681	16.50	
3415	9'-11½	Sprinkler	10.679	18.30	
3416	12'-10	Sprinkler	8.479	16.31	
3417	13'-2	Sprinkler	9.752	17.49	

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
3418	13'-2	Sprinkler	9.931	17.65	
3419	13'-2	Sprinkler	10.069	17.77	
3420	13'-2	Sprinkler	10.156	17.85	
3421	13'-2	Sprinkler	10.375	18.04	
2	-15'-0		48.197		
3	-15'-0		46.151		
6	-15'-0		44.112		
7	-8'-9½		40.791		
8	2'-6½		35.669		
200	11'-5		27.989		
201	12'-2		23.854		
202	13'-2		14.279		
203	13'-2		10.936		
204	11'-5		27.751		
300	11'-5		27.833		
301	12'-9½		26.967		
302	11'-10½		18.661		
303	13'-4½		12.531		
304	12'-10		13.218		
305	11'-5		27.778		
307	12'-8½		12.198		
308	12'-8½		12.525		
309	12'-7½		11.240		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
310	12'-8½		11.768		
311	12'-7½		10.755		
312	12'-8½		11.595		
313	12'-2		14.954		
314	13'-2		10.821		
315	12'-10		9.442		
316	13'-2		9.822		
317	12'-8½		11.631		
318	13'-2		10.816		
319	11'-11½		9.812		
320	12'-2		13.430		
321	13'-2		10.818		
322	13'-2		10.831		
323	13'-2		10.867		
324	13'-2		11.111		
325	13'-2		11.090		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
3414	13'-7½	5.6	16.50	1	(See Notes)	3'-2½	120	8.681	••••• Route 1 ••••• Sprinkler, E(2'-0), T(5'-0)
316	13'-2		16.50	1.0490		7'-0	0.091164	0.208	
						10'-2½		0.933	
316	13'-2		33.45	1½	(See Notes)	3'-4½	120	9.822	Flow (q) from Route 2 PO(8'-0)
314	13'-2		49.95	1.6100		8'-0	0.087842		
						11'-4½		0.999	
314	13'-2		10.06	2½	(See Notes)	2'-0½	120	10.821	Flow (q) from Route 21 E(8'-3)
203	13'-2		60.01	2.6350		8'-3	0.011199		
						10'-3½		0.115	
203	13'-2			2	(See Notes)	9'-4	120	10.936	E(6'-2)
312	12'-8½		60.01	2.1570		6'-2	0.029684	0.199	
						15'-6		0.460	
312	12'-8½		18.24	2		3'-6½	120	11.595	Flow (q) from Route 3
310	12'-8½		78.25	2.1570			0.048498	0.000	
						3'-6½		0.172	
310	12'-8½		18.37	2		6'-0	120	11.768	Flow (q) from Route 4
307	12'-8½		96.62	2.1570			0.071637	0.000	
						6'-0		0.430	
307	12'-8½		18.71	2		3'-3½	120	12.198	Flow (q) from Route 8
308	12'-8½		115.33	2.1570			0.099398	0.000	
						3'-3½		0.327	
308	12'-8½		18.98	2	(See Notes)	2'-6	120	12.525	Flow (q) from Route 11 2E(6'-2)
202	13'-2		134.31	2.1570		12'-3½	0.131759	-0.199	
						14'-10		1.953	
202	13'-2			2½	(See Notes)	128'-2½	120	14.279	4PO(16'-5½), 5E(8'-3), T(16'-5½), EE(4'-1½)
204	11'-5		134.31	2.6350		127'-8	0.049708	0.752	
						255'-10½		12.719	
204	11'-5			6		40'-7½	120	27.751	
305	11'-5		134.31	6.3570			0.000682	0.000	
						40'-7½		0.028	
305	11'-5		77.52	6		34'-9½	120	27.778	Flow (q) from Route 18
300	11'-5		211.83	6.3570			0.001585	0.000	
						34'-9½		0.055	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
300	11'-5		28.32	6	(See Notes)	60'-4½	120	27.833	Flow (q) from Route 20 E(17'-7)
200	11'-5		240.15	6.3570		17'-7	0.001999		
						78'-0		0.156	
200	11'-5		168.47	6	(See Notes)	30'-1	120	27.989	Flow (q) from Route 5 3E(17'-7), f(-0.000), f(-3.000), CV(17'-2½), BV(17'-7), PO(37'-8½)
8	2'-6½		408.62	6.3570		125'-4½	0.005343	3.849	
						155'-5½		3.830	
8	2'-6½			6	(See Notes)	21'-0½	120	35.669	E(17'-7)
7	-8'-9½		408.62	6.3570		17'-7	0.005343	4.915	
						38'-7½		0.206	
7	-8'-9½			6	(See Notes)	86'-3½	140	40.791	3E(23'-1½)
6	-15'-0		408.62	6.3400		69'-4	0.004070	2.688	
						155'-7½		0.633	
6	-15'-0			6	(See Notes)	4'-1½	140	44.112	BFP(-1.810)
3	-15'-0		408.62	6.3400		4'-1½	0.004070	2.039	
3	-15'-0			6	(See Notes)	11'-2½	140	46.151	PIV(-2.000)
2	-15'-0		408.62	6.3400		11'-2½	0.004070	2.046	
2	-15'-0			6	(See Notes)	21'-7	140	48.197	E(23'-1½), EE(11'-6½), S
1	-15'-0		408.62	6.3400		34'-8	0.004070		
						56'-3		0.229	
			100.00					48.425	Hose Allowance At Source
1			508.62						Total(Pt) Route 1
3416	12'-10	5.6	16.31	1	(See Notes)	5'-9½	120	8.479	..... Route 2 ..... Sprinkler, T(5'-0)
315	12'-10		16.31	1.0490		5'-0	0.089195	0.963	
						10'-9½			
315	12'-10		17.14	1½	(See Notes)	4'-6½	120	9.442	Flow (q) from Route 6 2E(4'-0)
316	13'-2		33.45	1.6100		8'-0	0.041836	-0.145	
						12'-6½		0.524	
								9.822	Total(Pt) Route 2

Pipe Information										
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
3411	13'-6	5.6	18.24	1	(See Notes)	0'-10	120	10.605		
312	12'-8½		18.24	1.0490		5'-0	0.109707	0.352		
						5'-10		0.638		
								11.595	Total(Pt) Route 3	
3409	13'-6½	5.6	18.37	1	(See Notes)	0'-10	120	10.758	***** Route 4 ***** Sprinkler, PO(5'-0)	
310	12'-8½		18.37	1.0490		5'-0	0.111166	0.361		
						5'-10		0.648		
								11.768	Total(Pt) Route 4	
3404	13'-3	5.6	16.93	1	(See Notes)	7'-0	120	9.141	***** Route 5 ***** Sprinkler, E(2'-0), PO(5'-0)	
311	12'-7½		16.93	1.0490		7'-0	0.095614	0.277		
						14'-0		1.338		
311	12'-7½		18.27	1½	(See Notes)	2'-6½	120	10.755	Flow (q) from Route 15 PO(8'-0)	
309	12'-7½		35.20	1.6100		8'-0	0.045979	-0.000		
						10'-6½		0.485		
309	12'-7½		19.19	1½	(See Notes)	14'-2	120	11.240	Flow (q) from Route 17 2PO(8'-0), E(4'-0)	
313	12'-2		54.39	1.6100		20'-0	0.102826	0.199		
						34'-2		3.514		
313	12'-2		114.08	2½	(See Notes)	68'-3½	120	14.954	Flow (q) from Route 7 6E(8'-3)	
201	12'-2		168.47	2.6350		49'-5	0.075597			
						117'-9		8.900		
201	12'-2			3	(See Notes)	81'-7½	120	23.854	3E(9'-5), EE(4'-0½), 2Ee1(4'-0½), PO(20'-2)	
200	11'-5		168.47	3.2600		60'-5½	0.026813	0.325		
						142'-1½		3.810		
								27.989	Total(Pt) Route 5	
3412	12'-10	5.6	17.14	1¼	(See Notes)	2'-9	120	9.372	***** Route 6 ***** Sprinkler	
315	12'-10		17.14	1.3800			0.025736			
						2'-9		0.070		
								9.442	Total(Pt) Route 6	
3413	9'-11½	5.6	17.05	1	(See Notes)	9'-6½	120	9.270	***** Route 7 ***** Sprinkler, T(5'-0), fd	
319	11'-11½		17.05	1.0490		5'-0	0.096870	-0.867		
						14'-6½		1.409		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
319	11'-11½		18.30	1	(See Notes)	0'-9½	120	9.812	Flow (q) from Route 16 PO(5'-0)
317	12'-8½		35.35	1.0490		5'-0	0.373256	-0.338	
						5'-9½		2.157	
317	12'-8½			1½	(See Notes)	13'-7½	120	11.631	2PO(8'-0), E(4'-0)
320	12'-2		35.35	1.6100		20'-0	0.046338	0.242	
						33'-7½		1.557	
320	12'-2		78.73	2½	(See Notes)	24'-11½	120	13.430	Flow (q) from Route 9 2E(8'-3)
313	12'-2		114.08	2.6350		16'-5½	0.036752	-0.000	
						41'-5½		1.523	
								14.954	Total(Pt) Route 7
3407	13'-6½	5.6	18.71	1	(See Notes)	0'-10	120	11.165	..... Route 8 ..... Sprinkler, PO(5'-0)
307	12'-8½		18.71	1.0490		5'-0	0.115053	0.361	
						5'-10		0.671	
								12.198	Total(Pt) Route 8
3417	13'-2	5.6	17.49	1	(See Notes)	5'-6	120	9.752	..... Route 9 ..... Sprinkler, PO(5'-0)
318	13'-2		17.49	1.0490		5'-0	0.101514		
						10'-6		1.065	
318	13'-2			2½		5'-8½	120	10.816	
321	13'-2		7.43	2.6350		5'-8½	0.000235	0.001	
321	13'-2		17.65	2½		6'-0½	120	10.818	Flow (q) from Route 10
322	13'-2		25.07	2.6350		6'-0½	0.002229	0.013	
322	13'-2		17.77	2½		5'-11½	120	10.831	Flow (q) from Route 12
323	13'-2		42.84	2.6350		5'-11½	0.006004	0.036	
323	13'-2		17.85	2½	(See Notes)	4'-10½	120	10.867	Flow (q) from Route 13 PO(16'-5½)
324	13'-2		60.69	2.6350		16'-5½	0.011435	0.244	
						21'-4			
324	13'-2		18.04	2½	(See Notes)	44'-6½	120	11.111	Flow (q) from Route 14 3E(8'-3), 2PO(16'-5½)
320	12'-2		78.73	2.6350		57'-8	0.018505	0.427	
						102'-2½		1.892	
								13.430	Total(Pt) Route 9



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
3418	13'-2	5.6	17.65	1	(See Notes)	3'-7	120	9.931		
321	13'-2		17.65	1.0490		5'-0	0.103236			
						8'-7		0.887		
								10.818	Total(Pt) Route 10	
3408	13'-6	5.6	18.98	1	(See Notes)	0'-10	120	11.486	***** Route 11 ***** Sprinkler, PO(5'-0)	
308	12'-8½		18.98	1.0490		5'-0	0.118112	0.352		
						5'-10		0.687		
								12.525		Total(Pt) Route 11
3419	13'-2	5.6	17.77	1	(See Notes)	2'-3½	120	10.069	***** Route 12 ***** Sprinkler, PO(5'-0)	
322	13'-2		17.77	1.0490		5'-0	0.104569			
						7'-3½		0.762		
								10.831		Total(Pt) Route 12
3420	13'-2	5.6	17.85	1	(See Notes)	1'-9	120	10.156	***** Route 13 ***** Sprinkler, PO(5'-0)	
323	13'-2		17.85	1.0490		5'-0	0.105396			
						6'-9		0.712		
								10.867		Total(Pt) Route 13
3421	13'-2	5.6	18.04	1	(See Notes)	1'-8	120	10.375	***** Route 14 ***** Sprinkler, PO(5'-0)	
325	13'-2		18.04	1.0490		5'-0	0.107502			
						6'-8		0.715		
325	13'-2			2½	(See Notes)	1'-1½	120	11.090		PO(16'-5½)
324	13'-2		18.04	2.6350		16'-5½	0.001212			
						17'-7		0.021		
								11.111	Total(Pt) Route 14	
3410	12'-7½	5.6	18.27	1½	(See Notes)	8'-0½	120	10.646	***** Route 15 ***** Sprinkler	
311	12'-7½		18.27	1.6100			0.013667	-0.000		
						8'-0½		0.110		
								10.755		Total(Pt) Route 15
3415	9'-11½	5.6	18.30	1	(See Notes)	0'-0	120	10.679	***** Route 16 ***** Sprinkler, , fd	
319	11'-11½		18.30	1.0490			0.110411	-0.867		
						0'-0		0.000		
								9.812		Total(Pt) Route 16

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
3406	9'-11½	5.6	19.19	1	(See Notes)	0'-6	120	11.739	***** Route 17 ***** Sprinkler, PO(5'-0), fd
309	12'-7½		19.19	1.0490		5'-0	0.120512	-1.163	
						5'-6		0.664	
								11.240	Total(Pt) Route 17
3405	13'-3½	5.6	19.20	1½	(See Notes)	9'-0	120	11.750	***** Route 18 ***** Sprinkler
3402	13'-3½		19.20	1.6100		9'-0	0.014974	0.135	
3402	13'-3½	5.6	19.31	1½	(See Notes)	12'-11		120	11.884
304	12'-10		38.50	1.6100		8'-0	0.054266	0.199	
						20'-11		1.135	
304	12'-10		39.02	1½	(See Notes)	13'-4½	120	13.218	Flow (q) from Route 19 3E(4'-0)
302	11'-10½		77.52	1.6100		12'-0	0.198092	0.415	
						25'-4½		5.028	
302	11'-10½			2	(See Notes)	87'-0	120	18.661	9E(5'-0), 2PO(10'-0)
305	11'-5		77.52	2.0670		65'-0	0.058668	0.199	
						152'-0		8.918	
								27.778	Total(Pt) Route 18
3403	13'-4½	5.6	19.47	1½	(See Notes)	9'-0	120	12.084	***** Route 19 ***** Sprinkler
3401	13'-4½		19.47	1.6820		9'-0	0.012419	0.112	
3401	13'-4½	5.6	19.56	1½	(See Notes)	2'-6		120	12.196
303	13'-4½		39.02	1.6820		4'-11½	0.044960	0.335	
						7'-5½			
303	13'-4½			1½	(See Notes)	0'-0	120	12.531	PO(8'-0)
304	12'-10		39.02	1.6100		8'-0	0.055636	0.242	
						8'-0		0.445	
								13.218	Total(Pt) Route 19
3400	13'-2½	5.6	28.32	1½	(See Notes)	11'-7½	120	25.579	***** Route 20 ***** Sprinkler, 5E(4'-0), PO(8'-0)
301	12'-9½		28.32	1.6100		28'-0	0.030750	0.169	
						39'-7½		1.219	
301	12'-9½			2½	(See Notes)	54'-2½	120	26.967	3E(8'-3), PO(16'-5½)
300	11'-5		28.32	2.6350		41'-2	0.002792	0.600	
						95'-4½		0.266	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes  Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
								27.833		
318	13'-2		7.43	2½		11'-4	120	10.816		••••• Route 21 ••••• Flow (q) from Route 9
314	13'-2		10.06	2.6350		11'-4	0.000411	0.005		
								10.821	Total(Pt) Route 21	

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L21-R041-Plans

Calculation Date: 5/15/2023

## Design

Remote Area Number: 4  
Remote Area Location: Classroom 102/102  
Occupancy Classification: Light Hazard  
Commodity Classification: N/A

Density: 0.10gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 1045ft<sup>2</sup>)  
Coverage per Sprinkler: 130ft<sup>2</sup>  
Type of sprinklers calculated: Upright  
No. of sprinklers calculated: 12  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source


Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 290.92 @ 37.798 (Safety Margin = 24.899)  
Type of System: Wet  
Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

Notes:

Automatic peaking results Left: N/A Right: N/A

FPET NICET #106245 LEVEL IV,<sup>MSME</sup>




# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: 4

N<sup>1.85</sup>

Date: 5/15/2023

**Supply  
Summary Sheet  
Node: 1**





# Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	4200	16.53	13.00	5.6	8.711		
Sprinkler	4201	17.24	13.00	5.6	9.473		
Sprinkler	4202	17.15	13.00	5.6	9.381		
Sprinkler	4203	16.43	13.00	5.6	8.605		
Sprinkler	4204	15.82	13.00	5.6	7.976		
Sprinkler	4205	17.15	13.00	5.6	9.382		
Sprinkler	4206	15.00	13.00	5.6	7.176		
Sprinkler	4207	15.60	13.00	5.6	7.757		
Sprinkler	4208	15.36	13.00	5.6	7.523		
Sprinkler	4209	14.99	13.00	5.6	7.163		
Sprinkler	4210	14.84	13.00	5.6	7.023		
<b>⇒ Sprinkler</b>	<b>4211</b>	<b>14.82</b>	<b>13.00</b>	<b>5.6</b>	<b>7.000</b>		

⇒ Most Demanding Sprinkler Data

<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	64.000	20.000	1950.00	62.697	290.92	37.798

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-15'-0	Supply	37.798	190.92	
4200	13'-8½	Sprinkler	8.711	16.53	
4201	13'-8½	Sprinkler	9.473	17.24	
4202	13'-8½	Sprinkler	9.381	17.15	
4203	13'-8½	Sprinkler	8.605	16.43	
4204	13'-8	Sprinkler	7.976	15.82	
4205	13'-8	Sprinkler	9.382	17.15	
4206	13'-8½	Sprinkler	7.176	15.00	
4207	13'-8½	Sprinkler	7.757	15.60	
4208	13'-8½	Sprinkler	7.523	15.36	
4209	13'-8	Sprinkler	7.163	14.99	
4210	13'-6	Sprinkler	7.023	14.84	
4211	13'-6	Sprinkler	7.000	14.82	
2	-15'-0		37.742		
3	-15'-0		35.731		
6	-15'-0		34.137		
7	-8'-9½		31.294		
8	2'-6½		26.329		
200	11'-5		19.276		



Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
201	12'-2		17.119		
202	13'-2		13.884		
203	13'-2		11.826		
204	11'-5		19.238		
400	12'-8½		9.682		
401	12'-2		10.752		
402	12'-8½		9.570		
403	12'-8½		10.511		
404	12'-8½		10.397		
405	12'-2		10.535		
406	12'-8½		8.894		
407	12'-8½		10.395		
408	12'-8½		10.379		
409	12'-8½		8.775		
410	12'-2		10.253		
411	12'-8½		9.078		
412	12'-8½		8.058		
413	12'-8½		8.459		
414	12'-8½		8.673		
415	12'-2		10.165		
416	12'-8½		8.134		
417	12'-8½		8.033		
418	12'-8½		8.109		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
4211	13'-6	5.6	14.82	1	(See Notes)	3'-3	120	7.000	••••• Route 1 ••••• Sprinkler, E(2'-0), PO(5'-0)
418	12'-8½		14.82	1.0490		7'-0	0.074703	0.343	
						10'-3		0.766	
418	12'-8½		14.99	1½	(See Notes)	2'-4½	120	8.109	Flow (q) from Route 3 PO(8'-0)
413	12'-8½		29.80	1.6100		8'-0	0.033793		
						10'-4½		0.351	
413	12'-8½		29.84	1½	(See Notes)	0'-0	120	8.459	Flow (q) from Route 2 E(4'-0), PO(8'-0)
415	12'-2		59.65	1.6100		12'-0	0.121966	0.242	
						12'-0		1.464	
415	12'-2			2½		8'-0	120	10.165	
410	12'-2		59.65	2.6350			0.011073		
						8'-0		0.089	
410	12'-2		46.77	2½		8'-8½	120	10.253	Flow (q) from Route 5
405	12'-2		106.42	2.6350			0.032318		
						8'-8½		0.282	
405	12'-2			2½		11'-3½	120	10.535	
401	12'-2		80.44	2.6350			0.019255		
						11'-3½		0.217	
401	12'-2		32.96	2½	(See Notes)	109'-3½	120	10.752	Flow (q) from Route 8 8E(8'-3)
201	12'-2		113.39	2.6350		65'-11	0.036344		
						175'-2		6.367	
201	12'-2			3	(See Notes)	81'-7½	120	17.119	3E(9'-5), EE(4'-0½), 2Ee1(4'-0½), PO(20'-2)
200	11'-5		113.39	3.2600		60'-5½	0.012890	0.325	
						142'-1½		1.832	
200	11'-5		77.52	6	(See Notes)	30'-1	120	19.276	Flow (q) from Route 10 3E(17'-7), f(-0.000), f(-3.000), CV(17'-2½), BV(17'-7), PO(37'-8½)
8	2'-6½		190.92	6.3570		125'-4½	0.001307	3.849	
						155'-5½		3.203	
8	2'-6½			6	(See Notes)	21'-0½	120	26.329	E(17'-7)
7	-8'-9½		190.92	6.3570		17'-7	0.001307	4.915	
						38'-7½		0.050	
7	-8'-9½			6	(See Notes)	86'-3½	140	31.294	3E(23'-1½)
6	-15'-0		190.92	6.3400		69'-4	0.000996	2.688	
						155'-7½		0.155	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
6	-15'-0			6	(See Notes)	4'-1½	140	34.137	BFP(-1.810)
3	-15'-0		190.92	6.3400		4'-1½	0.000996	1.594	
3	-15'-0			6	(See Notes)	11'-2½	140	35.731	PIV(-2.000)
2	-15'-0		190.92	6.3400		11'-2½	0.000996	2.011	
2	-15'-0			6	(See Notes)	21'-7	140	37.742	E(23'-1½), EE(11'-6½), S
1	-15'-0		190.92	6.3400		34'-8	0.000996		
						56'-3		0.056	
			100.00					37.798	Hose Allowance At Source
1			290.92						Total(Pt) Route 1
4210	13'-6	5.6	14.84	1	(See Notes)	3'-3	120	7.023	••••• Route 2 ••••• Sprinkler, E(2'-0), PO(5'-0)
416	12'-8½		14.84	1.0490		7'-0	0.074927	0.343	
						10'-3		0.768	
416	12'-8½		15.00	1½	(See Notes)	1'-7½	120	8.134	Flow (q) from Route 4 PO(8'-0)
413	12'-8½		29.84	1.6100		8'-0	0.033872		
						9'-7½		0.326	
								8.459	Total(Pt) Route 2
4209	13'-8	5.6	14.99	1	(See Notes)	0'-11½	120	7.163	••••• Route 3 ••••• Sprinkler, PO(5'-0)
417	12'-8½		14.99	1.0490		5'-0	0.076313	0.415	
						5'-11½		0.455	
417	12'-8½			1½		8'-0	120	8.033	
418	12'-8½		14.99	1.6100		8'-0	0.009474	0.076	
								8.109	Total(Pt) Route 3
4206	13'-8½	5.6	15.00	1	(See Notes)	0'-11½	120	7.176	••••• Route 4 ••••• Sprinkler, PO(5'-0)
412	12'-8½		15.00	1.0490		5'-0	0.076444	0.424	
						5'-11½		0.457	
412	12'-8½			1½		8'-0	120	8.058	
416	12'-8½		15.00	1.6100		8'-0	0.009490	0.076	
								8.134	Total(Pt) Route 4

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
4208	13'-8½	5.6	15.36	1	(See Notes)	3'-4½	120	7.523	***** Route 5 ***** Sprinkler, E(2'-0), PO(5'-0)
409	12'-8½		15.36	1.0490		7'-0	0.079856	0.424	
						10'-4½		0.827	
409	12'-8½		15.60	1½	(See Notes)	0'-4½	120	8.775	Flow (q) from Route 6 PO(8'-0)
411	12'-8½		30.96	1.6100		8'-0	0.036251		
						8'-4½		0.303	
411	12'-8½		15.82	1½	(See Notes)	0'-0	120	9.078	Flow (q) from Route 7 E(4'-0), PO(8'-0)
410	12'-2		46.77	1.6100		12'-0	0.077786	0.242	
						12'-0		0.933	
								10.253	Total(Pt) Route 5
4207	13'-8½	5.6	15.60	1	(See Notes)	0'-11½	120	7.757	***** Route 6 ***** Sprinkler, PO(5'-0)
414	12'-8½		15.60	1.0490		5'-0	0.082151	0.424	
						5'-11½		0.491	
414	12'-8½			1½	(See Notes)	10'-0	120	8.673	
409	12'-8½		15.60	1.6100		10'-0	0.010199	0.102	
								8.775	Total(Pt) Route 6
4204	13'-8	5.6	15.82	1	(See Notes)	0'-11½	120	7.976	***** Route 7 ***** Sprinkler, PO(5'-0)
406	12'-8½		15.82	1.0490		5'-0	0.084293	0.415	
						5'-11½		0.502	
406	12'-8½			1½	(See Notes)	9'-7½	120	8.894	PO(8'-0)
411	12'-8½		15.82	1.6100		8'-0	0.010465		
						17'-7½		0.185	
								9.078	Total(Pt) Route 7
4203	13'-8½	5.6	16.43	1	(See Notes)	0'-11½	120	8.605	***** Route 8 ***** Sprinkler, PO(5'-0)
402	12'-8½		16.43	1.0490		5'-0	0.090421	0.424	
						5'-11½		0.541	
402	12'-8½			1½	(See Notes)	10'-0	120	9.570	
400	12'-8½		16.43	1.6100		10'-0	0.011225	0.112	
400	12'-8½		16.53	1½	(See Notes)	0'-4½	120	9.682	Flow (q) from Route 9 2PO(8'-0), E(4'-0)
401	12'-2		32.96	1.6100		20'-0	0.040698	0.242	
						20'-4½		0.829	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
								10.752	Total(Pt) Route 8
4200	13'-8½	5.6	16.53	1	(See Notes)	0'-11½	120	8.711	***** Route 9 ***** Sprinkler, PO(5'-0)
400	12'-8½		16.53	1.0490		5'-0	0.091452	0.424	
						5'-11½		0.547	
								9.682	Total(Pt) Route 9
4202	13'-8½	5.6	17.15	1	(See Notes)	1'-0	120	9.381	***** Route 10 ***** Sprinkler, PO(5'-0)
407	12'-8½		17.15	1.0490		5'-0	0.097938	0.428	
						6'-0		0.586	
407	12'-8½		17.15	2½		0'-5½	120	10.395	Flow (q) from Route 11
404	12'-8½		34.30	2.6350		0'-5½	0.003980	0.000	
								0.002	
404	12'-8½		25.98	2½		9'-6½	120	10.397	Flow (q) from Route 13
403	12'-8½		60.29	2.6350		9'-6½	0.011295	0.005	
								0.108	
403	12'-8½		17.24	2½	(See Notes)	42'-9½	120	10.511	Flow (q) from Route 12 3E(8'-3), PO(16'-5½)
203	13'-2		77.52	2.6350		41'-2	0.017985	-0.195	
						83'-11½		1.510	
203	13'-2			2	(See Notes)	24'-8½	120	11.826	3E(6'-2)
202	13'-2		77.52	2.1570		18'-5½	0.047671	-0.000	
						43'-2		2.058	
202	13'-2			2½	(See Notes)	128'-2½	120	13.884	4PO(16'-5½), 5E(8'-3), T(16'-5½), EE(4'-1½)
204	11'-5		77.52	2.6350		127'-8	0.017985	0.752	
						255'-10½		4.602	
204	11'-5			6	(See Notes)	135'-10	120	19.238	E(17'-7)
200	11'-5		77.52	6.3570		17'-7	0.000247	0.000	
						153'-5½		0.038	
								19.276	Total(Pt) Route 10
4205	13'-8	5.6	17.15	1	(See Notes)	0'-11½	120	9.382	***** Route 11 ***** Sprinkler, PO(5'-0)
408	12'-8½		17.15	1.0490		5'-0	0.097949	0.414	
						5'-11½		0.583	
408	12'-8½			2½		10'-0	120	10.379	
407	12'-8½		17.15	2.6350		10'-0	0.001104	0.006	
								0.011	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes  Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
							10.395	Total(Pt) Route 11	
4201	13'-8½	5.6	17.24	1	(See Notes)	1'-0	120	9.473	
403	12'-8½		17.24	1.0490		5'-0	0.098829	0.442	
								6'-0	0.595
								10.511	Total(Pt) Route 12
405	12'-2			2½	(See Notes)	0'-11	120	10.535	••••• Route 13 ••••• PO(16'-5½)  E(8'-3), PO(16'-5½)
404	12'-8½		25.98	2.6350		41'-2	0.002380	-0.238	
								42'-1	
								10.397	Total(Pt) Route 13

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L21-R041-Plans

Calculation Date: 5/15/2023

## Design

Remote Area Number: 5  
Remote Area Location: LOBBY  
Occupancy Classification: Light Hazard  
Commodity Classification: N/A

Density: 0.10gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 1335ft<sup>2</sup>)  
Coverage per Sprinkler: 120ft<sup>2</sup>  
Type of sprinklers calculated: Upright, Pendent  
No. of sprinklers calculated: 14  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source


Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 314.93 @ 29.635 (Safety Margin = 32.857)  
Type of System: WET  
Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

Notes:

Automatic peaking results Left: N/A Right: N/A

FPET NICET #106245 LEVEL IV,MSME






# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: 5

N<sup>1.85</sup>

Date: 5/15/2023

**Supply  
Summary Sheet  
Node: 1**





# Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	5600	15.69	12.00	5.6	7.853		
Sprinkler	5601	15.42	12.00	5.6	7.578		
Sprinkler	5602	15.64	12.00	5.6	7.801		
Sprinkler	5603	15.35	12.00	5.6	7.511		
Sprinkler	5604	15.63	12.00	5.6	7.795		
Sprinkler	5605	15.36	12.00	5.6	7.528		
Sprinkler	5606	15.36	12.00	5.6	7.521		
Sprinkler	5607	15.30	12.00	5.6	7.461		
Sprinkler	5608	15.02	12.00	5.6	7.192		
Sprinkler	5609	15.29	12.00	5.6	7.455		
Sprinkler	5610	14.93	12.00	5.6	7.111		
Sprinkler	5611	16.23	14.82	5.6	8.397		
➔ Sprinkler	<b>5612</b>	<b>14.82</b>	<b>12.00</b>	<b>5.6</b>	<b>7.000</b>		
Sprinkler	5613	14.89	12.00	5.6	7.073		

➔ Most Demanding Sprinkler Data

<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	64.000	20.000	1950.00	62.491	314.93	29.635

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-15'-0	Supply	29.635	214.93	
5600	13'-2½	Sprinkler	7.853	15.69	
5601	13'-2½	Sprinkler	7.578	15.42	
5602	13'-2½	Sprinkler	7.801	15.64	
5603	13'-2½	Sprinkler	7.511	15.35	
5604	13'-2½	Sprinkler	7.795	15.63	
5605	13'-2½	Sprinkler	7.528	15.36	
5606	13'-2½	Sprinkler	7.521	15.36	
5607	13'-2½	Sprinkler	7.461	15.30	
5608	12'-9½	Sprinkler	7.192	15.02	
5609	13'-2½	Sprinkler	7.455	15.29	
5610	12'-9½	Sprinkler	7.111	14.93	
5611	10'-0	Sprinkler	8.397	16.23	
5612	13'-2½	Sprinkler	7.000	14.82	
5613	13'-2½	Sprinkler	7.073	14.89	
2	-15'-0		29.565		
3	-15'-0		27.551		
6	-15'-0		25.922		
7	-8'-9½		23.041		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
8	2'-6½		18.063		
200	11'-5		10.961		
201	12'-2		9.570		
202	13'-2		9.791		
203	13'-2		9.618		
204	11'-5		10.931		
300	11'-5		10.932		
301	12'-9½		8.862		
500	11'-7		9.850		
501	11'-7		9.795		
502	11'-7		9.784		
503	12'-9½		7.673		
504	12'-9½		8.900		
505	13'-2½		7.059		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
5612	13'-2½	5.6	14.82	1½	(See Notes)	7'-11	120	7.000	..... Route 1 ..... Sprinkler
505	13'-2½		14.82	1.6820		7'-11	0.007495	0.059	
505	13'-2½			1½		1'-6	120	7.059	
5613	13'-2½		14.82	1.6100		1'-6	0.009274	0.000	
5613	13'-2½	5.6	14.89	1½	(See Notes)	20'-2½	120	7.073	Sprinkler, 5E(4'-0), PO(8'-0)
301	12'-9½		29.71	1.6100		28'-0	0.033595	0.170	
						48'-2½		1.619	
301	12'-9½			2½		12'-7	120	8.862	
504	12'-9½		29.71	2.6350		12'-7	0.003050	-0.000	
504	12'-9½		46.18	2½	(See Notes)	41'-7½	120	8.900	Flow (q) from Route 2 3E(8'-3), PO(16'-5½)
300	11'-5		75.89	2.6350		41'-2	0.017289	0.600	
						82'-9½		1.432	
300	11'-5		20.34	6	(See Notes)	60'-4½	120	10.932	Flow (q) from Route 7 E(17'-7)
200	11'-5		96.23	6.3570		17'-7	0.000368	0.029	
200	11'-5		118.70	6	(See Notes)	30'-1	120	10.961	Flow (q) from Route 3 3E(17'-7), f(-0.000), f(-3.000), CV(17'-2½), BV(17'-7), PO(37'-8½)
8	2'-6½		214.93	6.3570		125'-4½	0.001628	3.849	
						155'-5½		3.253	
8	2'-6½			6	(See Notes)	21'-0½	120	18.063	E(17'-7)
7	-8'-9½		214.93	6.3570		17'-7	0.001628	4.915	
						38'-7½		0.063	
7	-8'-9½			6	(See Notes)	86'-3½	140	23.041	3E(23'-1½)
6	-15'-0		214.93	6.3400		69'-4	0.001240	2.688	
						155'-7½		0.193	
6	-15'-0			6	(See Notes)	4'-1½	140	25.922	BFP(-1.810)
3	-15'-0		214.93	6.3400		4'-1½	0.001240	1.629	
3	-15'-0			6	(See Notes)	11'-2½	140	27.551	PIV(-2.000)
2	-15'-0		214.93	6.3400		11'-2½	0.001240	2.014	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
2	-15'-0			6	(See Notes)	21'-7	140	29.565	E(23'-1½), EE(11'-6½), S
1	-15'-0		214.93	6.3400		34'-8	0.001240		
						56'-3		0.070	
			100.00					29.635	Hose Allowance At Source
1			314.93						Total(Pt) Route 1
5610	12'-9½	5.6	14.93	1½	(See Notes)	10'-7½	120	7.111	..... Route 2 ..... Sprinkler
5608	12'-9½		14.93	1.6820		10'-7½	0.007605	0.081	
5608	12'-9½	5.6	15.02	1½	(See Notes)	12'-6	120	7.192	Sprinkler, E(4'-11½)
503	12'-9½		29.95	1.6820		4'-11½	0.027559	0.481	
503	12'-9½		16.23	1½	(See Notes)	10'-1	120	7.673	Flow (q) from Route 6 PO(9'-11)
504	12'-9½		46.18	1.6820		9'-11	0.061391	1.228	
						20'-0			
								8.900	Total(Pt) Route 2
5609	13'-2½	5.6	15.29	1½	(See Notes)	8'-4½	120	7.455	..... Route 3 ..... Sprinkler
5606	13'-2½		15.29	1.6820		8'-4½	0.007944	0.067	
5606	13'-2½	5.6	15.36	1½	(See Notes)	9'-6	120	7.521	Sprinkler
5604	13'-2½		30.65	1.6820		9'-6	0.028755	0.273	
5604	13'-2½	5.6	15.63	1½	(See Notes)	6'-2½	120	7.795	Sprinkler, E(4'-11½), PO(9'-11)
502	11'-7		46.28	1.6820		14'-10	0.061645	0.690	
						21'-1		1.299	
502	11'-7			3		9'-0	120	9.784	
501	11'-7		25.94	3.2600		9'-0	0.000842	0.004	
								0.008	
501	11'-7		46.30	3		10'-7½	120	9.795	Flow (q) from Route 4
500	11'-7		72.24	3.2600		10'-7½	0.005598	-0.004	
								0.060	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
500	11'-7		46.46	3	(See Notes)	35'-9½	120	9.850	Flow (q) from Route 5 2Ee1(4'-0½), E(9'-5), PO(20'-2)
200	11'-5		118.70	3.2600		37'-7½	0.014028	0.081	
						73'-5		1.030	
								10.961	Total(Pt) Route 3
5607	13'-2½	5.6	15.30	1½	(See Notes)	8'-4½	120	7.461	..... Route 4 ..... Sprinkler
5605	13'-2½		15.30	1.6820		8'-4½	0.007950	0.067	
5605	13'-2½	5.6	15.36	1½	(See Notes)	9'-6		120	7.528
5602	13'-2½		30.66	1.6820		9'-6	0.028778	0.274	
5602	13'-2½	5.6	15.64	1½	(See Notes)	6'-2½		120	7.801
						14'-10	0.061693	0.693	
501	11'-7		46.30	1.6820		21'-1		1.300	
								9.795	Total(Pt) Route 4
5603	13'-2½	5.6	15.35	1½	(See Notes)	8'-4½	120	7.511	..... Route 5 ..... Sprinkler
5601	13'-2½		15.35	1.6820		8'-4½	0.007999	0.067	
5601	13'-2½	5.6	15.42	1½	(See Notes)	9'-6		120	7.578
5600	13'-2½		30.76	1.6820		9'-6	0.028956	0.275	
5600	13'-2½	5.6	15.69	1½	(See Notes)	6'-2½		120	7.853
						14'-10	0.062075	0.690	
500	11'-7		46.46	1.6820		21'-0½		1.307	
								9.850	Total(Pt) Route 5
5611	10'-0	5.6	16.23	1	(See Notes)	0'-6½	120	8.397	..... Route 6 ..... Sprinkler, PO(5'-0), fd
						5'-0	0.088397	-1.214	
503	12'-9½		16.23	1.0490		5'-6½		0.490	
								7.673	Total(Pt) Route 6
203	13'-2			2	(See Notes)	24'-8½	120	9.618	..... Route 7 .....  3E(6'-2)
						18'-5½	0.004012	-0.000	
202	13'-2		20.34	2.1570		43'-2		0.173	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes  Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
202	13'-2			2½	(See Notes)	128'-2½	120	9.791		
204	11'-5		20.34	2.6350		127'-8	0.001514	0.752		
						255'-10½		0.387		
204	11'-5			6		75'-5½	120	10.931		
							0.000021	0.000		
300	11'-5		20.34	6.3570		75'-5½		0.002		
								10.932	Total(Pt) Route 7	
502	11'-7		25.94	3	(See Notes)	26'-2½	120	9.784	..... Route 8 ..... Flow (q) from Route 3  EE(4'-0½), 3E(9'-5)	
201	12'-2		20.34	3.2600		32'-3	0.000537	-0.245		
						58'-5½		0.031		
201	12'-2			2½	(See Notes)	173'-9½	120	9.570	11E(8'-3), 3PO(16'-5½)	
						140'-0½	0.001514	-0.427		
203	13'-2		20.34	2.6350		313'-10		0.475		
								9.618	Total(Pt) Route 8	



**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L22-R041-Plans

Calculation Date: 5/15/2023

## Design

Remote Area Number: 6  
Remote Area Location: General Bioogy Lab  
Occupancy Classification: Ordinary Group II  
Commodity Classification: N/A

Density: 0.20gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 960ft<sup>2</sup>)  
Coverage per Sprinkler: 110ft<sup>2</sup>  
Type of sprinklers calculated: Pendent  
No. of sprinklers calculated: 9  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 250.00 at Node: 1 Type: Allowance at Source


Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 501.26 @ 45.628 (Safety Margin = 14.807)  
Type of System: Wet  
Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

Notes:

Automatic peaking results Left: N/A Right: N/A

FPET NICET #106245 LEVEL IV,MSME




# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: 6

N<sup>1.85</sup>

Date: 5/15/2023

**Supply  
Summary Sheet  
Node: 1**





# Summary Of Outflowing Devices

Job Number: 22-3688

Report Description: Ordinary Group II (6)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	6400	29.98	26.00	8	14.041		
Sprinkler	6401	26.11	26.00	8	10.649		
Sprinkler	6402	26.32	26.00	8	10.825		
Sprinkler	6403	27.17	26.00	8	11.536		
Sprinkler	6404	31.26	26.00	8	15.273		
⇒ Sprinkler	<b>6405</b>	<b>26.00</b>	<b>26.00</b>	<b>8</b>	<b>10.563</b>		
Sprinkler	6406	26.21	26.00	8	10.737		
Sprinkler	6407	27.06	26.00	8	11.443		
Sprinkler	6408	31.14	26.00	8	15.152		

⇒ Most Demanding Sprinkler Data

<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	64.000	20.000	1950.00	60.435	501.26	45.628

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-10'-4	Supply	45.628	251.26	
6400	24'-8	Sprinkler	14.041	29.98	
6401	24'-8	Sprinkler	10.649	26.11	
6402	24'-8	Sprinkler	10.825	26.32	
6403	24'-8	Sprinkler	11.536	27.17	
6404	24'-0	Sprinkler	15.273	31.26	
6405	24'-8	Sprinkler	10.563	26.00	
6406	24'-8	Sprinkler	10.737	26.21	
6407	24'-8	Sprinkler	11.443	27.06	
6408	24'-0	Sprinkler	15.152	31.14	
2	-10'-4		45.535		
3	-10'-4		43.516		
6	-10'-4		41.827		
7	-4'-1½		38.882		
8	7'-2½		33.883		
600	26'-6		22.016		
601	26'-6		20.265		
602	26'-6		16.299		
603	26'-6		14.622		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
604	26'-6		15.072		
605	26'-6		10.920		
606	26'-6		11.112		
607	26'-6		11.888		
608	26'-6		14.628		
609	26'-6		14.189		
610	26'-6		10.825		
611	26'-6		11.016		
612	26'-6		11.786		
613	26'-6		14.505		
614	26'-6		14.069		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
6405	24'-8	8	26.00	1	(See Notes)	0'-0	120	10.563	***** Route 1 ***** Sprinkler, PO(5'-0), fd
610	26'-6		26.00	1.0490		5'-0	0.211435	-0.795	
						5'-0		1.057	
610	26'-6			1½		9'-0	120	10.825	Flow (q) from Route 3
611	26'-6		26.00	1.6820		9'-0	0.021212	0.191	
611	26'-6		26.21	1½		10'-0	120	11.016	
612	26'-6		52.21	1.6820		10'-0	0.077053	0.771	
612	26'-6		27.06	1½	(See Notes)	6'-5	120	11.786	Flow (q) from Route 5 PO(9'-11)
613	26'-6		79.28	1.6820		9'-11	0.166836		
						16'-3½		2.719	
613	26'-6		31.14	3		10'-0	120	14.505	Flow (q) from Route 8
608	26'-6		110.42	3.2600		10'-0	0.012272	0.123	
608	26'-6		79.60 + 31.26	3		10'-0	120	14.628	
604	26'-6		221.28	3.2600		10'-0	0.044405	0.444	Flow (q) from Route 2 and 9
604	26'-6		29.98	3		21'-10	120	15.072	Flow (q) from Route 7
602	26'-6		251.26	3.2600		21'-10	0.056170	1.227	
602	26'-6			3		117'-9½	120	16.299	
601	26'-6		190.54	3.2600		117'-9½	0.033672	3.967	
601	26'-6		60.72	3	(See Notes)	11'-0	120	20.265	Flow (q) from Route 10 PO(20'-2)
600	26'-6		251.26	3.2600		20'-2	0.056170		
						31'-2		1.751	
600	26'-6			6	(See Notes)	70'-4½	120	22.016	5E(17'-7), f(-0.000), f(-3.000), CV(17'-2½), BV(17'-7), PO(37'-8½)
8	7'-2½		251.26	6.3570		160'-6½	0.002173	8.365	
						230'-11½		3.502	
8	7'-2½			6	(See Notes)	21'-0½	120	33.883	E(17'-7)
7	-4'-1½		251.26	6.3570		17'-7	0.002173	4.915	
						38'-7½		0.084	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
7	-4'-1½			6	(See Notes)	86'-3½	140	38.882	3E(23'-1½)
6	-10'-4		251.26	6.3400		69'-4	0.001655	2.688	
						155'-7½		0.258	
6	-10'-4			6	(See Notes)	4'-1½	140	41.827	BFP(-1.654)
3	-10'-4		251.26	6.3400		4'-1½	0.001655	1.689	
3	-10'-4			6	(See Notes)	11'-2½	140	43.516	PIV(-2.000)
2	-10'-4		251.26	6.3400		11'-2½	0.001655	2.019	
2	-10'-4			6	(See Notes)	21'-7	140	45.535	E(23'-1½), EE(11'-6½), S
1	-10'-4		251.26	6.3400		34'-8	0.001655		
						56'-3		0.093	
			250.00					45.628	Hose Allowance At Source
1			501.26						Total(Pt) Route 1
6401	24'-8	8	26.11	1	(See Notes)	0'-0	120	10.649	••••• Route 2 ••••• Sprinkler, PO(5'-0), fd
605	26'-6		26.11	1.0490		5'-0	0.213041	-0.795	
						5'-0		1.065	
605	26'-6			1½		9'-0	120	10.920	
606	26'-6		26.11	1.6820		9'-0	0.021373	0.192	
606	26'-6		26.32	1½		10'-0	120	11.112	Flow (q) from Route 4
607	26'-6		52.43	1.6820		10'-0	0.077638	0.776	
607	26'-6		27.17	1½	(See Notes)	6'-5	120	11.888	Flow (q) from Route 6 PO(9'-11)
608	26'-6		79.60	1.6820		9'-11	0.168101		
						16'-3½		2.739	
								14.628	Total(Pt) Route 2
6406	24'-8	8	26.21	1	(See Notes)	0'-0	120	10.737	••••• Route 3 ••••• Sprinkler, PO(5'-0), fd
611	26'-6		26.21	1.0490		5'-0	0.214669	-0.795	
						5'-0		1.073	
								11.016	Total(Pt) Route 3



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
6402	24'-8	8	26.32	1	(See Notes)	0'-0	120	10.825		
606	26'-6		26.32	1.0490		5'-0	0.216298	-0.795		
						5'-0		1.081		
								11.112	Total(Pt) Route 4	
6407	24'-8	8	27.06	1	(See Notes)	0'-0	120	11.443	***** Route 5 ***** Sprinkler, PO(5'-0), fd	
612	26'-6		27.06	1.0490		5'-0	0.227684	-0.795		
						5'-0		1.138		
								11.786		Total(Pt) Route 5
6403	24'-8	8	27.17	1	(See Notes)	0'-0	120	11.536	***** Route 6 ***** Sprinkler, PO(5'-0), fd	
607	26'-6		27.17	1.0490		5'-0	0.229404	-0.795		
						5'-0		1.147		
								11.888		Total(Pt) Route 6
6400	24'-8	8	29.98	1	(See Notes)	0'-0	120	14.041	***** Route 7 ***** Sprinkler, PO(5'-0), fd	
603	26'-6		29.98	1.0490		5'-0	0.275133	-0.795		
						5'-0		1.376		
603	26'-6			1½	(See Notes)	6'-5	120	14.622		PO(9'-11)
604	26'-6		29.98	1.6820		9'-11	0.027602			
						16'-3½		0.450		
								15.072	Total(Pt) Route 7	
6408	24'-0	8	31.14	1	(See Notes)	0'-0	120	15.152	***** Route 8 ***** Sprinkler, , fd	
614	26'-6		31.14	1.0490		0'-0	0.295216	-1.084		
						0'-0		0.000		
614	26'-6			1½	(See Notes)	3'-11	120	14.069		PO(8'-0)
613	26'-6		31.14	1.6100		8'-0	0.036650			
						11'-11		0.436		
								14.505	Total(Pt) Route 8	
6404	24'-0	8	31.26	1	(See Notes)	0'-0	120	15.273	***** Route 9 ***** Sprinkler, , fd	
609	26'-6		31.26	1.0490		0'-0	0.297387	-1.084		
						0'-0		0.000		
609	26'-6			1½	(See Notes)	3'-10½	120	14.189		PO(8'-0)
608	26'-6		31.26	1.6100		8'-0	0.036920			
						11'-10½		0.439		
								14.628	Total(Pt) Route 9	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes  Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a <b>negative value</b> .
						Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
Total (Foot)	Friction(Pf)								
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)				
602	26'-6			2½	(See Notes)	231'-3½	120	16.299	***** Route 10 ***** PO(16'-5½) 6E(8'-3), 2T(16'-5½), PO(16'-5 ½)
601	26'-6		60.72	2.6350		115'-4	0.011444	-0.000	
						346'-7½		3.967	
								20.265	

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L22-R041-Plans

Calculation Date: 5/15/2023

## Design

Remote Area Number: 7  
Remote Area Location: Classroom 201/202  
Occupancy Classification: Light Hazard  
Commodity Classification: N/A

Density: 0.10gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 1032ft<sup>2</sup>)  
Coverage per Sprinkler: 196ft<sup>2</sup>  
Type of sprinklers calculated: Upright  
No. of sprinklers calculated: 10  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):

From Water Supply at Node 1: 310.62 @ 51.897

(Safety Margin = 10.632)

Type of System: wet

Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

## Notes:

Automatic peaking results Left: 51.897 Right: 51.897

FPET NICET #106245 LEVEL IV,MSME




# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: 7

N<sup>1.85</sup>

Date: 5/15/2023

**Supply  
Summary Sheet  
Node: 1**





# Summary Of Outflowing Devices

Job Number: 22-3688

Report Description: Light Hazard (7)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	7000	22.19	19.60	5.6	15.697		
Sprinkler	7001	22.09	19.60	5.6	15.564		
Sprinkler	7002	22.12	19.60	5.6	15.604		
Sprinkler	7003	21.50	19.60	5.6	14.737		
Sprinkler	7004	21.41	19.60	5.6	14.611		
Sprinkler	7005	20.06	19.60	5.6	12.834		
Sprinkler	7006	19.94	19.60	5.6	12.674		
Sprinkler	7007	21.85	19.60	5.6	15.222		
Sprinkler	7008	19.87	19.60	5.6	12.584		
⇒ Sprinkler	<b>7009</b>	<b>19.60</b>	<b>19.60</b>	<b>5.6</b>	<b>12.250</b>		

⇒ Most Demanding Sprinkler Data

<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	64.000	20.000	1950.00	62.529	310.62	51.897

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-10'-4	Supply	51.897	210.62	
7000	28'-3	Sprinkler	15.697	22.19	
7001	28'-3	Sprinkler	15.564	22.09	
7002	28'-3	Sprinkler	15.604	22.12	
7003	28'-3	Sprinkler	14.737	21.50	
7004	28'-3	Sprinkler	14.611	21.41	
7005	28'-2½	Sprinkler	12.834	20.06	
7006	28'-2½	Sprinkler	12.674	19.94	
7007	28'-2½	Sprinkler	15.222	21.85	
7008	28'-3	Sprinkler	12.584	19.87	
7009	28'-3	Sprinkler	12.250	19.60	
2	-10'-4		51.830		
3	-10'-4		49.817		
6	-10'-4		48.194		
7	-4'-1½		45.321		
8	7'-2½		40.345		
600	26'-6		28.618		
601	26'-6		27.354		
602	26'-6		26.210		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
700	26'-6		21.292		
701	26'-6		17.507		
702	26'-6		18.417		
704	26'-6		17.366		
705	26'-6		17.345		
706	26'-6		16.487		
707	26'-6		16.354		
708	26'-6		16.938		
709	26'-6		14.464		
710	26'-6		14.760		
711	26'-6		16.941		
712	26'-6		14.295		
713	26'-6		14.391		
714	26'-6		16.543		



Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
7009	28'-3	5.6	19.60	1	(See Notes)	4'-1	120	12.250	***** Route 1 ***** Sprinkler, E(2'-0), PO(5'-0)
713	26'-6		19.60	1.0490		7'-0	0.125357	0.750	
						11'-1		1.391	
713	26'-6		19.94	1½		1'-7	120	14.391	Flow (q) from Route 3
709	26'-6		39.54	1.6820		1'-7	0.046061	0.074	
709	26'-6		20.06	1½		3'-0	120	14.464	Flow (q) from Route 4
710	26'-6		59.60	1.6820		3'-0	0.098416	0.295	
710	26'-6		19.87	1½	(See Notes)	3'-1½	120	14.760	Flow (q) from Route 2 PO(9'-11)
711	26'-6		79.46	1.6820		9'-11	0.167568		
						13'-0		2.182	
711	26'-6		21.85	2½		13'-8½	120	16.941	Flow (q) from Route 7
705	26'-6		101.31	2.6350		13'-8½	0.029507	0.404	
705	26'-6		42.90 + 22.12	2½		14'-6	120	17.345	Flow (q) from Route 5 and 9
702	26'-6		166.34	2.6350		14'-6	0.073838	1.072	
702	26'-6		44.28	2½		25'-2	120	18.417	Flow (q) from Route 8
700	26'-6		210.62	2.6350		25'-2	0.114264	2.874	
700	26'-6			2½	(See Notes)	117'-8½	120	21.292	T(16'-5½), 2E(8'-3), PO(16'-5½)
601	26'-6		113.28	2.6350		49'-5	0.036279	0.000	
						167'-1½		6.063	
601	26'-6		97.33	3	(See Notes)	11'-0	120	27.354	Flow (q) from Route 11 PO(20'-2)
600	26'-6		210.62	3.2600		20'-2	0.040527		
						31'-2		1.263	
600	26'-6			6	(See Notes)	70'-4½	120	28.618	5E(17'-7), f(-0.000), f(-3.000), CV(17'-2½), BV(17'-7), PO(37'-8½)
8	7'-2½		210.62	6.3570		160'-6½	0.001568	8.365	
						230'-11½		3.362	
8	7'-2½			6	(See Notes)	21'-0½	120	40.345	E(17'-7)
7	-4'-1½		210.62	6.3570		17'-7	0.001568	4.915	
						38'-7½		0.061	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
7	-4'-1½			6	(See Notes)	86'-3½	140	45.321		
6	-10'-4		210.62	6.3400		69'-4	0.001194	2.688		
						155'-7½		0.186		
6	-10'-4			6	(See Notes)	4'-1½	140	48.194	BFP(-1.654)	
3	-10'-4		210.62	6.3400		4'-1½	0.001194	1.622		
3	-10'-4			6	(See Notes)	11'-2½		140	49.817	PIV(-2.000)
2	-10'-4		210.62	6.3400		11'-2½	0.001194	2.013		
2	-10'-4			6	(See Notes)	21'-7		140	51.830	E(23'-1½), EE(11'-6½), S
1	-10'-4		210.62	6.3400		34'-8	0.001194			
						56'-3		0.067		
			100.00					51.897	Hose Allowance At Source	
1			310.62						Total(Pt) Route 1	
7008	28'-3	5.6	19.87	1	(See Notes)	4'-1	120	12.584	***** Route 2 ***** Sprinkler, E(2'-0), PO(5'-0)	
						7'-0	0.128515	0.750		
710	26'-6		19.87	1.0490		11'-1		1.426		
								14.760	Total(Pt) Route 2	
7006	28'-2½	5.6	19.94	1	(See Notes)	1'-9	120	12.674	***** Route 3 ***** Sprinkler, PO(5'-0)	
712	26'-6		19.94	1.0490		5'-0	0.129369	0.750		
						6'-9		0.871		
712	26'-6			1½	(See Notes)	7'-5	120	14.295	Total(Pt) Route 3	
713	26'-6		19.94	1.6820		7'-5	0.012979	0.096		
								14.391	Total(Pt) Route 3	
7005	28'-2½	5.6	20.06	1	(See Notes)	1'-9	120	12.834	***** Route 4 ***** Sprinkler, PO(5'-0)	
709	26'-6		20.06	1.0490		5'-0	0.130875	0.750		
						6'-9		0.881		
								14.464	Total(Pt) Route 4	
7004	28'-3	5.6	21.41	1	(See Notes)	1'-9	120	14.611	***** Route 5 ***** Sprinkler, PO(5'-0)	
707	26'-6		21.41	1.0490		5'-0	0.147558	0.750		
						6'-9		0.993		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
707	26'-6			1½		9'-0	120	16.354	
706	26'-6		21.41	1.6820		9'-0	0.014804	0.133	
706	26'-6		21.50	1½	(See Notes)	6'-1½	120	16.487	
705	26'-6		42.90	1.6820		9'-11	0.053578	0.858	Flow (q) from Route 6 PO(9'-11)
								17.345	Total(Pt) Route 5
7003	28'-3	5.6	21.50	1	(See Notes)	1'-9	120	14.737	..... Route 6 ..... Sprinkler, PO(5'-0)
706	26'-6		21.50	1.0490		5'-0	0.148728	0.750	
						6'-9		1.001	
								16.487	Total(Pt) Route 6
7007	28'-2½	5.6	21.85	1	(See Notes)	1'-9	120	15.222	..... Route 7 ..... Sprinkler, E(2'-0)
714	26'-6		21.85	1.0490		2'-0	0.153253	0.750	
						3'-9		0.572	
714	26'-6			1¼	(See Notes)	3'-10½	120	16.543	PO(6'-0)
711	26'-6		21.85	1.3800		6'-0	0.040306		
						9'-10½		0.398	
								16.941	Total(Pt) Route 7
7001	28'-3	5.6	22.09	1	(See Notes)	1'-9	120	15.564	..... Route 8 ..... Sprinkler, PO(5'-0)
704	26'-6		22.09	1.0490		5'-0	0.156435	0.750	
						6'-9		1.053	
704	26'-6			1½		9'-0	120	17.366	
701	26'-6		22.09	1.6820		9'-0	0.015694	0.141	
701	26'-6		22.19	1½	(See Notes)	6'-1½	120	17.507	
702	26'-6		44.28	1.6820		9'-11	0.056801	0.910	Flow (q) from Route 10 PO(9'-11)
								18.417	Total(Pt) Route 8
7002	28'-3	5.6	22.12	1	(See Notes)	1'-9	120	15.604	..... Route 9 ..... Sprinkler, E(2'-0)
708	26'-6		22.12	1.0490		2'-0	0.156804	0.750	
						3'-9		0.585	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes  Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
		Friction(Pf)							
708	26'-6			1¼	(See Notes)	3'-10½	120	16.938	PO(6'-0)
705	26'-6		22.12	1.3800		6'-0	0.041240	0.000	
						9'-10½		0.407	
								17.345	
7000	28'-3	5.6	22.19	1	(See Notes)	1'-9	120	15.697	••••• Route 10 ••••• Sprinkler,  PO(5'-0)
701	26'-6		22.19	1.0490		5'-0	0.157670	0.750	
						6'-9		1.061	
								17.507	
700	26'-6			2½	(See Notes)	113'-7	120	21.292	••••• Route 11 ••••• T(16'-5½)  4E(8'-3), PO(16'-5½)
602	26'-6		97.33	2.6350		65'-11	0.027399	0.000	
						179'-6		4.918	
602	26'-6			3	(See Notes)	117'-9½	120	26.210	
601	26'-6		97.33	3.2600			0.009718		
						117'-9½		1.145	
								27.354	Total(Pt) Route 11

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L22-R041-Plans

Calculation Date: 5/15/2023

## Design

Remote Area Number: 8  
Remote Area Location: E Over hang  
Occupancy Classification: Light Hazard  
Commodity Classification: N/A

Density 0.10gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 1091ft<sup>2</sup>)  
Coverage per Sprinkler: 130ft<sup>2</sup>  
Type of sprinklers calculated: Pendent  
No. of sprinklers calculated: 8  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 222.56 @ 36.530 (Safety Margin = 26.676)  
Type of System: Dry  
Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

## Notes:

Automatic peaking results Left: N/A Right: N/A

FPET NICET #106245 LEVEL IV,MSME




# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: 8

N<sup>1.85</sup>

Date: 5/15/2023

**Supply  
Summary Sheet  
Node: 1**





# Summary Of Outflowing Devices

Job Number: 22-3688  
Report Description: Light Hazard (8)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	8400	15.90	13.00	5.6	8.066		
Sprinkler	8401	16.06	13.00	5.6	8.225		
Sprinkler	8402	15.48	13.00	5.6	7.640		
Sprinkler	8403	15.33	13.00	5.6	7.497		
Sprinkler	8404	14.92	13.00	5.6	7.102		
Sprinkler	8405	15.07	13.00	5.6	7.245		
➔ <b>Sprinkler</b>	<b>8406</b>	<b>14.82</b>	<b>13.00</b>	<b>5.6</b>	<b>7.000</b>		
Sprinkler	8407	14.97	13.00	5.6	7.142		

➔ Most Demanding Sprinkler Data



<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	64.000	20.000	1950.00	63.206	222.56	36.530

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-10'-4	Supply	36.530	122.56	
8400	24'-6	Sprinkler	8.066	15.90	
8401	24'-4	Sprinkler	8.225	16.06	
8402	24'-4	Sprinkler	7.640	15.48	
8403	24'-5	Sprinkler	7.497	15.33	
8404	24'-4	Sprinkler	7.102	14.92	
8405	24'-4	Sprinkler	7.245	15.07	
8406	24'-4	Sprinkler	7.000	14.82	
8407	24'-4	Sprinkler	7.142	14.97	
2	-10'-4		36.506		
3	-10'-4		34.501		
6	-10'-4		32.988		
7	-4'-1½		30.232		
8	7'-2½		25.294		
800	26'-9		10.545		
801	16'-2½		15.459		
802	26'-9		9.551		
803	26'-9		9.383		
804	26'-9		8.166		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
805	25'-4		7.913		
806	26'-9		7.997		
807	25'-6		7.751		
808	25'-4		7.320		
809	25'-5		7.175		
810	26'-9		7.516		
811	26'-9		7.344		
812	26'-9		6.880		
813	25'-4		6.920		
814	25'-4		6.774		
815	26'-9		7.039		
816	26'-9		6.768		
817	25'-4		6.815		
818	25'-4		6.671		
819	26'-9		6.924		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
8406	24'-4	5.6	14.82	1	(See Notes)	1'-0	100	7.000	..... Route 1 ..... Sprinkler
818	25'-4		14.82	1.0490			0.104671	-0.434	
						1'-0		0.105	
818	25'-4			1	(See Notes)	2'-5	120	6.671	E(2'-0), PO(5'-0)
816	26'-9		14.82	1.0490		7'-0	0.074703	-0.606	
						9'-5		0.702	
816	26'-9			1½		15'-0	120	6.768	
812	26'-9		14.82	1.6820			0.007495		
						15'-0		0.112	
812	26'-9		14.92	1½	(See Notes)	13'-6	120	6.880	Flow (q) from Route 2 2E(4'-11½)
810	26'-9		29.74	1.6820		9'-11	0.027199		
						23'-5		0.636	
810	26'-9		15.48	1½		11'-0	120	7.516	Flow (q) from Route 6
804	26'-9		45.22	1.6820			0.059050		
						11'-0		0.650	
804	26'-9		16.06	1½	(See Notes)	3'-5½	120	8.166	Flow (q) from Route 8 PO(9'-11)
802	26'-9		61.28	1.6820		9'-11	0.103612		
						13'-4½		1.385	
802	26'-9		61.28	2½	(See Notes)	7'-2½	120	9.551	Flow (q) from Route 3 2E(8'-3)
800	26'-9		122.56	2.6350		16'-5½	0.041963		
						23'-8		0.993	
800	26'-9			3	(See Notes)	10'-6½	120	10.545	E(7'-0)
801	16'-2½		122.56	3.0680		7'-0	0.020002	4.564	
						17'-6½		0.351	
801	16'-2½			3	(See Notes)	99'-4½	120	15.459	6E(9'-5), f(-3.000), CV(7'-1½), BV(13'-5½), PO(20'-2)
8	7'-2½		122.56	3.2600		97'-2	0.014883	3.910	
						196'-6½		5.925	
8	7'-2½			6	(See Notes)	21'-0½	120	25.294	E(17'-7)
7	-4'-1½		122.56	6.3570		17'-7	0.000576	4.915	
						38'-7½		0.022	
7	-4'-1½			6	(See Notes)	86'-3½	140	30.232	3E(23'-1½)
6	-10'-4		122.56	6.3400		69'-4	0.000439	2.688	
						155'-7½		0.068	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
6	-10'-4			6	(See Notes)	4'-1½	140	32.988		
3	-10'-4		122.56	6.3400		4'-1½	0.000439	1.513		
3	-10'-4			6	(See Notes)	11'-2½	140	34.501	PIV(-2.000)	
2	-10'-4		122.56	6.3400		11'-2½	0.000439	2.005		
2	-10'-4			6	(See Notes)	21'-7	140	36.506	E(23'-1½), EE(11'-6½), S	
1	-10'-4		122.56	6.3400		34'-8	0.000439	0.025		
						56'-3				
			100.00					36.530	Hose Allowance At Source	
1			222.56						Total(Pt) Route 1	
8404	24'-4	5.6	14.92	1	(See Notes)	1'-0	100	7.102	..... Route 2 ..... Sprinkler	
814	25'-4		14.92	1.0490		1'-0	0.106075	-0.434		
814	25'-4			1	(See Notes)	2'-5	120	6.774	E(2'-0), PO(5'-0)	
812	26'-9		14.92	1.0490		7'-0	0.075706	-0.606		
						9'-5		0.711		
								6.880	Total(Pt) Route 2	
8407	24'-4	5.6	14.97	1	(See Notes)	1'-0	100	7.142	..... Route 3 ..... Sprinkler	
817	25'-4		14.97	1.0490		1'-0	0.106630	-0.434		
817	25'-4			1	(See Notes)	2'-5	120	6.815	E(2'-0), PO(5'-0)	
819	26'-9		14.97	1.0490		7'-0	0.076101	-0.606		
						9'-5		0.715		
819	26'-9			1½		15'-0	120	6.924		
815	26'-9		14.97	1.6820		15'-0	0.007635	0.115		
815	26'-9		15.07	1½		11'-0	120	7.039	Flow (q) from Route 4	
811	26'-9		30.04	1.6820		11'-0	0.027707	0.305		
811	26'-9		15.33	1½		11'-0	120	7.344	Flow (q) from Route 5	
806	26'-9		45.37	1.6820		11'-0	0.059421	0.654		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
	Node 2		Elev 2 (Foot)	Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	
Total (Foot)		Friction(Pf)							
806	26'-9"		15.90	1½"	(See Notes)	3'-5½"	120	7.997	
803	26'-9"		61.28	1.6820		9'-11"	0.103603		
						13'-4½"			1.385
803	26'-9"			2½"		14'-6"	120	9.383	
802	26'-9"		61.28	2.6350		14'-6"	0.011640	0.169	
								9.551	Total(Pt) Route 3
8405	24'-4"	5.6	15.07	1"	(See Notes)	1'-0"	100	7.245	..... Route 4 ..... Sprinkler
813	25'-4"		15.07	1.0490		1'-0"	0.108058	-0.434	
								0.108	
813	25'-4"			1"	(See Notes)	2'-5"	120	6.920	E(2'-0"), PO(5'-0")
						7'-0"	0.077121	-0.606	
815	26'-9"		15.07	1.0490		9'-5"			
								7.039	Total(Pt) Route 4
8403	24'-5"	5.6	15.33	1"	(See Notes)	1'-0"	100	7.497	..... Route 5 ..... Sprinkler
809	25'-5"		15.33	1.0490		1'-0"	0.111528	-0.434	
								0.112	
809	25'-5"			1"	(See Notes)	2'-4"	120	7.175	E(2'-0"), PO(5'-0")
						7'-0"	0.079598	-0.574	
811	26'-9"		15.33	1.0490		9'-4"			
								7.344	Total(Pt) Route 5
8402	24'-4"	5.6	15.48	1"	(See Notes)	1'-0"	100	7.640	..... Route 6 ..... Sprinkler
808	25'-4"		15.48	1.0490		1'-0"	0.113498	-0.434	
								0.113	
808	25'-4"			1"	(See Notes)	2'-11"	120	7.320	E(2'-0"), PO(5'-0")
						7'-0"	0.081003	-0.606	
810	26'-9"		15.48	1.0490		9'-11"			
								7.516	Total(Pt) Route 6
8400	24'-6"	5.6	15.90	1"	(See Notes)	1'-0"	100	8.066	..... Route 7 ..... Sprinkler
807	25'-6"		15.90	1.0490		1'-0"	0.119330	-0.434	
								0.119	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	<b>Notes</b> Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a <b>negative value</b> .
807	25'-6			1	(See Notes)	2'-3	120	7.751	
806	26'-9		15.90	1.0490		7'-0	0.085166	-0.542	
						9'-3		0.788	
								7.997	Total(Pt) Route 7
8401	24'-4	5.6	16.06	1	(See Notes)	1'-0	100	8.225	..... <b>Route 8</b> ..... Sprinkler
805	25'-4		16.06	1.0490		1'-0	0.121513	-0.434	
								0.122	
805	25'-4			1	(See Notes)	2'-11	120	7.913	E(2'-0), PO(5'-0)
804	26'-9		16.06	1.0490		7'-0	0.086724	-0.606	
						9'-11		0.858	
								8.166	Total(Pt) Route 8

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L23-R040-Plans

Calculation Date: 5/15/2023

## Design

Remote Area Number: 9  
Remote Area Location: 3rd flooor orgainc labna  
Occupancy Classification: Ordinary Group II  
Commodity Classification: N/A

Density 0.20gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 969ft<sup>2</sup>)  
Coverage per Sprinkler: 130ft<sup>2</sup>  
Type of sprinklers calculated: Pendent  
No. of sprinklers calculated: 10  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 250.00 at Node: 1 Type: Allowance at Source


Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 515.36 @ 44.470 (Safety Margin = 15.778)  
Type of System: Wet  
Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

## Notes:

Automatic peaking results Left: 44.361 Right: 44.527

FPET NICET #106245 LEVEL IV,MSME






# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: 9

N<sup>1.85</sup>

Date: 5/15/2023

**Supply  
Summary Sheet  
Node: 1**





# Summary Of Outflowing Devices

Job Number: 22-3688

Report Description: Ordinary Group II (9)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	9200	26.46	26.00	8	10.943		
Sprinkler	9201	26.05	26.00	8	10.604		
⇒ Sprinkler	<b>9202</b>	<b>26.00</b>	<b>26.00</b>	<b>8</b>	<b>10.563</b>		
Sprinkler	9203	26.39	26.00	8	10.878		
Sprinkler	9204	26.39	26.00	8	10.878		
Sprinkler	9205	26.00	26.00	8	10.566		
Sprinkler	9206	27.75	26.00	8	12.032		
Sprinkler	9207	26.46	26.00	8	10.937		
Sprinkler	9208	27.75	26.00	8	12.031		
Sprinkler	9209	26.11	26.00	8	10.656		

⇒ Most Demanding Sprinkler Data

<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	64.000	20.000	1950.00	60.248	515.36	44.470

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-10'-4	Supply	44.470	265.36	
9200	39'-2	Sprinkler	10.943	26.46	
9201	39'-2	Sprinkler	10.604	26.05	
9202	39'-2	Sprinkler	10.563	26.00	
9203	39'-2	Sprinkler	10.878	26.39	
9204	39'-2	Sprinkler	10.878	26.39	
9205	39'-2	Sprinkler	10.566	26.00	
9206	39'-2	Sprinkler	12.032	27.75	
9207	39'-2	Sprinkler	10.937	26.46	
9208	39'-2	Sprinkler	12.031	27.75	
9209	39'-2	Sprinkler	10.656	26.11	
2	-10'-4		44.367		
3	-10'-4		42.346		
6	-10'-4		40.631		
7	-4'-1½		37.659		
8	7'-2½		32.651		
900	44'-6		13.003		
901	44'-6		12.035		
902	44'-6		11.892		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
903	44'-6		11.841		
904	44'-6		11.797		
905	44'-6		9.211		
906	40'-6		10.031		
907	44'-6		8.855		
908	40'-6		10.370		
909	44'-6		9.143		
910	40'-6		9.990		
911	44'-6		8.812		
912	40'-6		10.306		
913	44'-6		9.143		
914	40'-6		10.306		
915	40'-6		9.993		
916	44'-6		8.815		
917	40'-6		11.459		
918	40'-6		10.365		
919	44'-6		10.352		
920	44'-6		9.205		
921	40'-6		11.458		
922	44'-6		10.351		
923	40'-6		10.071		
924	44'-6		8.908		
925	44'-6		10.694		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
926	44'-6		10.702		
927	44'-6		10.733		
928	44'-6		10.781		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
9202	39'-2	8	26.00	1	(See Notes)	0'-0	120	10.563	.....Route 1..... Sprinkler, , fd
910	40'-6		26.00	1.0490		0'-0	0.211435	-0.573	
								0.000	
910	40'-6			1¼	(See Notes)	4'-0	120	9.990	PO(6'-0)
911	44'-6		26.00	1.3800		6'-0	0.055609	-1.734	
						10'-0		0.556	
911	44'-6			2		10'-11½	120	8.812	
907	44'-6		20.20	2.1570		10'-11½	0.003959	0.043	
907	44'-6		26.05	2	(See Notes)	122'-7	120	8.855	Flow (q) from Route 3 T(12'-3½), 3E(6'-2), PO(12'-3½)
902	44'-6		46.25	2.1570		43'-1	0.018332		
						165'-8		3.037	
902	44'-6		165.75	4		12'-10	120	11.892	Flow (q) from Route 2
901	44'-6		212.00	4.2600		12'-10	0.011147	0.143	
901	44'-6		53.36	4	(See Notes)	31'-0	120	12.035	Flow (q) from Route 5 2E(13'-2)
900	44'-6		265.36	4.2600		26'-4	0.016886		
						57'-4		0.968	
900	44'-6			6	(See Notes)	58'-5	120	13.003	4E(17'-7), f(-0.000), f(-3.000), CV(17'-2½), BV(17'-7), PO(37'-8½)
8	7'-2½		265.36	6.3570		142'-11½	0.002404	16.163	
						201'-4½		3.484	
8	7'-2½			6	(See Notes)	21'-0½	120	32.651	E(17'-7)
7	-4'-1½		265.36	6.3570		17'-7	0.002404	4.915	
						38'-7½		0.093	
7	-4'-1½			6	(See Notes)	86'-3½	140	37.659	3E(23'-1½)
6	-10'-4		265.36	6.3400		69'-4	0.001831	2.688	
						155'-7½		0.285	
6	-10'-4			6	(See Notes)	4'-1½	140	40.631	BFP(-1.698)
3	-10'-4		265.36	6.3400		4'-1½	0.001831	1.715	
3	-10'-4			6	(See Notes)	11'-2½	140	42.346	PIV(-2.000)
2	-10'-4		265.36	6.3400		11'-2½	0.001831	2.021	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
2	-10'-4			6	(See Notes)	21'-7	140	44.367	E(23'-1½), EE(11'-6½), S
1	-10'-4		265.36	6.3400		34'-8	0.001831		
						56'-3		0.103	
			250.00					44.470	Hose Allowance At Source
1			515.36						Total(Pt) Route 1
9205	39'-2	8	26.00	1	(See Notes)	0'-0	120	10.566	..... Route 2 ..... Sprinkler, , fd
915	40'-6		26.00	1.0490		0'-0	0.211491	-0.573	
								0.000	
915	40'-6			1¼	(See Notes)	4'-0	120	9.993	PO(6'-0)
						6'-0	0.055623	-1.734	
916	44'-6		26.00	1.3800		10'-0		0.556	
916	44'-6		5.80	2		10'-1½	120	8.815	Flow (q) from Route 12
924	44'-6		31.81	2.1570			0.009173		
						10'-1½		0.093	
924	44'-6		26.11	2	(See Notes)	52'-3	120	8.908	Flow (q) from Route 4 PO(12'-3½)
						12'-3½	0.027801		
926	44'-6		57.92	2.1570		64'-6½		1.794	
926	44'-6		52.33	4		9'-4½	120	10.702	Flow (q) from Route 7
927	44'-6		110.26	4.2600			0.003326		
						9'-4½		0.031	
927	44'-6		25.09	4		9'-9½	120	10.733	Flow (q) from Route 11
928	44'-6		135.34	4.2600			0.004859		
						9'-9½		0.048	
928	44'-6			4	(See Notes)	239'-6	120	10.781	4E(13'-2)
						52'-8	0.003477		
904	44'-6		112.95	4.2600		292'-2		1.016	
904	44'-6		22.39	4		9'-2½	120	11.797	Flow (q) from Route 14
903	44'-6		135.34	4.2600			0.004859		
						9'-2½		0.045	
903	44'-6		30.41	4		7'-2	120	11.841	Flow (q) from Route 9
902	44'-6		165.75	4.2600			0.007070		
						7'-2		0.051	
								11.892	Total(Pt) Route 2

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
9201	39'-2	8	26.05	1	(See Notes)	0'-0	120	10.604		
906	40'-6		26.05	1.0490		0'-0	0.212200	-0.573		
906	40'-6			1 1/4	(See Notes)	4'-0	120	10.031		
907	44'-6		26.05	1.3800		6'-0	0.055810	-1.734	PO(6'-0)	
						10'-0		0.558		
								8.855		Total(Pt) Route 3
9209	39'-2	8	26.11	1	(See Notes)	0'-0	120	10.656	***** Route 4 ***** Sprinkler, , fd	
923	40'-6		26.11	1.0490		0'-0	0.213157	-0.585		
923	40'-6			1 1/4	(See Notes)	3'-11 1/2	120	10.071		
924	44'-6		26.11	1.3800		6'-0	0.056062	-1.722	PO(6'-0)	
						9'-11 1/2		0.559		
								8.908		Total(Pt) Route 4
9204	39'-2	8	26.39	1	(See Notes)	0'-0	120	10.878	***** Route 5 ***** Sprinkler, , fd	
914	40'-6		26.39	1.0490		0'-0	0.217274	-0.573		
914	40'-6			1 1/4	(See Notes)	4'-0	120	10.306		
913	44'-6		26.39	1.3800		6'-0	0.057144	-1.734	PO(6'-0)	
						10'-0		0.571		
913	44'-6			2		9'-2	120	9.143		
909	44'-6		0.51	2.1570		9'-2	0.000004	0.000		
909	44'-6		26.39	2		10'-1	120	9.143	Flow (q) from Route 6	
905	44'-6		26.89	2.1570		10'-1	0.006725	0.068		
905	44'-6		26.46	2	(See Notes)	105'-11 1/2	120	9.211		
901	44'-6		53.36	2.1570		12'-3 1/2	0.023886		Flow (q) from Route 8 PO(12'-3 1/2)	
						118'-3		2.824		
								12.035		Total(Pt) Route 5
9203	39'-2	8	26.39	1	(See Notes)	0'-0	120	10.878	***** Route 6 ***** Sprinkler, , fd	
912	40'-6		26.39	1.0490		0'-0	0.217275	-0.573		
								0.000		



Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
912	40'-6			1¼	(See Notes)	4'-0	120	10.306	PO(6'-0)
909	44'-6		26.39	1.3800		6'-0	0.057144	-1.734	
						10'-0		0.571	
								9.143	Total(Pt) Route 6
9207	39'-2	8	26.46	1	(See Notes)	0'-0	120	10.937	..... Route 7 ..... Sprinkler, , fd
918	40'-6		26.46	1.0490		0'-0	0.218365	-0.573	
918	40'-6			1¼	(See Notes)	4'-0		120	10.365
920	44'-6		26.46	1.3800		6'-0	0.057431	-1.734	
						10'-0		0.574	
920	44'-6		25.88	2	(See Notes)	52'-3½	120	9.205	Flow (q) from Route 13 PO(12'-3½)
925	44'-6		52.33	2.1570		12'-3½	0.023044		
						64'-7½		1.489	
925	44'-6			4	(See Notes)	10'-0½	120	10.694	
926	44'-6		52.33	4.2600		10'-0½	0.000838	0.008	
								10.702	Total(Pt) Route 7
9200	39'-2	8	26.46	1	(See Notes)	0'-0	120	10.943	..... Route 8 ..... Sprinkler, , fd
908	40'-6		26.46	1.0490		0'-0	0.218469	-0.573	
908	40'-6			1¼	(See Notes)	4'-0		120	10.370
905	44'-6		26.46	1.3800		6'-0	0.057459	-1.734	
						10'-0		0.575	
								9.211	Total(Pt) Route 8
9208	39'-2	8	27.75	1	(See Notes)	0'-0	120	12.031	..... Route 9 ..... Sprinkler, , fd
921	40'-6		27.75	1.0490		0'-0	0.238489	-0.573	
921	40'-6			1¼	(See Notes)	4'-0		120	11.458
922	44'-6		27.75	1.3800		6'-0	0.062724	-1.734	
						10'-0		0.627	
922	44'-6			2	(See Notes)	10'-0½	120	10.351	
919	44'-6		2.66	2.1570		10'-0½	0.000093	0.001	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
919	44'-6		27.75	2	(See Notes)	139'-6	120	10.352		
903	44'-6		30.41	2.1570		36'-11	0.008441			
						176'-5			1.489	
								11.841	Total(Pt) Route 9	
9206	39'-2	8	27.75	1	(See Notes)	0'-0	120	12.032	***** Route 10 ***** Sprinkler, , fd	
917	40'-6		27.75	1.0490		0'-0	0.238506	-0.573		
917	40'-6			1¼	(See Notes)	4'-0		120		11.459
919	44'-6		27.75	1.3800		6'-0	0.062728	-1.734	PO(6'-0)	
					10'-0			0.627		
								10.352	Total(Pt) Route 10	
922	44'-6		2.66	2	(See Notes)	52'-3	120	10.351	***** Route 11 ***** Flow (q) from Route 9 PO(12'-3½)	
927	44'-6		25.09	2.1570		12'-3½	0.005913			
						64'-6½				0.382
								10.733	Total(Pt) Route 11	
911	44'-6		20.20	2		8'-0½	120	8.812	***** Route 12 ***** Flow (q) from Route 1	
916	44'-6		5.80	2.1570		8'-0½	0.000394			
										0.003
								8.815	Total(Pt) Route 12	
913	44'-6		0.51	2		9'-10½	120	9.143	***** Route 13 ***** Flow (q) from Route 5	
920	44'-6		25.88	2.1570		9'-10½	0.006262			
										0.062
								9.205	Total(Pt) Route 13	
928	44'-6			2	(See Notes)	187'-4½	120	10.781	***** Route 14 ***** PO(12'-3½) PO(12'-3½)	
904	44'-6		22.39	2.1570		24'-7½	0.004792			
						212'-0				1.016
								11.797	Total(Pt) Route 14	

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L23-R040-Plans

Calculation Date: 5/15/2023

## Design

Remote Area Number: 10  
Remote Area Location: Earth Science B Lab  
Occupancy Classification: Ordinary Group II  
Commodity Classification: N/A

Density: 0.20gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 986ft<sup>2</sup>)  
Coverage per Sprinkler: 130ft<sup>2</sup>  
Type of sprinklers calculated: Pendent  
No. of sprinklers calculated: 10  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 250.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 515.76 @ 47.184 (Safety Margin = 13.058)  
Type of System: Wet  
Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

## Notes:

Automatic peaking results Left: 47.184 Right: 47.184

FPET NICET #106245 LEVEL IV,<sub>MSME</sub>




# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: 10

N<sup>1.85</sup>

Date: 5/15/2023

**Supply  
Summary Sheet  
Node: 1**





# Summary Of Outflowing Devices

Job Number: 22-3688

Report Description: Ordinary Group II (10)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	10000	26.79	26.00	8	11.215		
Sprinkler	10001	26.29	26.00	8	10.798		
Sprinkler	10002	27.57	26.00	8	11.878		
Sprinkler	10003	26.39	26.00	8	10.883		
Sprinkler	10004	26.06	26.00	8	10.614		
Sprinkler	10005	27.50	26.00	8	11.820		
Sprinkler	10006	26.46	26.00	8	10.937		
⇒ Sprinkler	<b>10007</b>	<b>26.00</b>	<b>26.00</b>	<b>8</b>	<b>10.563</b>		
Sprinkler	10008	26.38	26.00	8	10.873		
Sprinkler	10009	26.31	26.00	8	10.820		

⇒ Most Demanding Sprinkler Data

<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	64.000	20.000	1950.00	60.242	515.76	47.184

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-10'-4	Supply	47.184	265.76	
10000	39'-2	Sprinkler	11.215	26.79	
10001	39'-2	Sprinkler	10.798	26.29	
10002	39'-2	Sprinkler	11.878	27.57	
10003	39'-2	Sprinkler	10.883	26.39	
10004	39'-2	Sprinkler	10.614	26.06	
10005	39'-2	Sprinkler	11.820	27.50	
10006	39'-2	Sprinkler	10.937	26.46	
10007	39'-2	Sprinkler	10.563	26.00	
10008	39'-2	Sprinkler	10.873	26.38	
10009	39'-2	Sprinkler	10.820	26.31	
2	-10'-4		47.081		
3	-10'-4		45.060		
6	-10'-4		43.345		
7	-4'-1½		40.371		
8	7'-2½		35.363		
900	44'-6		15.714		
901	44'-6		14.743		
902	44'-6		14.558		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
903	44'-6		14.467		
904	44'-6		14.366		
925	44'-6		13.781		
926	44'-6		13.779		
927	44'-6		13.774		
928	44'-6		13.765		
1019	44'-6		13.464		
1020	44'-6		12.692		
1021	46'-7		10.017		
1022	44'-6		12.677		
1023	47'-0		11.218		
1024	44'-6		12.309		
1025	47'-0		10.609		
1026	46'-7		9.530		
1027	46'-7		10.160		
1028	47'-0		10.541		
1029	46'-7		9.316		
1030	46'-5		9.701		
1031	44'-6		12.193		
1032	46'-5		10.125		
1033	46'-5		9.765		
1034	46'-7		9.255		
1035	46'-5		9.690		



Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1036	46'-5		9.628		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
10007	39'-2	8	26.00	1	(See Notes)	4'-0	120	10.563	..... Route 1 ..... Sprinkler, PO(5'-0), fd
1034	46'-7		26.00	1.0490		5'-0	0.211435	-3.210	
						9'-0		1.903	
1034	46'-7			2		9'-7	120	9.255	
1029	46'-7		26.00	2.1570		9'-7	0.006317	0.061	
1029	46'-7		26.06	2		9'-4½	120	9.316	Flow (q) from Route 2
1026	46'-7		52.06	2.1570		9'-4½	0.022824	0.214	
1026	46'-7		26.29	2	(See Notes)	0'-8	120	9.530	Flow (q) from Route 3 PO(12'-3½)
1027	46'-7		78.35	2.1570		12'-3½	0.048618		
						12'-11½		0.630	
1027	46'-7		26.79	2	(See Notes)	2'-1	120	10.160	Flow (q) from Route 8 PO(10'-0)
1024	44'-6		105.14	2.0670		10'-0	0.103095	0.903	
						12'-1		1.246	
1024	44'-6		105.54	3		9'-1	120	12.309	Flow (q) from Route 4
1022	44'-6		210.69	3.2600		9'-1	0.040552	0.368	
1022	44'-6			4		1'-4½	120	12.677	
1020	44'-6		210.69	4.2600		1'-4½	0.011019	0.015	
1020	44'-6		55.08	4	(See Notes)	19'-3	120	12.692	Flow (q) from Route 9 PO(26'-4)
1019	44'-6		265.76	4.2600		26'-4	0.016933		
						45'-7		0.772	
1019	44'-6			4	(See Notes)	156'-5½	120	13.464	3E(13'-2)
928	44'-6		72.64	4.2600		39'-6	0.001537		
						195'-11½		0.301	
928	44'-6			4		9'-9½	120	13.765	
927	44'-6		55.77	4.2600		9'-9½	0.000942	0.009	
927	44'-6			4		9'-4½	120	13.774	
926	44'-6		39.15	4.2600		9'-4½	0.000490	0.005	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
926	44'-6			4		10'-0½	120	13.779	
925	44'-6		21.75	4.2600		10'-0½	0.000165	0.002	
925	44'-6			2	(See Notes)	187'-4½	120	13.781	PO(12'-3½)
901	44'-6		21.75	2.1570		24'-7½	0.004541	0.963	
						212'-0			PO(12'-3½)
901	44'-6		244.01	4	(See Notes)	31'-0	120	14.743	Flow (q) from Route 11 2E(13'-2)
						26'-4	0.016933		
900	44'-6		265.76	4.2600		57'-4		0.971	
900	44'-6			6	(See Notes)	58'-5	120	15.714	4E(17'-7), f(-0.000), f(-3.000), CV(17'-2½), BV(17'-7), PO(37'-8½)
						142'-11½	0.002411	16.163	
8	7'-2½		265.76	6.3570		201'-4½		3.485	
8	7'-2½			6	(See Notes)	21'-0½	120	35.363	E(17'-7)
						17'-7	0.002411	4.915	
7	-4'-1½		265.76	6.3570		38'-7½		0.093	
7	-4'-1½			6	(See Notes)	86'-3½	140	40.371	3E(23'-1½)
						69'-4	0.001836	2.688	
6	-10'-4		265.76	6.3400		155'-7½		0.286	
6	-10'-4			6	(See Notes)	4'-1½	140	43.345	BFP(-1.698)
							0.001836		
3	-10'-4		265.76	6.3400		4'-1½		1.715	
3	-10'-4			6	(See Notes)	11'-2½	140	45.060	PIV(-2.000)
							0.001836		
2	-10'-4		265.76	6.3400		11'-2½		2.021	
2	-10'-4			6	(See Notes)	21'-7	140	47.081	E(23'-1½), EE(11'-6½), S
						34'-8	0.001836		
1	-10'-4		265.76	6.3400		56'-3		0.103	
			250.00					47.184	Hose Allowance At Source
1			515.76						Total(Pt) Route 1
10004	39'-2	8	26.06	1	(See Notes)	4'-0	120	10.614	••••• Route 2 ••••• Sprinkler, PO(5'-0), fd
						5'-0	0.212397	-3.210	
1029	46'-7		26.06	1.0490		9'-0		1.912	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
								9.316		
10001	39'-2	8	26.29	1	(See Notes)	4'-0	120	10.798		***** Route 3 ***** Sprinkler,  PO(5'-0), fd
						5'-0	0.215787	-3.210		
1026	46'-7		26.29	1.0490		9'-0		1.942		
								9.530	Total(Pt) Route 3	
10009	39'-2	8	26.31	1	(See Notes)	4'-0	120	10.820	***** Route 4 ***** Sprinkler,  PO(5'-0), fd	
						5'-0	0.216198	-3.138		
1036	46'-5		26.31	1.0490		9'-0		1.946		
1036	46'-5			2		9'-7	120	9.628		
							0.006459			
1035	46'-5		26.31	2.1570		9'-7		0.062		
1035	46'-5		26.38	2	(See Notes)	6'-4	120	9.690	Flow (q) from Route 5  PO(12'-3½)	
						12'-3½	0.023338			
1032	46'-5		52.69	2.1570		18'-7½		0.435		
1032	46'-5		52.85	2	(See Notes)	1'-11	120	10.125	Flow (q) from Route 6  PO(10'-0)	
						10'-0	0.103822	0.831		
1031	44'-6		105.54	2.0670		11'-11		1.237		
1031	44'-6			3		10'-3	120	12.193		
							0.011288			
1024	44'-6		105.54	3.2600		10'-3		0.116		
								12.309	Total(Pt) Route 4	
10008	39'-2	8	26.38	1	(See Notes)	4'-0	120	10.873	***** Route 5 ***** Sprinkler,  PO(5'-0), fd	
						5'-0	0.217180	-3.138		
1035	46'-5		26.38	1.0490		9'-0		1.955		
								9.690	Total(Pt) Route 5	
10003	39'-2	8	26.39	1	(See Notes)	4'-0	120	10.883	***** Route 6 ***** Sprinkler,  PO(5'-0), fd	
						5'-0	0.217357	-3.138		
1030	46'-5		26.39	1.0490		9'-0		1.956		
1030	46'-5			2		9'-9½	120	9.701		
							0.006494			
1033	46'-5		26.39	2.1570		9'-9½		0.064		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
1033	46'-5		26.46	2	(See Notes)	3'-0½	120	9.765		
1032	46'-5		52.85	2.1570		12'-3½	0.023464			
						15'-4			0.360	
								10.125	Total(Pt) Route 6	
10006	39'-2	8	26.46	1	(See Notes)	4'-0	120	10.937	..... Route 7 ..... Sprinkler,  PO(5'-0), fd	
1033	46'-5		26.46	1.0490		5'-0	0.218365	-3.138		
						9'-0				1.965
								9.765	Total(Pt) Route 7	
10000	39'-2	8	26.79	1	(See Notes)	4'-0	120	11.215	..... Route 8 ..... Sprinkler,  PO(5'-0), fd	
1021	46'-7		26.79	1.0490		5'-0	0.223492	-3.210		
						9'-0				2.011
1021	46'-7			2	(See Notes)	9'-2	120	10.017	PO(12'-3½)	
1027	46'-7		26.79	2.1570		12'-3½	0.006677			
						21'-5½				0.143
								10.160	Total(Pt) Route 8	
10005	39'-2	8	27.50	1	(See Notes)	4'-0	120	11.820	..... Route 9 ..... Sprinkler,  PO(5'-0), fd	
1028	47'-0		27.50	1.0490		5'-0	0.234626	-3.391		
						9'-0				2.112
1028	47'-0			2	(See Notes)	9'-7	120	10.541	Flow (q) from Route 10  PO(12'-3½)	
1025	47'-0		27.50	2.1570		9'-7	0.007010	0.067		
1025	47'-0		27.57	2	(See Notes)	11'-9	120	10.609	Flow (q) from Route 10  PO(12'-3½)	
1023	47'-0		55.08	2.1570		12'-3½	0.025327			
						24'-1				0.610
1023	47'-0			2	(See Notes)	2'-6	120	11.218	PO(10'-0)	
1020	44'-6		55.08	2.0670		10'-0	0.031170	1.084		
						12'-6				0.390
								12.692	Total(Pt) Route 9	
10002	39'-2	8	27.57	1	(See Notes)	4'-0	120	11.878	..... Route 10 ..... Sprinkler,  PO(5'-0), fd	
1025	47'-0		27.57	1.0490		5'-0	0.235686	-3.391		
						9'-0				2.121
								10.609	Total(Pt) Route 10	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
904	44'-6		16.87 + 193.13	4		9'-2½	120	14.366	••••• Route 11 ••••• Flow (q) from Route 14 and 15
903	44'-6		209.99	4.2600		9'-2½	0.010952	0.101	
903	44'-6		16.62	4		7'-2	120	14.467	
902	44'-6		226.62	4.2600		7'-2	0.012610	0.090	Flow (q) from Route 12
902	44'-6		17.40	4		12'-10	120	14.558	Flow (q) from Route 13
901	44'-6		244.01	4.2600		12'-10	0.014459	0.186	
								14.743	
927	44'-6			2	(See Notes)	201'-9	120	13.774	••••• Route 12 ••••• PO(12'-3½) 4E(6'-2), PO(12'-3½)
903	44'-6		16.62	2.1570		49'-2½	0.002762	0.693	
								14.467	
926	44'-6			2	(See Notes)	203'-11	120	13.779	••••• Route 13 ••••• PO(12'-3½) T(12'-3½), 3E(6'-2), PO(12'-3½)
902	44'-6		17.40	2.1570		55'-4½	0.003003	0.779	
								14.558	
928	44'-6			2	(See Notes)	187'-4½	120	13.765	••••• Route 14 ••••• PO(12'-3½) PO(12'-3½)
904	44'-6		16.87	2.1570		24'-7½	0.002837	0.601	
								14.366	
1019	44'-6		72.64	4	(See Notes)	83'-0½	120	13.464	••••• Route 15 ••••• Flow (q) from Route 1 E(13'-2)
904	44'-6		193.13	4.2600		13'-2	0.009381	0.903	
								14.366	

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L24-R041-Plans

Calculation Date: 5/15/2023

## Design

Remote Area Number: 11  
Remote Area Location: Mech Room Pent house  
Occupancy Classification: Ordinary Group I  
Commodity Classification: N/A

Density: 0.15gpm/ft<sup>2</sup>  
Area of Application: 418ft<sup>2</sup> (Actual 418ft<sup>2</sup>)  
Coverage per Sprinkler: 112ft<sup>2</sup>  
Type of sprinklers calculated: Pendent  
No. of sprinklers calculated: 4  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 250.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 279.78 @ 44.009 (Safety Margin = 18.779)  
Type of System: Wet  
Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

## Notes:

Automatic peaking results Left: N/A Right: N/A

FPET NICET #106245 LEVEL IV, MSME






# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: 11

N<sup>1.85</sup>

Date: 5/15/2023

**Supply  
Summary Sheet  
Node: 1**





# Summary Of Outflowing Devices

Job Number: 22-3688

Report Description: Ordinary Group I (11)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	11000	7.51	7.41	2.8	7.196		
Sprinkler	11001	7.45	7.41	2.8	7.074		
Sprinkler	11002	7.42	7.41	2.8	7.016		
⇒ Sprinkler	<b>11003</b>	<b>7.41</b>	<b>7.41</b>	<b>2.8</b>	<b>7.000</b>		

⇒ Most Demanding Sprinkler Data

<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	64.000	20.000	1950.00	62.788	279.78	44.009

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-10'-4	Supply	44.009	29.78	
11000	57'-9	Sprinkler	7.196	7.51	
11001	57'-9	Sprinkler	7.074	7.45	
11002	57'-9	Sprinkler	7.016	7.42	
11003	57'-9	Sprinkler	7.000	7.41	
2	-10'-4		44.007		
3	-10'-4		42.007		
6	-10'-4		40.553		
7	-4'-1½		37.860		
8	7'-2½		32.943		
755	44'-6		13.473		
900	44'-6		13.772		
901	44'-6		13.755		
902	44'-6		13.752		
903	44'-6		13.750		
904	44'-6		13.749		
925	44'-6		13.737		
926	44'-6		13.737		
927	44'-6		13.737		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
928	44'-6		13.738		
1100	57'-9		7.406		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
11003	57'-9	2.8	7.41	1½	(See Notes)	7'-8½	120	7.000	••••• Route 1 ••••• Sprinkler
11002	57'-9		7.41	1.6820			0.002079	0.000	
						7'-8½		0.016	
11002	57'-9	2.8	7.42	1½	(See Notes)	7'-8	120	7.016	Sprinkler
11001	57'-9		14.82	1.6820			0.007502	0.000	
						7'-8		0.058	
11001	57'-9	2.8	7.45	1½	(See Notes)	7'-8½	120	7.074	Sprinkler
11000	57'-9		22.27	1.6820			0.015930	0.000	
						7'-8½		0.123	
11000	57'-9	2.8	7.51	1½	(See Notes)	2'-9	120	7.196	Sprinkler, E(4'-11½)
1100	57'-9		29.78	1.6820		4'-11½	0.027272	0.000	
						7'-8		0.209	
1100	57'-9			2	(See Notes)	13'-3	120	7.406	f(-0.000), CV(13'-6½), T(12'-3½)
755	44'-6		29.78	2.1570		25'-10	0.008122	5.750	
						39'-1½		0.318	
755	44'-6			2	(See Notes)	119'-3	120	13.473	4E(6'-2), PO(12'-3½)
903	44'-6		13.08	2.1570		36'-11	0.001773		
						156'-2½		0.277	
903	44'-6		12.19	4		7'-2	120	13.750	Flow (q) from Route 2
902	44'-6		25.27	4.2600			0.000218		
						7'-2		0.002	
902	44'-6		2.01	4		12'-10	120	13.752	Flow (q) from Route 4
901	44'-6		27.28	4.2600			0.000251		
						12'-10		0.003	
901	44'-6		2.50	4	(See Notes)	31'-0	120	13.755	Flow (q) from Route 3 2E(13'-2)
900	44'-6		29.78	4.2600		26'-4	0.000295		
						57'-4		0.017	
900	44'-6			6	(See Notes)	58'-5	120	13.772	4E(17'-7), f(-0.000), f(-3.000), CV(17'-2½), BV(17'-7), PO(37'-8½)
8	7'-2½		29.78	6.3570		142'-11½	0.000042	16.163	
						201'-4½		3.008	
8	7'-2½			6	(See Notes)	21'-0½	120	32.943	E(17'-7)
7	-4'-1½		29.78	6.3570		17'-7	0.000042	4.915	
						38'-7½		0.002	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
7	-4'-1½			6	(See Notes)	86'-3½	140	37.860	3E(23'-1½)
6	-10'-4		29.78	6.3400		69'-4	0.000032	2.688	
						155'-7½		0.005	
6	-10'-4			6	(See Notes)	4'-1½	140	40.553	BFP(-1.454)
3	-10'-4		29.78	6.3400		4'-1½	0.000032	1.454	
3	-10'-4			6	(See Notes)	11'-2½		140	42.007
2	-10'-4		29.78	6.3400		11'-2½	0.000032	2.000	
2	-10'-4			6	(See Notes)	21'-7		140	44.007
1	-10'-4		29.78	6.3400		34'-8	0.000032		
						56'-3		0.002	
			250.00					44.009	Hose Allowance At Source
1			279.78						Total(Pt) Route 1
904	44'-6		10.17 + 2.02	4		9'-2½	120	13.749	***** Route 2 ***** Flow (q) from Route 5 and 6
903	44'-6		12.19	4.2600		9'-2½	0.000057	0.001	
									13.750
927	44'-6		16.70	4		9'-4½	120	13.737	***** Route 3 ***** Flow (q) from Route 7
926	44'-6		4.51	4.2600		9'-4½	0.000009	0.000	
926	44'-6			4		10'-0½		120	13.737
925	44'-6		2.50	4.2600		10'-0½	0.000003	0.000	
925	44'-6			2	(See Notes)	187'-4½		120	13.737
901	44'-6		2.50	2.1570		24'-7½	0.000083		PO(12'-3½)
						212'-0		0.018	
								13.755	Total(Pt) Route 3
926	44'-6			2	(See Notes)	203'-11	120	13.737	***** Route 4 ***** PO(12'-3½)
902	44'-6		2.01	2.1570		55'-4½	0.000055		
						259'-3½		0.014	T(12'-3½), 3E(6'-2), PO(12'-3½)
								13.752	Total(Pt) Route 4

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes  Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
					Total (Foot)			Friction(Pf)	
927	44'-6		16.70	4		9'-9½	120	13.737	••••• Route 5 ••••• Flow (q) from Route 7
928	44'-6		12.19	4.2600		9'-9½	0.000057	0.001	
928	44'-6			4	(See Notes)	239'-6	120	13.738	4E(13'-2)
904	44'-6		10.17	4.2600		52'-8	0.000040		
					292'-2		0.012		
								13.749	Total(Pt) Route 5
928	44'-6			2	(See Notes)	187'-4½	120	13.738	••••• Route 6 ••••• PO(12'-3½)
904	44'-6		2.02	2.1570		24'-7½	0.000056		
						212'-0		0.012	
								13.749	Total(Pt) Route 6
755	44'-6		13.08	2	(See Notes)	82'-6	120	13.473	••••• Route 7 ••••• Flow (q) from Route 1
927	44'-6		16.70	2.1570		12'-3½	0.002785		
						94'-9½		0.264	
								13.737	Total(Pt) Route 7

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		



# Hydraulic Calculations

for

Project Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING

Location: 1601 39th AVE SE, Puyallup, WA 98374,

Drawing Name: 22-3688 PeirceSTEM-L10-R041-Standpipe

Calculation Date: 5/16/2023

## Design

Remote Area Number: ROOF TOP HOSE FLOW  
Remote Area Location: ROOF TOP  
Occupancy Classification: ROOF TOP HOSE FLOW  
Commodity Classification: N/A

Density 0.10gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 1340ft<sup>2</sup>)  
Coverage per Sprinkler: 130ft<sup>2</sup>  
Type of sprinklers calculated: NA  
No. of sprinklers calculated: 0  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 0.0 gpm at Node: 4 Type: Allowance at Source  
250.00 at Node: 17 Type: Hose  
250.00 at Node: 19 Type: Hose  
250.00 at Node: 15 Type: Hose

Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 4: 750.00 @ 152.781 (Safety Margin = 1.219)

Type of System: WET  
Volume of Dry/PreAction/Antifreeze/OtherAgent N/A

Name of Contractor: SHINN FIRE PROTECTION  
Address: 18802 80TH AVE S, KENT WA98032  
Phone Number: 425-204-3945  
Name of designer: Ben Bernard  
Authority Having Jurisdiction: CITY OF PUYALLUP

Notes:

Automatic peaking results Left: N/A Right: N/A

FPET NICET #106245 LEVEL IV,MSME




# Hydraulic Graph

Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING  
Remote Area Number: ROOF TOP HOSE FLOW

N<sup>1.85</sup>

Date: 5/16/2023

Water Supply  
Summary Sheet  
Node: 4





# Summary Of Outflowing Devices

Job Number: 22-3688

Report Description: ROOF TOP HOSE FLOW (ROOF TOP HOSE FLOW)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Hose	15	250.00	250.00	28.87	101.866		
Hose	17	250.00	250.00	28.87	75.211		
Hose	19	250.00	250.00	28.87	74.987		

⇒ Most Demanding Sprinkler Data

## Supply Analysis

Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
4	Water Supply	154.000	154.000	750.00	154.000	750.00	152.781

## Node Analysis

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
4	-21'-0	Supply	152.781	750.00	
15	22'-10	Hose	101.866	250.00	Hos
17	42'-10	Hose	75.211	250.00	Hos
19	43'-4	Hose	74.987	250.00	Hos
6	-25'-0		146.726		
7	-18'-9½		141.471		
8	-7'-5½		135.921		
12	1'-3½		126.927		
13	1'-3½		123.870		
14	22'-10		111.128		
16	42'-10		84.474		
18	43'-4		84.250		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
19	43'-4		250.00	2½	(See Notes)	0'-0	120	74.987	••••• Route 1 ••••• Hose(-74.987)(31'-0)  PO(12'-0)
18	43'-4		250.00	2.4690		43'-0	0.215409		
						43'-0		9.263	
18	43'-4			4		0'-6	120	84.250	
16	42'-10		250.00	4.2600			0.015122	0.217	
						0'-6		0.008	
16	42'-10		250.00	4	(See Notes)	218'-9	120	84.474	Flow (q) from Route 2 7E(13'-2), PIV(2'-7½), 2T(26'-4), BV(15'-9½), 2EE(5'-3)
13	1'-3½		500.00	4.2600		173'-9½	0.054516	17.995	
						392'-7		21.401	
13	1'-3½		250.00	4		26'-6	120	123.870	Flow (q) from Route 3
12	1'-3½		750.00	4.2600			0.115423	-0.000	
						26'-6		3.056	
12	1'-3½			6	(See Notes)	30'-4½	120	126.927	3E(17'-7), f(-3.000), BV(12'-7), PO(37'-8½)
8	-7'-5½		750.00	6.3570		103'-1	0.016432	3.801	
						133'-5½		5.193	
8	-7'-5½			6	(See Notes)	21'-0½	120	135.921	E(17'-7)
7	-18'-9½		750.00	6.3570		17'-7	0.016432	4.915	
						38'-7½		0.635	
7	-18'-9½			6	(See Notes)	86'-3½	140	141.471	3E(23'-1½), PO(49'-6)
6	-25'-0		750.00	6.3400		118'-10	0.012517	2.688	
						205'-1½		2.568	
6	-25'-0			4	(See Notes)	31'-3	120	146.726	2E(10'-0), S
4	-21'-0		750.00	4.0260		20'-0	0.151978	-1.734	
						51'-3		7.788	
			0.00					152.781	Hose Allowance At Source
4			750.00						Total(Pt) Route 1
17	42'-10		250.00	2½	(See Notes)	0'-0	120	75.211	••••• Route 2 ••••• Hose(-74.987)(31'-0)  PO(12'-0)
16	42'-10		250.00	2.4690		43'-0	0.215409		
						43'-0		9.263	
								84.474	Total(Pt) Route 2

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
15	22'-10		250.00	2½	(See Notes)	0'-0	120	101.866	
14	22'-10		250.00	2.4690		43'-0	0.215409		
						43'-0		9.263	
14	22'-10			4	(See Notes)	64'-10	120	111.128	
13	1'-3½		250.00	4.2600		160'-7½	0.015122	9.333	
						225'-5½		3.410	
								123.870	Total(Pt) Route 3

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Fittings Legend

ALV Alarm Valve	AngV Angle Valve	b Bushing
BalV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		