




1601 39th Ave SE, Puyallup, WA 98374, USA

Latitude, Longitude: 47.1568032, -122.2731117



Date	7/26/2022, 6:33:37 AM
Design Code Reference Document	ASCE7-16
Risk Category	II
Site Class	D - Default (See Section 11.4.3)

Type	Value	Description
S_S	1.254	MCE_R ground motion. (for 0.2 second period)
S_1	0.432	MCE_R ground motion. (for 1.0s period)
S_{MS}	1.504	Site-modified spectral acceleration value
S_{M1}	null -See Section 11.4.8	Site-modified spectral acceleration value
S_{DS}	1.003	Numeric seismic design value at 0.2 second SA
S_{D1}	null -See Section 11.4.8	Numeric seismic design value at 1.0 second SA

Type	Value	Description
SDC	null -See Section 11.4.8	Seismic design category
F_a	1.2	Site amplification factor at 0.2 second
F_v	null -See Section 11.4.8	Site amplification factor at 1.0 second

Type	Value	Description
PGA	0.5	MCE _G peak ground acceleration
F _{PGA}	1.2	Site amplification factor at PGA
PGA _M	0.6	Site modified peak ground acceleration
T _L	6	Long-period transition period in seconds
SsRT	1.254	Probabilistic risk-targeted ground motion. (0.2 second)
SsUH	1.372	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration
SsD	1.5	Factored deterministic acceleration value. (0.2 second)
S1RT	0.432	Probabilistic risk-targeted ground motion. (1.0 second)
S1UH	0.482	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration.
S1D	0.6	Factored deterministic acceleration value. (1.0 second)
PGAd	0.5	Factored deterministic acceleration value. (Peak Ground Acceleration)
C _{RS}	0.914	Mapped value of the risk coefficient at short periods
C _{R1}	0.898	Mapped value of the risk coefficient at a period of 1 s

DISCLAIMER

While the information presented on this website is believed to be correct, SEAOC / OSHPD and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in this web application should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. SEAOC / OSHPD do not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the seismic data provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the search results of this website.

Seismic Brace Report



Project Name Peirce CO. STEM Building
Date 07/26/2022
Address 1601 39th Ave SE
 puyallup, WA 98374

Contractor Shinn Fire protection
 425-203-9800

Engineer Ben Bernard
 425-204-3945

APPROVAL STAMP

- Approved
- Approved as Noted
- Not Approved

Remarks:

Standard NFPA 13-2016

BRACE SUMMARY

Brace Name	Drawing Reference	Seismic Design Load	Structure	Brace Description	Fastener	Attachments
SB-1	FP-2.0 - 2.3	409 lbf.	Horizontal Beam Flange	Lateral Orientation 45° - 90° 1 NPS Sch 40		AF772 Type B AF700 - 1/2" AF730 - 4 NPS
SB-2	FP-2.0 - 2.3	483 lbf.	Horizontal Beam Flange	Longitudinal Orientation 45° - 90° 1 NPS Sch 40		AF772 Type B AF700 - 1/2" AF730 - 4 NPS

NOTE: Per NFPA 13-2016, all load capacities listed for fasteners installed in cracked concrete have been reduced based on the prying factors listed for ASC's swivel attachments. Prying factors for NFPA fastener orientations "A" through "I" may be found in ASC's individual product submittal at asc-es.com

NFPA 13-2016 Product loads incorporate a minimum safety factor of 1.5. NFPA 13-2019 FM Product loads have been reduced to include a safety factor of 2.2 unless noted in the applicable product submittal.

SB-1 - SEISMIC BRACE CALCULATIONS

Seismic Project SB-1
Standard NFPA 13-2016
Brace Type Lateral

Brace Name SB-1
Drawing Reference FP-2.0 - 2.3
Approval Agency UL Listed

STRUCTURE INFORMATION

Structure I-Beam/Joist
Substrate Horizontal Beam Flange
Thickness 1.000 in.
Load Orientation Perpendicular to Beam

BRACE INFORMATION

Brace Member 1 NPS Sch 40
Brace Length Max 3 ft 6 in
Brace Angle 45° - 90°
Least Radius of Gyration 0.421 in.
I/r Ratio Max 100
Max Horizontal Load 4,455 lbf.


FASTENER INFORMATION

Fastener Name N/A

SEISMIC BRACE ATTACHMENTS

	Model	Size	Load Rating
Structural Att.	AF772	Type B	707 lbf.
Swivel Att.	AF700	1/2"	1,333 lbf.
Pipe Att.	AF730	4 NPS	1,333 lbf.

See Appendix A for alternate seismic brace attachments.
 All seismic brace attachments manufactured by ASC Engineered Solutions.



Net Vertical Reaction Forces do not need to be addressed per NFPA 13-2016.

SPRINKLER SYSTEM LOAD CALCULATION ($F_{PW} = C_p * W_p$) $C_p = 0.594$

Qty	Line	Description	Pipe Diameter/Type	Length	Weight per ft	Weight
1	Main	Braced Pipe	4 NPS Steel Sch 10	30.00 ft.	11.78 lb/ft.	353.40 lb.
4	Branch 1	Segment A	1 1/2 NPS Steel Sch 10	20.00 ft.	3.04 lb/ft.	60.80 lb.

Weakest Main Size	Spacing	Max Fpw
4 NPS Steel Sch 10	30 ft.	1,071 lbf.

Total System Weight	596.60 lb.
System Design Weight (W_p)	687 lb.
Horizontal Seismic Load (F_{pw})	409 lbf.

FPET NICET #106245 LEVEL IV, MSME

**WASHINGTON STATE
 CERTIFICATE OF COMPETENCY
 FIRE PROTECTION SPRINKLER SYSTEMS**

Hussein A. A. Huballa
 8321-1119-C Level 3
 Shinn Mechanical, Inc.
 SHINNMI060QP

05/16/2023
Date

Expires
DEC 31, 23

Signature

SB-2 - SEISMIC BRACE CALCULATIONS

Seismic Project SB-1
Standard NFPA 13-2016
Brace Type Longitudinal

Brace Name SB-2
Drawing Reference FP-2.0 - 2.3
Approval Agency UL Listed

STRUCTURE INFORMATION

Structure I-Beam/Joist
Substrate Horizontal Beam Flange
Thickness 1.000 in.
Load Orientation Parallel to Beam

BRACE INFORMATION

Brace Member 1 NPS Sch 40
Brace Length Max 3 ft 6 in
Brace Angle 45° - 90°
Least Radius of Gyration 0.421 in.
I/r Ratio Max 100
Max Horizontal Load 4,455 lbf.


FASTENER INFORMATION

Fastener Name N/A

SEISMIC BRACE ATTACHMENTS

	Model	Size	Load Rating
Structural Att.	AF772	Type B	707 lbf.
Swivel Att.	AF700	1/2"	1,333 lbf.
Pipe Att.	AF730	4 NPS	1,333 lbf.

*See Appendix A for alternate seismic brace attachments.
 All seismic brace attachments manufactured by ASC Engineered Solutions.*



Net Vertical Reaction Forces do not need to be addressed per NFPA 13-2016.

SPRINKLER SYSTEM LOAD CALCULATION ($F_{PW} = C_p * W_p$) $C_p = 0.594$

Qty	Line	Description	Pipe Diameter/Type	Length	Weight per ft	Weight
1	Main	Braced Pipe	4 NPS Steel Sch 10	60.00 ft.	11.78 lb/ft.	706.80 lb.

Total System Weight	706.80 lb.
System Design Weight (W_p)	813 lb.
Horizontal Seismic Load (F_{pw})	483 lbf.

FPET NICET #106245 LEVEL IV, MSME

**WASHINGTON STATE
 CERTIFICATE OF COMPETENCY
 FIRE PROTECTION SPRINKLER SYSTEMS**

Hussein A. A. Huballa
 8321-1119-C Level 3
 Shinn Mechanical, Inc.
 SHINNMI060QP

05/16/2023
Date

Expires
DEC 31, 23

Signature