



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 23, 2023                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCTI20230447

**Property Address:** 2504 E MAIN, PUYALLUP, WA 98372;

**Contractor:** POE CONSTRUCTION INC. PO BOX 899 AUBURN, WA 98071-0899

**To construct:** Installation of manufacturing equipment and machines, crane structure, assembly and testing workstations and storage racking within existing warehouse building. Work includes existing slab modifications for new equipment foundations, equipment anchorage, and new roof penetrations for equipment exhaust piping.

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Nitrogen pipe test complete at 450 psi as noted on sheet p2.1 & p2.2 of City approved plans.

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)