



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 26, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20221802

Property Address: 3500 S MERIDIAN, Unit: 235, PUYALLUP, WA 98373;

Contractor: CANYON CONTRACTING CORP 2821 SKYE RD WASOUGALW, WA 98671

To construct: TI - remodel of (E) retail space including doors, partitions, ceilings, lighting fixtures, etc - (Occupant load of 68) - BATH & BODY WORKS *
REVISION (1) - 04/06/2023 - MINOR BLDG REVISIONS, ANCHORING CHANGES

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 2 1. clean garbage off of roof as discussed with contractor
2. provide plumbing boots at sinks as discussed with contractor
3. seal dog house at MECH on roof
4. TCO 10 working days ok to stock

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590