

May 30, 2023

Development & Permitting Services  
City of Puyallup  
333 S. Meridian  
Puyallup, WA 98371

Attn: David Leahy

RE: **CIMCO-Permit application #PRPF20230347**

Dear Sir or Madam.

We offer the following responses to the various plan review comments, together with updated drawings to correspond:

We have updated the architectural plans to reflect responses to the plan review comments received.

G1.1: Removed the reference to “deferred permits” for mechanical & electrical permits. Note that the mechanical permit has been submitted previously, under #PRMH20230349.

G1.1: Added note addressing travel distance to restroom on the adjacent building; not exceeding 500 ft per 2018 IBC.


A2.0: Added note stating the racking and anchorage to the slab will be a separate permit.

Geotechnical: We are submitting the geotechnical report previously completed for the project, by GeoResources, Inc. dated March 1, 2023.

Metal Building: We are submitting the engineering for the building, including frame reactions, sealed by a WA State licensed engineer, from Varco-Pruden Buildings.

We trust this supplemental information adequately addresses the plan review comments.

Thank you.



James H. Castino  
Principal  
Castino Architecture  
Updated PV (Solar Array) drawing set.  
Updated Mechanical drawing set.  
Electrical/Lighting Set for WSEC Compliance (again)