



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 30, 2023 **Inspection Result:** **PASSED W/
CONDITIONS**

Permit Number: PRRASF20221937

Property Address: 3305 S FRUITLAND, PUYALLUP, WA 98373;

Contractor:

To construct: Remodel existing single family residence increasing size by 387 SF. -
FIELD REVISION PER MJ 5/11/2023 - EXISTING FOUNDATION PLANNED
TO REMAIN UNSTABLE, REPLACE FOUNDATION, ADD 483 SF OF
BASEMENT - SEE REVISED SHEETS S1.1 AND S1.2 - ENGINEER TO
PROVIDE NEW CALCULATION ON SITE TO INSPECTOR - ALL SUBJECT
TO FIELD INSPECTION PER MJ

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. provide letter from engineer of record for wall HT as discussed with contractor
2. provide special inspection report for footing missed on north west corner of foundation
3. dose not include interior footing at stairs
- 4.OK TO POOR

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org