



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 31, 2023

Inspection Result:

**PASSED W/
CONDITIONS**

Permit Number: PRRNSF20220550

Property Address: 2504 12TH AVE NW, PUYALLUP, WA 98371;

Contractor: CHESHIRE CONSTRUCTION LLC P O BOX 716 BUCKLEY, WA 98321

To construct: NEW SFR

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. provide letter from engineer for over cut beam from previous list
2. provide insulation baffles that were missing as discussed with contractor
3. ok to cover

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590