

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

| Date of Inspection: | May 31, 2023 | Inspection Result: | FAILED |
|-------------------------------------|--|--------------------|--------|
| Permit Number: Property Address: | PRCTI20230098 1015 39TH AVE SE, PUYA | ALLUP, WA 98374; | |
| Contractor: | JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA | | |
| | 98108 (206) 702-8193 | | |
| To construct: | Tenant improvement and finish out of the North side of level 1. | | |
| | Improvements include offices, meeting rooms, cardio area, and break | | |
| | rooms. The interior alterations do not increase the building's area, nor | | |
| | do they alter the building egress and/or circulation outside the | | |
| | renovated space. REVISION (1) - 03/17/2023 - OPEN CEILING IN SOME | | |
| | AREAS, CEILING DETAILS, DOOR & WINDOW SCHEDULE UPDATES | | |

On this day we have inspected your construction for **Firewall/Firestop Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1 1; complete firestop at penetration of shaftwall as discussed with contractor.

Sincerely,

, King

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

(253) 840-6684